

**New Source Performance Standard Subpart KKKK
Semi-Annual Report (40 CFR 60.4375)**

Pollutant: NO_x, parts per million by volume correct to 15% oxygen dry basis (ppmvdc)

Emission Limitation: 25 ppmvdc natural gas firing
74 ppmvdc firing fuels other than natural gas

Reporting period dates: From January 1, 2023 to June 30, 2023

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-1

Monitor Manufacturer and Model No.: Micro Motion model 170013ABZEZZZ; Micro Motion model R100S130NCAZEZZX.

Date of Latest CMS Certification or Audit: N/A (there are no applicable “certification or audit” requirements for fuel flow meters and water meters).

Total source operating time in reporting period¹: 1041.5

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 18	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 0	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 0	c. Quality assurance calibration – 0 hours
d. Other known causes – 0	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 18	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 1.7%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%

¹For gases, record all times in hours.

Emission data summary	CMS performance summary
------------------------------	--------------------------------

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.

On a separate page, describe any changes since last quarter in CMS, process or controls.

NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature



Title

Vice President- EEHS & Regulatory

Date

08/29/2025

Excess Emissions

40 CFR 60.7(c) requires that the magnitude of excess emissions be computed in accordance with § 60.13(h)(3), which is in terms of the standard. Per agreement with USEPA, a water injection to fuel ratio between 0.65 and 1.00 demonstrates compliance with the NO_x limits which are in units of parts per million by volume correct to 15% oxygen dry basis (ppmvdc). There are no conversion factors to convert water injection to fuel ratios to ppmvdc. Therefore, the noncompliant water injection to fuel ratios are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CLOCK HOUR AVERAGE	4-HOUR AVERAGE	HOURS EXCESS EMISSIONS	CAUSE
03/15/23	18	10.631	0.396			Startup
03/15/23	19	27.536	0.990			
03/15/23	20	8.622	0.393			Shutdown
* 03/19/23	18	12.816	0.466	0.56	4	

05/22/23	22	7.107	0.290			Shutdown
* 05/23/23	8	19.419	0.729			Startup
05/23/23	9	28.068	0.984			
05/23/23	10	8.300	0.346	0.59	4	Shutdown

06/13/23	22	27.670	0.959			
06/13/23	23	26.172	0.915			
* 06/14/23	0	7.326	0.301			Shutdown
06/14/23	15	6.925	0.312	0.62	4	Startup
06/14/23	16	26.011	0.996	0.63	1	

06/17/23	0	27.695	0.968			
06/17/23	1	10.357	0.444			Shutdown
* 06/20/23	16	8.802	0.467			Unit Trip
* 06/21/23	15	14.184	0.536	0.60	4	Startup
06/21/23	16	27.183	0.942	0.60	1	

* Consecutive unit operating hours with operating load at or above 25%

**New Source Performance Standard Subpart KKKK
Semi-Annual Report (40 CFR 60.4375)**

Pollutant: NO_x, parts per million by volume correct to 15% oxygen dry basis (ppmvdc)

Emission Limitation: 25 ppmvdc natural gas firing
74 ppmvdc firing fuels other than natural gas

Reporting period dates: From July 1, 2023 to December 31, 2023

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-1

Monitor Manufacturer and Model No.: Micro Motion model 170013ABZEZZZ; Micro Motion model R100S130NCAZEZZZX.

Date of Latest CMS Certification or Audit: N/A (there are no applicable “certification or audit” requirements for fuel flow meters and water meters).

Total source operating time in reporting period¹: 1,549

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 18	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 23	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 0	c. Quality assurance calibration – 0 hours
d. Other known causes – 0	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 41	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 2.6%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%

¹For gases, record all times in hours.

Emission data summary**CMS performance summary**

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.


On a separate page, describe any changes since last quarter in CMS, process or controls.

NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature**Title**

Vice President- EEHS & Regulatory

Date

08/29/2025

Excess Emissions

40 CFR 60.7(c) requires that the magnitude of excess emissions be computed in accordance with § 60.13(h)(3), which is in terms of the standard. Per agreement with USEPA, a water injection to fuel ratio between 0.65 and 1.00 demonstrates compliance with the NO_x limits which are in units of parts per million by volume correct to 15% oxygen dry basis (ppmvdc). There are no conversion factors to convert water injection to fuel ratios to ppmvdc. Therefore, the noncompliant water injection to fuel ratios are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CLOCK HOUR AVERAGE	4-HOUR AVERAGE	HOURS EXCESS EMISSIONS	Cause
08/20/23	5	21.879	0.776			
* 08/21/23	11	15.909	0.569			Startup
08/21/23	12	19.250	0.686			Shutdown
* 08/21/23	15	11.737	0.470	0.63	4	Startup

09/17/23	3	23.99	0.898			
09/17/23	4	23.99	0.893			
09/17/23	5	16.05	0.638			Shutdown
* 09/17/23	15	23.14	0.000	0.61	4	Malfunction
09/17/23	16	23.88	0.000	0.38	1	Malfunction
09/17/23	17	23.93	0.000	0.16	1	Malfunction
09/17/23	18	23.97	0.000	0.00	1	Malfunction
09/17/23	19	23.98	0.000	0.00	1	Malfunction
09/17/23	20	23.98	0.000	0.00	1	Malfunction
09/17/23	21	23.98	0.000	0.00	1	Malfunction
09/17/23	22	23.94	0.000	0.00	1	Malfunction
09/17/23	23	23.96	0.000	0.00	1	Malfunction
09/18/23	0	23.96	0.000	0.00	1	Malfunction
09/18/23	1	23.98	0.000	0.00	1	Malfunction
09/18/23	2	23.99	0.000	0.00	1	Malfunction
09/18/23	3	23.95	0.000	0.00	1	Malfunction
09/18/23	4	23.99	0.000	0.00	1	Malfunction
09/18/23	5	23.99	0.000	0.00	1	Malfunction
09/18/23	6	23.97	0.000	0.00	1	Malfunction
09/18/23	7	23.97	0.000	0.00	1	Malfunction
09/18/23	8	23.97	0.239	0.06	1	Malfunction
09/18/23	9	23.98	0.900	0.28	1	
09/18/23	10	23.99	0.923	0.52	1	

09/24/23	7	28.045	0.952			
09/24/23	8	27.438	0.951			
09/24/23	9	7.875	0.321			Shutdown
* 09/24/23	13	7.457	0.313	0.63	4	Startup
09/24/23	14	24.15	0.853	0.61	1	
09/24/23	15	27.55	0.939	0.61	1	

	09/26/23	2	13.154	0.952			
*	09/26/23	9	17.808	0.951			
	09/26/23	10	24.591	0.321			Shutdown
*	09/26/23	14	9.478	0.313	0.63	4	Startup

	11/12/23	22	20.827	0.729			
*	11/17/23	19	21.822	0.774			
	11/17/23	20	8.919	0.353			Shutdown
*	12/05/23	13	13.209	0.490	0.59	4	Startup

* Consecutive unit operating hours with operating load at or above 25%

**New Source Performance Standard Subpart KKKK
Semi-Annual Report (40 CFR 60.4375)**

Pollutant: NO_x, parts per million by volume correct to 15% oxygen dry basis (ppmvdc)

Emission Limitation: 25 ppmvdc natural gas firing
74 ppmvdc firing fuels other than natural gas

Reporting period dates: From January 1, 2024 to June 30, 2024

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-1

Monitor Manufacturer and Model No.: Micro Motion model 170013ABZEEZZZ; Micro Motion model R100S130NCAZEZZZX.

Date of Latest CMS Certification or Audit: N/A (there are no applicable “certification or audit” requirements for fuel flow meters and water meters).

Total source operating time in reporting period¹: 307

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 0	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 0	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 0	c. Quality assurance calibration – 0 hours
d. Other known causes – 0	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 0	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 0%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%

¹ For gases, record all times in hours.

Emission data summary**CMS performance summary**

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.


On a separate page, describe any changes since last quarter in CMS, process or controls.

NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature**Title**

Vice President- EEHS & Regulatory

Date

08/29/2025

Excess Emissions

40 CFR 60.7(c) requires that the magnitude of excess emissions be computed in accordance with § 60.13(h)(3), which is in terms of the standard. Per agreement with USEPA, a water injection to fuel ratio between 0.65 and 1.00 demonstrates compliance with the NO_x limits which are in units of parts per million by volume correct to 15% oxygen dry basis (ppmvdc). There are no conversion factors to convert water injection to fuel ratios to ppmvdc. Therefore, the noncompliant water injection to fuel ratios are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CLOCK HOUR AVERAGE	4-HOUR AVERAGE	HOURS EXCESS EMISSIONS	CAUSE

**New Source Performance Standard Subpart KKKK
Semi-Annual Report (40 CFR 60.4375)**

Pollutant: NO_x, parts per million by volume correct to 15% oxygen dry basis (ppmvdc)

Emission Limitation: 25 ppmvdc natural gas firing
74 ppmvdc firing fuels other than natural gas

Reporting period dates: From July 1, 2024 to December 31, 2024

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-1

Monitor Manufacturer and Model No.: Micro Motion model 170013ABZEZZZ; Micro Motion model R100S130NCAZEZZX.

Date of Latest CMS Certification or Audit: N/A (there are no applicable “certification or audit” requirements for fuel flow meters and water meters).

Total source operating time in reporting period¹: 829

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 17	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 5	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 4	c. Quality assurance calibration – 0 hours
d. Other known causes – 0	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 26	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 3.1%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%

¹ For gases, record all times in hours.

Emission data summary**CMS performance summary**

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.


On a separate page, describe any changes since last quarter in CMS, process or controls.

NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature**Title**

Vice President- EEHS & Regulatory

Date

08/29/2025

Excess Emissions

40 CFR 60.7(c) requires that the magnitude of excess emissions be computed in accordance with § 60.13(h)(3), which is in terms of the standard. Per agreement with USEPA, a water injection to fuel ratio between 0.65 and 1.00 demonstrates compliance with the NO_x limits which are in units of parts per million by volume correct to 15% oxygen dry basis (ppmvdc). There are no conversion factors to convert water injection to fuel ratios to ppmvdc. Therefore, the noncompliant water injection to fuel ratios are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CLOCK HOUR AVERAGE	4-HOUR AVERAGE	HOURS EXCESS EMISSIONS	Cause	
	07/06/24	19	13.050	0.549		Startup/Shutdown	
*	07/11/24	17	11.925	0.537		Startup	
	07/11/24	18	9.402	0.537		Malfunction	
	07/11/24	19	10.670	0.547	0.54	4	Malfunction
	07/11/24	20	7.602	0.481	0.53	1	Malfunction
*	07/12/24	14	19.655	0.761	0.58	1	Startup
	07/12/24	15	8.013	0.341	0.53	1	Shutdown
*	07/12/24	17	17.952	0.681	0.57	1	Startup
	07/12/24	21	24.990	0.911			
	07/12/24	22	22.036	0.813			
*	07/18/24	13	10.020	0.443			Startup/Shutdown
*	07/18/24	16	8.557	0.386	0.64	4	Unit Trip
	08/01/24	8	27.272	0.944			
	08/01/24	9	27.462	0.945			
	08/01/24	10	14.217	0.281			Shutdown
*	08/01/24	14	7.105	0.294	0.62	4	Startup
	08/01/24	15	25.870	0.909	0.61	1	
	08/01/24	16	27.389	0.946	0.61	1	
	08/08/24	20	23.695	0.853			
	08/08/24	21	25.588	0.906			
	08/08/24	22	7.918	0.298			Shutdown
*	08/09/24	2	12.175	0.469	0.63	4	Startup
	12/13/24	23	8.235	0.304			Shutdown
*	12/14/24	18	20.077	0.763			Startup
	12/14/24	19	26.413	0.959			
	12/14/24	20	8.089	0.309	0.58	4	Shutdown

* Consecutive unit operating hours with operating load at or above 25%

**New Source Performance Standard Subpart KKKK
Semi-Annual Report (40 CFR 60.4375)**

Pollutant: NO_x, parts per million by volume correct to 15% oxygen dry basis (ppmvdc)

Emission Limitation: 25 ppmvdc natural gas firing
74 ppmvdc firing fuels other than natural gas

Reporting period dates: From January 1, 2023 to June 30, 2023

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-2

Monitor Manufacturer and Model No.: Micro Motion model 170013ABZEZZZ; Micro Motion model R100S130NCAZEZZZX.

Date of Latest CMS Certification or Audit: N/A (there are no applicable “certification or audit” requirements for fuel flow meters and water meters).

Total source operating time in reporting period¹: 1041.5

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 5	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 0	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 0	c. Quality assurance calibration – 0 hours
d. Other known causes – 0	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 5	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 0.5%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%

¹For gases, record all times in hours.

Emission data summary**CMS performance summary**

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.

On a separate page, describe any changes since last quarter in CMS, process or controls.

NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature**Title**

Vice President- EEHS & Regulatory

Date

08/29/2025

Excess Emissions

40 CFR 60.7(c) requires that the magnitude of excess emissions be computed in accordance with § 60.13(h)(3), which is in terms of the standard. Per agreement with USEPA, a water injection to fuel ratio between 0.65 and 1.00 demonstrates compliance with the NO_x limits which are in units of parts per million by volume correct to 15% oxygen dry basis (ppmvdc). There are no conversion factors to convert water injection to fuel ratios to ppmvdc. Therefore, the noncompliant water injection to fuel ratios are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CLOCK HOUR AVERAGE	4-HOUR AVERAGE	HOURS EXCESS EMISSIONS	Cause
03/14/23	23	9.938	0.425			Shutdown
* 03/15/23	18	15.076	0.328			Startup
03/15/23	19	28.116	1.013			
03/15/23	20	16.985	0.420	0.55	4	Shutdown
* 03/19/23	18	13.671	0.500	0.57	1	Startup

* Consecutive unit operating hours with operating load at or above 25%

**New Source Performance Standard Subpart KKKK
Semi-Annual Report (40 CFR 60.4375)**

Pollutant: NO_x, parts per million by volume correct to 15% oxygen dry basis (ppmvdc)

Emission Limitation: 25 ppmvdc natural gas firing
74 ppmvdc firing fuels other than natural gas

Reporting period dates: From July 1, 2023 to December 31, 2023

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-2

Monitor Manufacturer and Model No.: Micro Motion model 170013ABZEZZZ; Micro Motion model R100S130NCAZEZZX.

Date of Latest CMS Certification or Audit: N/A (there are no applicable “certification or audit” requirements for fuel flow meters and water meters).

Total source operating time in reporting period¹: 1,368

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 17	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 23	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 0	c. Quality assurance calibration – 0 hours
d. Other known causes – 0	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 17	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 1.2%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%

¹For gases, record all times in hours.

Emission data summary**CMS performance summary**

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.


On a separate page, describe any changes since last quarter in CMS, process or controls.

NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature**Title**

Vice President- EEHS & Regulatory

Date

08/29/2025

Excess Emissions

40 CFR 60.7(c) requires that the magnitude of excess emissions be computed in accordance with § 60.13(h)(3), which is in terms of the standard. Per agreement with USEPA, a water injection to fuel ratio between 0.65 and 1.00 demonstrates compliance with the NO_x limits which are in units of parts per million by volume correct to 15% oxygen dry basis (ppmvdc). There are no conversion factors to convert water injection to fuel ratios to ppmvdc. Therefore, the noncompliant water injection to fuel ratios are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CLOCK HOUR AVERAGE	4-HOUR AVERAGE	HOURS EXCESS EMISSIONS	Cause
07/21/23	3	27.497	0.973			
07/21/23	4	17.324	0.675			Shutdown
* 07/21/23	14	11.843	0.504			Startup/Shutdown
* 07/21/23	16	8.543	0.374	0.63	4	Startup/Shutdown
* 07/21/23	21	11.467	0.440	0.50	1	Startup
07/21/23	22	27.224	0.975	0.57	1	
07/27/23	19	27.200	0.963			
07/27/23	20	26.059	0.923			
07/27/23	21	12.799	0.049			Malfunction
* 07/28/23	13	13.861	0.542	0.62	4	Startup
07/28/23	14	26.606	0.963	0.62	1	
08/01/23	8	27.272	0.944			
08/01/23	9	27.462	0.945			
08/01/23	10	14.217	0.281			Shutdown
* 08/01/23	14	7.105	0.294	0.62	4	Startup
08/01/23	15	25.870	0.909	0.61	1	
08/01/23	16	27.389	0.946	0.61	1	

* Consecutive unit operating hours with operating load at or above 25%

**New Source Performance Standard Subpart KKKK
Semi-Annual Report (40 CFR 60.4375)**

Pollutant: NO_x, parts per million by volume correct to 15% oxygen dry basis (ppmvdc)

Emission Limitation: 25 ppmvdc natural gas firing
74 ppmvdc firing fuels other than natural gas

Reporting period dates: From January 1, 2024 to June 30, 2024

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-2

Monitor Manufacturer and Model No.: Micro Motion model 170013ABZEZZZ; Micro Motion model R100S130NCAZEZZX

Date of Latest CMS Certification or Audit: N/A (there are no applicable “certification or audit” requirements for fuel flow meters and water meters)

Total source operating time in reporting period¹: 285

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 4	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 0	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 0	c. Quality assurance calibration – 0 hours
d. Other known causes – 0	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 4	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 1.4%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%

¹For gases, record all times in hours.

Emission data summary**CMS performance summary**

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.


On a separate page, describe any changes since last quarter in CMS, process or controls.

NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature**Title**

Vice President- EEHS & Regulatory

Date

08/29/2025

Excess Emissions

40 CFR 60.7(c) requires that the magnitude of excess emissions be computed in accordance with § 60.13(h)(3), which is in terms of the standard. Per agreement with USEPA, a water injection to fuel ratio between 0.65 and 1.00 demonstrates compliance with the NO_x limits which are in units of parts per million by volume correct to 15% oxygen dry basis (ppmvdc). There are no conversion factors to convert water injection to fuel ratios to ppmvdc. Therefore, the noncompliant water injection to fuel ratios are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CLOCK HOUR AVERAGE	4-HOUR AVERAGE	HOURS EXCESS EMISSIONS	CAUSE
06/19/24	22	14.824	0.572			Shutdown
* 06/25/24	23	16.094	0.604			Startup
06/26/24	0	24.994	0.928			
06/26/24	1	10.725	0.440	0.64	4	Shutdown

* Consecutive unit operating hours with operating load at or above 25%

**New Source Performance Standard Subpart KKKK
Semi-Annual Report (40 CFR 60.4375)**

Pollutant: NO_x, parts per million by volume correct to 15% oxygen dry basis (ppmvdc)

Emission Limitation: 25 ppmvdc natural gas firing
74 ppmvdc firing fuels other than natural gas

Reporting period dates: From July 1, 2024 to December 31, 2024

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-2

Monitor Manufacturer and Model No.: Micro Motion model 170013ABZEZZZ; Micro Motion model R100S130NCAZEZZZX

Date of Latest CMS Certification or Audit: N/A (there are no applicable “certification or audit” requirements for fuel flow meters and water meters).

Total source operating time in reporting period¹: 826

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 12	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 4	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 0	c. Quality assurance calibration – 0 hours
d. Other known causes – 0	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 16	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 1.9%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%

¹For gases, record all times in hours.

Emission data summary**CMS performance summary**

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.


On a separate page, describe any changes since last quarter in CMS, process or controls.

NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature**Title**

Vice President- EEHS & Regulatory

Date

08/29/2025

Excess Emissions

40 CFR 60.7(c) requires that the magnitude of excess emissions be computed in accordance with § 60.13(h)(3), which is in terms of the standard. Per agreement with USEPA, a water injection to fuel ratio between 0.65 and 1.00 demonstrates compliance with the NO_x limits which are in units of parts per million by volume correct to 15% oxygen dry basis (ppmvdc). There are no conversion factors to convert water injection to fuel ratios to ppmvdc. Therefore, the noncompliant water injection to fuel ratios are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CLOCK HOUR AVERAGE	4-HOUR AVERAGE	HOURS EXCESS EMISSIONS	Cause
07/18/23	22	24.999	0.923			
07/18/23	23	19.958	0.746			Shutdown
* 07/24/23	9	11.302	0.448			Malfunction
* 08/01/23	7	7.124	0.299	0.60	4	Startup
08/01/23	8	26.716	0.946	0.61	1	
08/01/23	9	27.834	0.959	0.66	0	
08/01/23	10	13.122	0.228	0.61	1	Shutdown

12/09/23	22	11.91	0.436			Shutdown
* 12/10/23	8	21.44	0.785			Startup
12/10/23	9	18.41	0.650			Shutdown
* 12/12/23	16	11.41	0.442	0.58	4	Startup
12/18/23	18	27.895	0.984			
12/18/23	19	27.695	0.976			
* 12/19/23	9	7.968	0.000			Malfunction
* 12/19/23	13	14.161	0.613	0.64	4	Startup
12/19/23	14	19.948	0.862	0.61	1	
12/19/23	15	20.619	0.863	0.58	1	

* Consecutive unit operating hours with operating load at or above 25%

**New Source Performance Standard Subpart KKKK
Semi-Annual Report (40 CFR 60.4375)**

Pollutant: NO_x, parts per million by volume correct to 15% oxygen dry basis (ppmvdc)

Emission Limitation: 25 ppmvdc natural gas firing
74 ppmvdc firing fuels other than natural gas

Reporting period dates: From January 1, 2023 to June 30, 2023

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-3

Monitor Manufacturer and Model No.: Micro Motion model 170013ABZEZZZ; Micro Motion model R100S130NCAZEZZZX

Date of Latest CMS Certification or Audit: N/A (there are no applicable “certification or audit” requirements for fuel flow meters and water meters).

Total source operating time in reporting period¹: 995.5

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 2	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 0	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 0	c. Quality assurance calibration – 0 hours
d. Other known causes – 0	d. Other known causes – 0 hours
e. Unknown causes – 4	e. Unknown causes – 0 hours
2. Total duration of excess emission – 6	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 0.6%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%
¹ For gases, record all times in hours.	

Emission data summary	CMS performance summary
------------------------------	--------------------------------

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.

On a separate page, describe any changes since last quarter in CMS, process or controls.

NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature



Title

Vice President- EEHS & Regulatory

Date

08/29/2025

Excess Emissions

40 CFR 60.7(c) requires that the magnitude of excess emissions be computed in accordance with § 60.13(h)(3), which is in terms of the standard. Per agreement with USEPA, a water injection to fuel ratio between 0.65 and 1.00 demonstrates compliance with the NO_x limits which are in units of parts per million by volume correct to 15% oxygen dry basis (ppmvdc). There are no conversion factors to convert water injection to fuel ratios to ppmvdc. Therefore, the noncompliant water injection to fuel ratios are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CLOCK HOUR AVERAGE	4-HOUR AVERAGE	HOURS EXCESS EMISSIONS	CAUSE
05/18/23	23	24.199	0.866			
* 05/19/23	8	21.967	0.609			Unknown
05/19/23	9	17.065	0.237			Unknown
* 05/19/23	18	18.822	0.414	0.53	4	Unknown
* 05/19/23	22	22.702	0.818	0.52	1	
* 05/23/23	8	13.722	0.531	0.50	1	Startup

* Consecutive unit operating hours with operating load at or above 25%

**New Source Performance Standard Subpart KKKK
Semi-Annual Report (40 CFR 60.4375)**

Pollutant: NO_x, parts per million by volume correct to 15% oxygen dry basis (ppmvdc)

Emission Limitation: 25 ppmvdc natural gas firing
74 ppmvdc firing fuels other than natural gas

Reporting period dates: From July 1, 2023 to December 31, 2023

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-3

Monitor Manufacturer and Model No.: Micro Motion model 170013ABZEZZZ; Micro Motion model R100S130NCAZEZZZX

Date of Latest CMS Certification or Audit: N/A (there are no applicable “certification or audit” requirements for fuel flow meters and water meters).

Total source operating time in reporting period¹: 1,500

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 17	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 23	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 0	c. Quality assurance calibration – 0 hours
d. Other known causes – 0	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 17	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 0.9%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%
¹ For gases, record all times in hours.	

Emission data summary**CMS performance summary**

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.


On a separate page, describe any changes since last quarter in CMS, process or controls.

NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature**Title**

Vice President- EEHS & Regulatory

Date

08/29/2025

Excess Emissions

40 CFR 60.7(c) requires that the magnitude of excess emissions be computed in accordance with § 60.13(h)(3), which is in terms of the standard. Per agreement with USEPA, a water injection to fuel ratio between 0.65 and 1.00 demonstrates compliance with the NO_x limits which are in units of parts per million by volume correct to 15% oxygen dry basis (ppmvdc). There are no conversion factors to convert water injection to fuel ratios to ppmvdc. Therefore, the noncompliant water injection to fuel ratios are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CLOCK HOUR AVERAGE	4-HOUR AVERAGE	HOURS EXCESS EMISSIONS	Cause	
	08/20/23	4	13.575	0.521		Shutdown	
*	08/21/23	11	12.189	0.465		Startup	
	08/21/23	12	19.129	0.690		Shutdown	
*	08/21/23	16	20.034	0.735	0.60	4	Startup
	09/13/23	13	26.784	0.977			
	09/13/23	14	26.853	0.497		Malfunction	
*	09/13/23	17	9.004	0.370		Startup	
	09/13/23	18	18.389	0.663	0.63	4	Shutdown
*	09/13/23	20	18.102	0.666	0.55	1	Startup
	10/02/23	23	14.083	0.524			
*	11/12/23	21	16.890	0.621			
	11/12/23	22	26.817	0.943		Shutdown	
*	11/13/23	18	9.498	0.386	0.62	4	Startup

* Consecutive unit operating hours with operating load at or above 25%

**New Source Performance Standard Subpart KKKK
Semi-Annual Report (40 CFR 60.4375)**

Pollutant: NO_x, parts per million by volume correct to 15% oxygen dry basis (ppmvdc)

Emission Limitation: 25 ppmvdc natural gas firing
74 ppmvdc firing fuels other than natural gas

Reporting period dates: From January 1, 2024 to June 30, 2024

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-3

Monitor Manufacturer and Model No.: Micro Motion model 170013ABZEZZZ; Micro Motion model R100S130NCAZEZZX.

Date of Latest CMS Certification or Audit: N/A (there are no applicable “certification or audit” requirements for fuel flow meters and water meters).

Total source operating time in reporting period¹: 278

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 24	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 0	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 0	c. Quality assurance calibration – 0 hours
d. Other known causes – 0	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 24	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 8.6%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%

¹For gases, record all times in hours.

Emission data summary**CMS performance summary**

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.

On a separate page, describe any changes since last quarter in CMS, process or controls.

NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature**Title**

Vice President- EEHS & Regulatory

Date

08/29/2025

Excess Emissions

40 CFR 60.7(c) requires that the magnitude of excess emissions be computed in accordance with § 60.13(h)(3), which is in terms of the standard. Per agreement with USEPA, a water injection to fuel ratio between 0.65 and 1.00 demonstrates compliance with the NO_x limits which are in units of parts per million by volume correct to 15% oxygen dry basis (ppmvdc). There are no conversion factors to convert water injection to fuel ratios to ppmvdc. Therefore, the noncompliant water injection to fuel ratios are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CLOCK HOUR AVERAGE	4-HOUR AVERAGE	HOURS EXCESS EMISSIONS	CAUSE
	03/31/24	22	19.601	0.719		Shutdown
*	04/01/24	18	18.854	0.691		Startup
	04/01/24	19	11.468	0.443		Shutdown
*	04/02/24	20	9.976	0.714	0.64	4
*	04/03/24	15	15.630	0.625	0.62	1
*	04/05/24	14	12.572	0.491	0.57	1
	04/25/24	21	24.950	0.931		
	04/25/24	22	7.585	0.326		Shutdown
*	04/29/23	23	16.803	0.647		Startup
	04/30/24	0	15.269	0.614	0.63	4
*	04/30/24	17	19.137	0.744	0.58	1
	05/31/24	22	24.998	0.927		
	05/31/24	23	11.290	0.447		Shutdown
*	06/01/24	19	7.088	0.275		Startup
	06/01/24	20	23.916	0.903	0.64	4
	06/01/24	21	25.002	0.932	0.64	1
	06/01/24	22	11.751	0.468	0.64	1
	06/13/24	12	24.996	0.936		
	06/13/24	13	24.997	0.933		
*	06/13/24	14	23.561	0.372		Malfunction
	06/13/24	15	7.546	0.034	0.57	4
*	06/13/24	19	7.419	0.267	0.40	1
*	06/14/24	20	21.005	0.815	0.48	1
*	06/18/24	18	20.536	0.748	0.45	1

* Consecutive unit operating hours with operating load at or above 25%

**New Source Performance Standard Subpart KKKK
Semi-Annual Report (40 CFR 60.4375)**

Pollutant: NO_x, parts per million by volume correct to 15% oxygen dry basis (ppmvdc)

Emission Limitation: 25 ppmvdc natural gas firing
74 ppmvdc firing fuels other than natural gas

Reporting period dates: From July 1, 2024 to December 31, 2024

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-3

Monitor Manufacturer and Model No.: Micro Motion model 170013ABZEZZZ; Micro Motion model R100S130NCAZEZZX.

Date of Latest CMS Certification or Audit: N/A (there are no applicable “certification or audit” requirements for fuel flow meters and water meters).

Total source operating time in reporting period¹: 774

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 18	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 0	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 0	c. Quality assurance calibration – 0 hours
d. Other known causes – 0	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 18	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 2.3%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%

¹For gases, record all times in hours.

Emission data summary**CMS performance summary**

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.

On a separate page, describe any changes since last quarter in CMS, process or controls.

NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature**Title**

Vice President- EEHS & Regulatory

Date

08/29/2025

Excess Emissions

40 CFR 60.7(c) requires that the magnitude of excess emissions be computed in accordance with § 60.13(h)(3), which is in terms of the standard. Per agreement with USEPA, a water injection to fuel ratio between 0.65 and 1.00 demonstrates compliance with the NO_x limits which are in units of parts per million by volume correct to 15% oxygen dry basis (ppmvdc). There are no conversion factors to convert water injection to fuel ratios to ppmvdc. Therefore, the noncompliant water injection to fuel ratios are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CLOCK HOUR AVERAGE	4-HOUR AVERAGE	HOURS EXCESS EMISSIONS	Cause
07/12/23	22	24.997	0.926			
07/12/23	23	14.403	0.602			Shutdown
* 07/17/23	20	15.634	0.618			Startup
07/17/23	21	8.116	0.299	0.61	4	Shutdown
* 07/18/23	19	18.885	0.695	0.55	1	Startup
07/18/23	20	24.867	0.935	0.64	1	
07/18/23	21	17.413	0.652	0.65	0	Shutdown
* 07/20/23	13	11.996	0.514	0.70	0	Startup
07/20/23	14	14.705	0.600	0.68	0	Shutdown
* 07/23/23	15	14.422	0.653	0.60	1	Startup
* 08/01/23	7	19.226	0.734	0.63	1	Startup

08/08/23	19	7.26	0.302			Startup
08/08/23	20	24.10	0.907			
08/08/23	21	21.46	0.739			Shutdown
* 08/09/23	2	10.80	0.457	0.60	4	Startup
08/28/23	23	20.001	0.859			
08/29/23	0	20.000	0.860			
08/29/23	1	7.901	0.355			Shutdown
* 08/29/23	17	8.457	0.360	0.61	4	Startup
08/29/23	18	19.525	0.843	0.60	1	
08/29/23	19	19.998	0.862	0.61	1	

* Consecutive unit operating hours with operating load at or above 25%