

**National Emission Standard for Hazardous Air Pollutants Subpart YYYY
Semi-Annual Report (40 CFR 63.6150)**

Pollutant: Formaldehyde, parts per billion by volume correct to 15% oxygen dry basis (ppbvdc)

Emission Limitation: 91 ppbvdc natural gas and oil firing

Reporting period dates: From January 1, 2023 to June 30, 2023

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-1

Monitor Manufacturer and Model No.: Satec PM130EH Plus

Date of Latest CMS Certification or Audit: N/A

Total source operating time in reporting period¹: 1041.5

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 221	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 0	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 7	c. Quality assurance calibration – 0 hours
d. Other known causes – 0	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 228	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 21.9%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%

¹ For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.


On a separate page, describe any changes since last quarter in CMS, process or controls.
NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature



Title

Vice President- EEHS & Regulatory

Date

9/5/2025

Excess Emissions

Per agreement with USEPA, an operating load less than 90% is a period of noncompliance. The unit is rated at 27.6 megawatts (MW) and 90% operating load is 24.8 MW. There are no conversion factors from operating load to ppbvdc. Therefore, hours with operating load below 24.8 MW are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT (MW)	CAUSE
1/12/2023	11 AM	18.21	Startup
1/12/2023	9 PM	22.87	Shutdown
1/13/2023	5 PM	16.81	Startup
1/13/2023	9 PM	15.71	Shutdown
1/14/2023	4 PM	20.02	Startup
1/14/2023	11 PM	22.42	Shutdown
1/15/2023	4 PM	18.50	Startup
1/15/2023	8 PM	15.48	Shutdown
1/17/2023	8 PM	16.46	Shutdown
1/18/2023	9 PM	12.79	Shutdown
1/19/2023	5 PM	13.10	Startup
1/19/2023	9 PM	20.40	Shutdown
1/20/2023	5 PM	22.95	Startup
1/20/2023	9 PM	11.66	Shutdown
1/22/2023	5 PM	7.33	Startup
1/22/2023	6 PM	23.71	Malfunction
1/22/2023	9 PM	24.79	Shutdown
1/23/2023	5 PM	17.52	Startup
1/23/2023	10 PM	24.59	Shutdown
1/24/2023	4 PM	15.92	Startup
1/24/2023	8 PM	17.46	Shutdown
1/26/2023	5 PM	24.05	Startup
1/26/2023	9 PM	21.40	Shutdown
2/3/2023	4 PM	15.18	Startup
2/3/2023	11 PM	22.93	Shutdown
2/4/2023	5 PM	7.86	Startup
2/4/2023	10 PM	11.57	Shutdown
2/6/2023	5 PM	16.62	Startup
2/7/2023	10 PM	17.91	Shutdown
2/8/2023	3 PM	23.52	Startup
2/8/2023	9 PM	22.18	Shutdown
2/9/2023	2 PM	12.74	Startup
2/9/2023	10 PM	23.10	Shutdown
2/10/2023	10 PM	21.80	Shutdown
2/11/2023	7 PM	24.01	Startup
2/14/2023	12 AM	22.60	Startup
2/14/2023	9 PM	22.34	Shutdown
2/15/2023	6 PM	17.63	Startup
2/16/2023	11 PM	22.03	Shutdown

DATE	CLOCK HOUR	GENERATOR OUTPUT (MW)	CAUSE
2/17/2023	3 PM	19.14	Startup
2/17/2023	10 PM	14.86	Shutdown
2/20/2023	6 PM	21.79	Startup
2/20/2023	11 PM	14.77	Shutdown
2/21/2023	5 PM	13.64	Startup
2/21/2023	9 PM	12.52	Shutdown
2/22/2023	6 PM	22.71	Startup
2/22/2023	11 PM	13.44	Shutdown
2/23/2023	3 PM	7.39	Startup
2/23/2023	10 PM	20.42	Shutdown
2/24/2023	3 PM	16.98	Startup
2/24/2023	9 PM	16.39	Shutdown
2/25/2023	6 PM	18.55	Startup
2/25/2023	9 PM	21.00	Shutdown
2/27/2023	4 PM	18.60	Startup
2/27/2023	10 PM	19.49	Shutdown
2/28/2023	3 PM	12.97	Startup
2/28/2023	9 PM	23.86	Shutdown
3/1/2023	4 PM	13.09	Startup
3/1/2023	11 PM	24.19	Shutdown
3/2/2023	10 AM	24.45	Startup
3/2/2023	11 PM	24.47	Shutdown
3/3/2023	7 AM	14.21	Startup
3/4/2023	3 PM	17.29	Startup
3/4/2023	10 PM	22.14	Shutdown
3/5/2023	5 PM	14.11	Startup
3/5/2023	10 PM	12.06	Shutdown
3/6/2023	4 PM	16.38	Startup
3/6/2023	10 PM	18.49	Shutdown
3/7/2023	4 PM	11.28	Startup
3/7/2023	10 PM	7.14	Shutdown
3/8/2023	6 PM	13.66	Startup
3/8/2023	10 PM	24.70	Shutdown
3/11/2023	4 PM	14.65	Startup
3/11/2023	8 PM	21.29	Shutdown
3/13/2023	10 PM	24.38	Shutdown
3/14/2023	1 PM	12.18	Startup
3/15/2023	6 PM	10.63	Startup
3/15/2023	8 PM	8.62	Shutdown
3/19/2025	6 PM	12.82	Startup
3/19/2025	10 PM	22.91	Shutdown
3/20/2025	5 PM	19.82	Startup
3/20/2025	10 PM	24.03	Shutdown
3/21/2025	6 PM	20.25	Startup
3/21/2023	10 PM	23.17	Shutdown

DATE	CLOCK HOUR	GENERATOR OUTPUT (MW)	CAUSE
3/22/2023	4 PM	16.61	Startup
3/22/2023	10 PM	23.09	Shutdown
3/23/2023	9 PM	21.87	Shutdown
3/25/2023	6 PM	17.88	Startup
3/26/2023	5 PM	18.78	Startup
3/28/2023	4 PM	17.47	Startup
3/28/2023	10 PM	15.76	Shutdown
3/29/2023	6 PM	11.60	Startup
3/29/2023	9 PM	19.59	Shutdown
3/30/2023	6 PM	21.37	Startup
4/1/2023	12 AM	15.16	Shutdown
4/2/2023	6 PM	9.70	Startup
4/2/2023	11 PM	20.93	Shutdown
4/3/2023	5 PM	17.86	Startup
4/3/2023	10 PM	20.13	Shutdown
4/4/2023	4 PM	18.98	Startup
4/4/2023	10 PM	16.64	Shutdown
4/10/2023	3 PM	21.80	Startup
4/11/2023	12 AM	18.71	Shutdown
4/11/2023	2 PM	18.28	Startup
4/11/2023	10 PM	23.45	Shutdown
4/12/2023	6 PM	24.21	Startup
4/12/2023	10 PM	21.72	Shutdown
4/13/2023	3 PM	9.84	Startup
4/13/2023	10 PM	20.65	Shutdown
4/14/2023	5 PM	24.64	Startup
4/14/2023	9 PM	11.03	Shutdown
4/15/2023	5 PM	21.37	Startup
4/15/2023	9 PM	18.65	Shutdown
4/18/2023	3 PM	11.72	Shutdown
4/19/2023	5 PM	12.83	Startup
4/19/2023	10 PM	9.25	Shutdown
4/20/2023	6 PM	12.41	Startup
4/20/2023	9 PM	8.01	Shutdown
4/24/2023	4 PM	11.29	Startup
4/24/2023	10 PM	8.83	Shutdown
4/25/2023	5 PM	16.87	Startup
4/25/2023	10 PM	21.73	Shutdown
4/26/2023	3 PM	18.44	Startup
4/27/2023	10 PM	20.33	Shutdown
4/28/2023	3 PM	17.86	Startup
4/28/2023	8 PM	13.16	Shutdown
4/29/2023	4 PM	11.60	Startup
4/29/2023	10 PM	16.31	Shutdown
4/30/2023	5 PM	20.08	Startup

DATE	CLOCK HOUR	GENERATOR OUTPUT (MW)	CAUSE
4/30/2023	11 PM	14.91	Shutdown
5/1/2023	4 PM	20.95	Startup
5/1/2023	11 PM	18.03	Shutdown
5/2/2023	12 PM	23.51	Startup
5/2/2023	11 PM	18.00	Shutdown
5/3/2023	2 PM	13.14	Startup
5/3/2023	10 PM	20.83	Shutdown
5/4/2023	8 AM	19.98	Startup
5/5/2023	12 AM	14.70	Shutdown
5/5/2023	9 AM	21.11	Startup
5/5/2023	11 PM	7.34	Shutdown
5/7/2023	12 AM	11.97	Shutdown
5/7/2023	4 PM	20.46	Startup
5/7/2023	11 PM	11.66	Shutdown
5/8/2023	10 AM	21.09	Startup
5/8/2023	10 PM	20.41	Shutdown
5/9/2023	2 PM	23.30	Startup
5/10/2023	12 AM	8.34	Shutdown
5/10/2023	3 PM	19.89	Startup
5/10/2023	11 PM	20.90	Shutdown
5/11/2023	3 PM	19.29	Startup
5/12/2023	3 PM	17.55	Startup
5/13/2023	4 PM	20.68	Startup
5/14/2023	5 PM	13.01	Startup
5/15/2023	12 AM	19.49	Startup
5/15/2023	2 PM	10.54	Shutdown
5/16/2023	12 AM	20.00	Startup
5/16/2023	2 PM	16.94	Shutdown
5/17/2023	1 AM	15.96	Startup
5/17/2023	2 PM	21.86	Shutdown
5/18/2023	11 AM	7.60	Startup
5/18/2023	11 PM	17.88	Shutdown
5/19/2023	8 AM	21.54	Startup
5/19/2023	10 AM	9.43	Shutdown
5/19/2023	5 PM	13.88	Startup
5/19/2023	10 PM	24.03	Shutdown
5/22/2025	10 PM	7.11	Shutdown
5/23/2025	8 AM	19.42	Startup
5/23/2025	10 AM	8.30	Shutdown
5/23/2025	1 PM	20.27	Startup
5/23/2025	9 PM	15.02	Shutdown
5/24/2025	9 AM	20.67	Startup
5/24/2025	9 PM	15.96	Shutdown
5/25/2025	8 AM	18.54	Startup
5/25/2025	9 PM	24.04	Shutdown

DATE	CLOCK HOUR	GENERATOR OUTPUT (MW)	CAUSE
5/26/2025	7 AM	17.25	Startup
5/27/2025	5 PM	21.03	Startup
5/27/2025	10 PM	19.46	Shutdown
5/28/2025	7 PM	23.09	Startup
5/28/2025	11 PM	22.88	Shutdown
5/29/2025	4 PM	18.92	Startup
5/29/2025	10 PM	17.66	Shutdown
5/30/2025	8 AM	13.73	Startup
5/30/2025	10 PM	18.81	Shutdown
5/31/2025	8 AM	18.80	Startup
5/31/2025	10 PM	10.30	Shutdown
6/1/2025	8 AM	18.44	Startup
6/1/2025	11 PM	24.42	Shutdown
6/2/2025	8 AM	15.74	Startup
6/2/2025	11 PM	22.81	Shutdown
6/3/2025	3 PM	12.52	Startup
6/4/2025	1 AM	19.15	Shutdown
6/4/2025	2 PM	9.19	Startup
6/5/2025	11 PM	18.37	Shutdown
6/6/2025	2 PM	17.09	Startup
6/7/2025	1 AM	22.23	Shutdown
6/7/2025	8 AM	15.41	Startup
6/7/2025	10 PM	9.92	Malfunction
6/7/2025	11 PM	22.98	Malfunction
6/8/2025	12 PM	23.25	Malfunction
6/8/2025	4 PM	24.00	Malfunction
6/9/2023	12 AM	20.28	Shutdown
6/9/2023	4 PM	15.28	Startup
6/10/2023	10 PM	19.23	Shutdown
6/11/2023	4 PM	9.66	Startup
6/12/2023	12 AM	24.26	Shutdown
6/12/2023	4 PM	20.22	Startup
6/13/2023	4 PM	14.22	Startup
6/14/2025	12 AM	7.33	Shutdown
6/14/2025	3 PM	6.92	Startup
6/14/2025	11 PM	21.49	Shutdown
6/15/2025	3 PM	14.97	Startup
6/15/2025	5 PM	23.63	Malfunction
6/15/2025	6 PM	24.47	Malfunction
6/17/2025	1 AM	10.36	Shutdown
6/20/2025	4 PM	8.80	Shutdown
6/21/2025	3 PM	14.18	Startup
6/22/2025	8 AM	16.68	Startup
6/23/2025	12 AM	9.82	Shutdown
6/23/2025	12 PM	16.79	Startup

DATE	CLOCK HOUR	GENERATOR OUTPUT (MW)	CAUSE
6/25/2023	11 PM	15.67	Shutdown
6/26/2023	3 PM	23.21	Startup
6/27/2023	12 AM	14.73	Shutdown
6/27/2023	1 PM	17.10	Startup
6/27/2023	11 PM	18.52	Shutdown
6/29/2023	7 PM	22.98	Startup
6/30/2023	12 AM	9.87	Shutdown
6/30/2023	7 AM	10.81	Startup
6/30/2023	11 PM	13.69	Shutdown

**National Emission Standard for Hazardous Air Pollutants Subpart YYYY
Semi-Annual Report (40 CFR 63.6150)**

Pollutant: Formaldehyde, parts per billion by volume correct to 15% oxygen dry basis (ppbvdC)

Emission Limitation: 91 ppbvdC natural gas and oil firing

Reporting period dates: From July 1, 2023 to December 31, 2023

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-1

Monitor Manufacturer and Model No.: Satec PM130EH Plus

Date of Latest CMS Certification or Audit: N/A

Total source operating time in reporting period¹: 1549

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 93	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 0	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 1	c. Quality assurance calibration – 0 hours
d. Other known causes – 491	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 585	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 37.8%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%

¹ For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.


On a separate page, describe any changes since last quarter in CMS, process or controls.
NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature



Title

Vice President- EEHS & Regulatory

Date

9/5/2025

Excess Emissions

Per agreement with USEPA, an operating load less than 90% is a period of noncompliance. The unit is rated at 27.6 megawatts (MW) and 90% operating load is 24.8 MW. There are no conversion factors from operating load to ppbvdc. Therefore, hours with operating load below 24.8 MW are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
07/02/23	5 PM	14.86	Startup
07/03/23	12 AM	14.98	Shutdown
07/04/23	5 PM	19.97	Startup
07/05/23	1 AM	17.13	Shutdown
07/05/23	11 PM	19.40	Shutdown
07/06/23	3 PM	15.34	Startup
07/07/23	12 AM	10.49	Shutdown
07/07/23	11 PM	24.74	Shutdown
07/09/23	5 PM	15.92	Startup
07/09/23	11 PM	10.00	Shutdown
07/10/23	8 AM	9.13	Startup
07/12/23	11 PM	21.17	Shutdown
07/13/23	8 AM	8.31	Startup
07/14/23	2 AM	8.11	Shutdown
07/14/23	8 AM	14.82	Startup
07/16/23	2 AM	22.93	Shutdown
07/21/23	4 AM	21.40	Shutdown
07/21/23	8 AM	8.04	Startup
07/21/23	2 PM	18.87	Startup
07/22/23	12 AM	23.10	Shutdown
07/23/23	2 AM	17.29	Reduced Load 62.7%
07/23/23	3 AM	17.77	Reduced Load 64.4%
07/24/23	3 PM	21.85	Startup
07/25/23	1 AM	23.16	Shutdown
07/25/23	11 PM	14.77	Shutdown
07/26/23	8 AM	8.23	Startup
07/26/23	11 PM	11.66	Shutdown
07/28/23	12 AM	14.98	Shutdown
07/28/23	2 PM	13.31	Startup
07/29/23	6 PM	7.62	Startup
07/30/23	12 AM	21.19	Shutdown
08/01/23	2 PM	11.28	Startup
08/01/23	10 PM	21.15	Shutdown
08/03/23	6 PM	13.17	Startup
08/03/23	10 PM	20.01	Shutdown
08/04/23	9 PM	20.61	Shutdown
08/05/23	9 AM	20.21	Startup

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
08/06/23	12 PM	24.66	Startup
08/10/23	10 PM	24.41	Reduced Load 88.4%
08/10/23	11 PM	14.41	Reduced Load 52.2%
08/12/23	1 AM	20.82	Shutdown
08/13/23	6 PM	20.83	Startup
08/14/23	1 AM	23.14	Shutdown
08/14/23	5 PM	15.55	Startup
08/18/23	11 AM	21.48	Shutdown
08/18/23	2 PM	17.72	Startup
08/19/23	1 AM	9.86	Shutdown
08/19/23	5 PM	17.56	Startup
08/20/25	5 AM	21.88	Shutdown
08/21/25	11 AM	15.91	Startup
08/21/25	12 PM	19.25	Malfunction
08/21/25	3 PM	11.74	Startup
08/21/25	9 PM	18.30	Shutdown
08/22/25	9 AM	15.63	Startup
08/23/25	1 PM	22.66	Startup
08/24/25	1 AM	18.12	Shutdown
08/27/23	4 PM	24.71	Startup
08/28/23	1 PM	20.27	Reduced Load 73.4%
08/28/23	3 PM	22.74	Reduced Load 82.4%
08/28/23	4 PM	19.98	Reduced Load 72.4%
08/28/23	5 PM	20.15	Reduced Load 73.0%
08/28/23	6 PM	20.61	Reduced Load 74.7%
08/28/23	7 PM	21.16	Reduced Load 76.7%
08/28/23	8 PM	19.98	Reduced Load 72.4%
08/28/23	9 PM	19.97	Reduced Load 72.4%
08/28/23	10 PM	19.93	Reduced Load 72.2%
08/28/23	11 PM	19.97	Reduced Load 72.4%
08/29/23	12 AM	19.98	Reduced Load 72.4%
08/29/23	1 AM	19.98	Reduced Load 72.4%
08/29/23	2 AM	20.00	Reduced Load 72.5%
08/29/23	3 AM	19.99	Reduced Load 72.4%
08/29/23	4 AM	19.99	Reduced Load 72.4%
08/29/23	5 AM	19.87	Reduced Load 72.0%
08/29/23	6 AM	19.86	Reduced Load 71.9%
08/29/23	7 AM	19.88	Reduced Load 72.0%
08/29/23	8 AM	19.92	Reduced Load 72.2%
08/29/23	9 AM	19.96	Reduced Load 72.3%
08/29/23	10 AM	21.17	Reduced Load 76.7%
08/29/23	11 AM	21.95	Reduced Load 79.5%
08/29/23	12 PM	21.95	Reduced Load 79.5%
08/29/23	1 PM	21.97	Reduced Load 79.6%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
08/29/23	2 PM	21.97	Reduced Load 79.6%
08/29/23	3 PM	22.49	Reduced Load 81.5%
08/29/23	4 PM	23.84	Reduced Load 86.4%
08/29/23	5 PM	23.98	Reduced Load 86.9%
08/29/23	6 PM	23.96	Reduced Load 86.8%
08/29/23	7 PM	23.96	Reduced Load 86.8%
08/29/23	8 PM	24.00	Reduced Load 87.0%
08/29/23	9 PM	24.00	Reduced Load 87.0%
08/29/23	10 PM	23.98	Reduced Load 86.9%
08/29/23	11 PM	23.94	Reduced Load 86.7%
08/30/23	12 AM	23.98	Reduced Load 86.9%
08/30/23	1 AM	23.97	Reduced Load 86.9%
08/30/23	2 AM	23.99	Reduced Load 86.9%
08/30/23	3 AM	23.99	Reduced Load 86.9%
08/30/23	4 AM	24.01	Reduced Load 87.0%
08/30/23	5 AM	23.95	Reduced Load 86.8%
08/30/23	6 AM	23.93	Reduced Load 86.7%
08/30/23	7 AM	23.95	Reduced Load 86.8%
08/30/23	8 AM	23.94	Reduced Load 86.7%
08/30/23	9 AM	23.96	Reduced Load 86.8%
08/30/23	10 AM	23.97	Reduced Load 86.8%
08/30/23	11 AM	23.98	Reduced Load 86.9%
08/30/23	12 PM	23.96	Reduced Load 86.8%
08/30/23	1 PM	23.98	Reduced Load 86.9%
08/30/23	2 PM	23.98	Reduced Load 86.9%
08/30/23	3 PM	23.97	Reduced Load 86.9%
08/30/23	4 PM	23.97	Reduced Load 86.8%
08/30/23	5 PM	23.95	Reduced Load 86.8%
08/30/23	6 PM	23.89	Reduced Load 86.6%
08/30/23	7 PM	23.97	Reduced Load 86.9%
08/30/23	8 PM	23.98	Reduced Load 86.9%
08/30/23	9 PM	24.00	Reduced Load 86.9%
08/30/23	10 PM	23.99	Reduced Load 86.9%
08/30/23	11 PM	23.96	Reduced Load 86.8%
08/31/23	12 AM	23.99	Reduced Load 86.9%
08/31/23	1 AM	23.95	Reduced Load 86.8%
08/31/23	2 AM	23.92	Reduced Load 86.7%
08/31/23	3 AM	23.83	Reduced Load 86.3%
08/31/23	4 AM	23.83	Reduced Load 86.3%
08/31/23	5 AM	23.96	Reduced Load 86.8%
08/31/23	6 AM	23.96	Reduced Load 86.8%
08/31/23	7 AM	23.96	Reduced Load 86.8%
08/31/23	8 AM	23.97	Reduced Load 86.8%
08/31/23	9 AM	23.98	Reduced Load 86.9%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
08/31/23	10 AM	23.98	Reduced Load 86.9%
08/31/23	11 AM	23.98	Reduced Load 86.9%
08/31/23	12 PM	23.97	Reduced Load 86.8%
08/31/23	1 PM	23.97	Reduced Load 86.8%
08/31/23	2 PM	23.96	Reduced Load 86.8%
08/31/23	3 PM	23.97	Reduced Load 86.9%
08/31/23	4 PM	23.98	Reduced Load 86.9%
08/31/23	5 PM	23.99	Reduced Load 86.9%
08/31/23	6 PM	23.99	Reduced Load 86.9%
08/31/23	7 PM	24.00	Reduced Load 86.9%
08/31/23	8 PM	23.99	Reduced Load 86.9%
08/31/23	9 PM	23.99	Reduced Load 86.9%
08/31/23	10 PM	24.00	Reduced Load 86.9%
08/31/23	11 PM	23.99	Reduced Load 86.9%
09/01/23	12 AM	23.98	Reduced Load 86.9%
09/01/23	1 AM	23.95	Reduced Load 86.8%
09/01/23	2 AM	23.95	Reduced Load 86.8%
09/01/23	3 AM	23.98	Reduced Load 86.9%
09/01/23	4 AM	23.97	Reduced Load 86.9%
09/01/23	5 AM	23.98	Reduced Load 86.9%
09/01/23	6 AM	23.95	Reduced Load 86.8%
09/01/23	7 AM	23.96	Reduced Load 86.8%
09/01/23	8 AM	23.98	Reduced Load 86.9%
09/01/23	9 AM	23.97	Reduced Load 86.8%
09/01/23	10 AM	23.97	Reduced Load 86.8%
09/01/23	11 AM	23.97	Reduced Load 86.8%
09/01/23	12 PM	23.97	Reduced Load 86.9%
09/01/23	1 PM	23.97	Reduced Load 86.8%
09/01/23	2 PM	23.98	Reduced Load 86.9%
09/01/23	3 PM	23.97	Reduced Load 86.9%
09/01/23	4 PM	23.97	Reduced Load 86.9%
09/01/23	5 PM	23.96	Reduced Load 86.8%
09/01/23	6 PM	23.67	Reduced Load 85.8%
09/01/23	7 PM	23.63	Reduced Load 85.6%
09/01/23	8 PM	23.98	Reduced Load 86.9%
09/01/23	9 PM	23.97	Reduced Load 86.8%
09/01/23	10 PM	23.92	Reduced Load 86.7%
09/01/23	11 PM	23.89	Reduced Load 86.6%
09/02/23	12 AM	23.93	Reduced Load 86.7%
09/02/23	1 AM	23.93	Reduced Load 86.7%
09/02/23	2 AM	23.93	Reduced Load 86.7%
09/02/23	3 AM	23.97	Reduced Load 86.9%
09/02/23	4 AM	23.95	Reduced Load 86.8%
09/02/23	5 AM	23.96	Reduced Load 86.8%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
09/02/23	6 AM	18.92	Shutdown
09/02/23	2 PM	14.90	Startup
09/02/23	3 PM	23.97	Reduced Load 86.9%
09/02/23	4 PM	23.99	Reduced Load 86.9%
09/02/23	5 PM	23.99	Reduced Load 86.9%
09/02/23	6 PM	23.98	Reduced Load 86.9%
09/02/23	7 PM	23.99	Reduced Load 86.9%
09/02/23	8 PM	23.99	Reduced Load 86.9%
09/02/23	9 PM	23.99	Reduced Load 86.9%
09/02/23	10 PM	23.99	Reduced Load 86.9%
09/02/23	11 PM	23.98	Reduced Load 86.9%
09/03/23	12 AM	23.96	Reduced Load 86.8%
09/03/23	1 AM	23.97	Reduced Load 86.9%
09/03/23	2 AM	23.95	Reduced Load 86.8%
09/03/23	3 AM	23.97	Reduced Load 86.8%
09/03/23	4 AM	23.99	Reduced Load 86.9%
09/03/23	5 AM	23.96	Reduced Load 86.8%
09/03/23	6 AM	23.93	Reduced Load 86.7%
09/03/23	7 AM	10.58	Shutdown
09/03/23	2 PM	17.24	Startup
09/03/23	3 PM	23.97	Reduced Load 86.8%
09/03/23	4 PM	24.00	Reduced Load 87.0%
09/03/23	5 PM	23.99	Reduced Load 86.9%
09/03/23	6 PM	23.98	Reduced Load 86.9%
09/03/23	7 PM	23.99	Reduced Load 86.9%
09/03/23	8 PM	23.98	Reduced Load 86.9%
09/03/23	9 PM	23.98	Reduced Load 86.9%
09/03/23	10 PM	23.97	Reduced Load 86.9%
09/03/23	11 PM	23.94	Reduced Load 86.8%
09/04/23	12 AM	23.95	Reduced Load 86.8%
09/04/23	1 AM	23.93	Reduced Load 86.7%
09/04/23	2 AM	23.90	Reduced Load 86.6%
09/04/23	3 AM	23.88	Reduced Load 86.5%
09/04/23	4 AM	23.94	Reduced Load 86.7%
09/04/23	5 AM	23.93	Reduced Load 86.7%
09/04/23	6 AM	23.95	Reduced Load 86.8%
09/04/23	7 AM	23.97	Reduced Load 86.8%
09/04/23	8 AM	23.97	Reduced Load 86.8%
09/04/23	9 AM	23.96	Reduced Load 86.8%
09/04/23	10 AM	23.96	Reduced Load 86.8%
09/04/23	11 AM	23.86	Reduced Load 86.5%
09/04/23	12 PM	23.96	Reduced Load 86.8%
09/04/23	1 PM	23.97	Reduced Load 86.9%
09/04/23	2 PM	23.99	Reduced Load 86.9%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
09/04/23	3 PM	23.98	Reduced Load 86.9%
09/04/23	4 PM	23.99	Reduced Load 86.9%
09/04/23	5 PM	23.99	Reduced Load 86.9%
09/04/23	6 PM	23.97	Reduced Load 86.8%
09/04/23	7 PM	23.99	Reduced Load 86.9%
09/04/23	8 PM	23.99	Reduced Load 86.9%
09/04/23	9 PM	23.95	Reduced Load 86.8%
09/04/23	10 PM	23.99	Reduced Load 86.9%
09/04/23	11 PM	23.98	Reduced Load 86.9%
09/05/23	12 AM	23.95	Reduced Load 86.8%
09/05/23	1 AM	23.97	Reduced Load 86.8%
09/05/23	2 AM	23.97	Reduced Load 86.8%
09/05/23	3 AM	23.98	Reduced Load 86.9%
09/05/23	4 AM	23.99	Reduced Load 86.9%
09/05/23	5 AM	23.99	Reduced Load 86.9%
09/05/23	6 AM	23.97	Reduced Load 86.8%
09/05/23	7 AM	23.97	Reduced Load 86.8%
09/05/23	8 AM	23.98	Reduced Load 86.9%
09/05/23	9 AM	23.99	Reduced Load 86.9%
09/05/23	10 AM	22.28	Shutdown
09/05/23	2 PM	17.81	Startup
09/05/23	3 PM	23.99	Reduced Load 86.9%
09/05/23	4 PM	23.99	Reduced Load 86.9%
09/05/23	5 PM	23.99	Reduced Load 86.9%
09/05/23	6 PM	23.97	Reduced Load 86.9%
09/05/23	7 PM	23.99	Reduced Load 86.9%
09/05/23	8 PM	23.99	Reduced Load 86.9%
09/05/23	9 PM	23.98	Reduced Load 86.9%
09/05/23	10 PM	23.99	Reduced Load 86.9%
09/05/23	11 PM	23.98	Reduced Load 86.9%
09/06/23	12 AM	23.97	Reduced Load 86.9%
09/06/23	1 AM	23.97	Reduced Load 86.8%
09/06/23	2 AM	23.95	Reduced Load 86.8%
09/06/23	3 AM	23.97	Reduced Load 86.9%
09/06/23	4 AM	23.99	Reduced Load 86.9%
09/06/23	5 AM	23.96	Reduced Load 86.8%
09/06/23	6 AM	23.01	Shutdown
09/06/23	2 PM	10.38	Startup
09/06/23	4 PM	24.76	Reduced Load 89.7%
09/06/23	5 PM	23.97	Reduced Load 86.9%
09/06/23	6 PM	23.99	Reduced Load 86.9%
09/06/23	7 PM	23.96	Reduced Load 86.8%
09/06/23	8 PM	23.99	Reduced Load 86.9%
09/06/23	9 PM	23.99	Reduced Load 86.9%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
09/06/23	10 PM	23.99	Reduced Load 86.9%
09/06/23	11 PM	23.97	Reduced Load 86.9%
09/07/23	12 AM	23.99	Reduced Load 86.9%
09/07/23	1 AM	23.98	Reduced Load 86.9%
09/07/23	2 AM	23.97	Reduced Load 86.8%
09/07/23	3 AM	23.92	Reduced Load 86.7%
09/07/23	4 AM	23.99	Reduced Load 86.9%
09/07/23	5 AM	23.95	Reduced Load 86.8%
09/07/23	6 AM	23.92	Reduced Load 86.7%
09/07/23	7 AM	23.94	Reduced Load 86.7%
09/07/23	8 AM	23.97	Reduced Load 86.9%
09/07/23	9 AM	23.98	Reduced Load 86.9%
09/07/23	10 AM	23.98	Reduced Load 86.9%
09/07/23	11 AM	23.96	Reduced Load 86.8%
09/07/23	12 PM	23.93	Reduced Load 86.7%
09/07/23	1 PM	23.96	Reduced Load 86.8%
09/07/23	2 PM	23.98	Reduced Load 86.9%
09/07/23	3 PM	23.97	Reduced Load 86.9%
09/07/23	4 PM	23.99	Reduced Load 86.9%
09/07/23	5 PM	23.99	Reduced Load 86.9%
09/07/23	6 PM	23.97	Reduced Load 86.9%
09/07/23	7 PM	23.99	Reduced Load 86.9%
09/07/23	8 PM	23.99	Reduced Load 86.9%
09/07/23	9 PM	23.99	Reduced Load 86.9%
09/07/23	10 PM	24.00	Reduced Load 86.9%
09/07/23	11 PM	24.00	Reduced Load 86.9%
09/08/23	12 AM	23.99	Reduced Load 86.9%
09/08/23	1 AM	23.98	Reduced Load 86.9%
09/08/23	2 AM	23.96	Reduced Load 86.8%
09/08/23	3 AM	23.99	Reduced Load 86.9%
09/08/23	4 AM	23.99	Reduced Load 86.9%
09/08/23	5 AM	23.99	Reduced Load 86.9%
09/08/23	6 AM	23.99	Reduced Load 86.9%
09/08/23	7 AM	23.98	Reduced Load 86.9%
09/08/23	8 AM	23.99	Reduced Load 86.9%
09/08/23	9 AM	23.98	Reduced Load 86.9%
09/08/23	10 AM	23.99	Reduced Load 86.9%
09/08/23	11 AM	23.99	Reduced Load 86.9%
09/08/23	12 PM	23.98	Reduced Load 86.9%
09/08/23	1 PM	23.99	Reduced Load 86.9%
09/08/23	2 PM	23.98	Reduced Load 86.9%
09/08/23	3 PM	23.94	Reduced Load 86.8%
09/08/23	4 PM	23.97	Reduced Load 86.8%
09/08/23	5 PM	23.99	Reduced Load 86.9%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
09/08/23	6 PM	23.95	Reduced Load 86.8%
09/08/23	7 PM	23.96	Reduced Load 86.8%
09/08/23	8 PM	23.92	Reduced Load 86.7%
09/08/23	9 PM	24.00	Reduced Load 86.9%
09/08/23	10 PM	23.98	Reduced Load 86.9%
09/08/23	11 PM	24.00	Reduced Load 86.9%
09/09/23	12 AM	23.99	Reduced Load 86.9%
09/09/23	1 AM	23.99	Reduced Load 86.9%
09/09/23	2 AM	23.99	Reduced Load 86.9%
09/09/23	3 AM	23.99	Reduced Load 86.9%
09/09/23	4 AM	23.99	Reduced Load 86.9%
09/09/23	5 AM	23.97	Reduced Load 86.8%
09/09/23	6 AM	23.98	Reduced Load 86.9%
09/09/23	7 AM	23.99	Reduced Load 86.9%
09/09/23	8 AM	23.97	Reduced Load 86.9%
09/09/23	9 AM	23.99	Reduced Load 86.9%
09/09/23	10 AM	23.99	Reduced Load 86.9%
09/09/23	11 AM	23.99	Reduced Load 86.9%
09/09/23	12 PM	23.98	Reduced Load 86.9%
09/09/23	1 PM	23.99	Reduced Load 86.9%
09/09/23	2 PM	23.99	Reduced Load 86.9%
09/09/23	3 PM	24.00	Reduced Load 87.0%
09/09/23	4 PM	23.99	Reduced Load 86.9%
09/09/23	5 PM	23.99	Reduced Load 86.9%
09/09/23	6 PM	23.98	Reduced Load 86.9%
09/09/23	7 PM	23.98	Reduced Load 86.9%
09/09/23	8 PM	23.98	Reduced Load 86.9%
09/09/23	9 PM	23.98	Reduced Load 86.9%
09/09/23	10 PM	23.99	Reduced Load 86.9%
09/09/23	11 PM	23.99	Reduced Load 86.9%
09/10/23	12 AM	23.99	Reduced Load 86.9%
09/10/23	1 AM	23.98	Reduced Load 86.9%
09/10/23	2 AM	23.99	Reduced Load 86.9%
09/10/23	3 AM	24.00	Reduced Load 86.9%
09/10/23	4 AM	23.99	Reduced Load 86.9%
09/10/23	5 AM	24.00	Reduced Load 86.9%
09/10/23	6 AM	23.99	Reduced Load 86.9%
09/10/23	7 AM	23.99	Reduced Load 86.9%
09/10/23	8 AM	23.99	Reduced Load 86.9%
09/10/23	9 AM	23.99	Reduced Load 86.9%
09/10/23	10 AM	23.99	Reduced Load 86.9%
09/10/23	11 AM	23.98	Reduced Load 86.9%
09/10/23	12 PM	23.98	Reduced Load 86.9%
09/10/23	1 PM	23.98	Reduced Load 86.9%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
09/10/23	2 PM	23.98	Reduced Load 86.9%
09/10/23	3 PM	23.98	Reduced Load 86.9%
09/10/23	4 PM	23.97	Reduced Load 86.8%
09/10/23	5 PM	23.99	Reduced Load 86.9%
09/10/23	6 PM	23.91	Reduced Load 86.6%
09/10/23	7 PM	23.91	Reduced Load 86.6%
09/10/23	8 PM	23.97	Reduced Load 86.9%
09/10/23	9 PM	23.98	Reduced Load 86.9%
09/10/23	10 PM	23.98	Reduced Load 86.9%
09/10/23	11 PM	23.96	Reduced Load 86.8%
09/11/23	12 AM	23.99	Reduced Load 86.9%
09/11/23	1 AM	23.99	Reduced Load 86.9%
09/11/23	2 AM	24.00	Reduced Load 86.9%
09/11/23	3 AM	23.99	Reduced Load 86.9%
09/11/23	4 AM	23.99	Reduced Load 86.9%
09/11/23	5 AM	23.99	Reduced Load 86.9%
09/11/23	6 AM	23.99	Reduced Load 86.9%
09/11/23	7 AM	23.98	Reduced Load 86.9%
09/11/23	8 AM	23.99	Reduced Load 86.9%
09/11/23	9 AM	23.99	Reduced Load 86.9%
09/11/23	10 AM	23.97	Reduced Load 86.9%
09/11/23	11 AM	23.99	Reduced Load 86.9%
09/11/23	12 PM	23.99	Reduced Load 86.9%
09/11/23	1 PM	23.98	Reduced Load 86.9%
09/11/23	2 PM	23.99	Reduced Load 86.9%
09/11/23	3 PM	23.96	Reduced Load 86.8%
09/11/23	4 PM	23.99	Reduced Load 86.9%
09/11/23	5 PM	23.97	Reduced Load 86.9%
09/11/23	6 PM	23.96	Reduced Load 86.8%
09/11/23	7 PM	23.98	Reduced Load 86.9%
09/11/23	8 PM	23.84	Reduced Load 86.4%
09/11/23	9 PM	23.99	Reduced Load 86.9%
09/11/23	10 PM	23.99	Reduced Load 86.9%
09/11/23	11 PM	23.99	Reduced Load 86.9%
09/12/23	12 AM	23.98	Reduced Load 86.9%
09/12/23	1 AM	23.98	Reduced Load 86.9%
09/12/23	2 AM	24.00	Reduced Load 86.9%
09/12/23	3 AM	23.98	Reduced Load 86.9%
09/12/23	4 AM	23.98	Reduced Load 86.9%
09/12/23	5 AM	23.98	Reduced Load 86.9%
09/12/23	6 AM	23.98	Reduced Load 86.9%
09/12/23	7 AM	23.99	Reduced Load 86.9%
09/12/23	8 AM	23.97	Reduced Load 86.9%
09/12/23	9 AM	23.96	Reduced Load 86.8%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
09/12/23	10 AM	23.97	Reduced Load 86.9%
09/12/23	11 AM	23.97	Reduced Load 86.9%
09/12/23	12 PM	23.95	Reduced Load 86.8%
09/12/23	1 PM	23.97	Reduced Load 86.9%
09/12/23	2 PM	23.96	Reduced Load 86.8%
09/12/23	3 PM	23.97	Reduced Load 86.8%
09/12/23	4 PM	23.08	Shutdown
09/12/23	7 PM	13.70	Startup
09/12/23	8 PM	23.99	Reduced Load 86.9%
09/12/23	9 PM	23.99	Reduced Load 86.9%
09/12/23	10 PM	23.97	Reduced Load 86.9%
09/12/23	11 PM	23.97	Reduced Load 86.9%
09/13/23	12 AM	23.95	Reduced Load 86.8%
09/13/23	1 AM	23.95	Reduced Load 86.8%
09/13/23	2 AM	23.94	Reduced Load 86.7%
09/13/23	3 AM	23.96	Reduced Load 86.8%
09/13/23	4 AM	23.98	Reduced Load 86.9%
09/13/23	5 AM	23.96	Reduced Load 86.8%
09/13/23	6 AM	23.95	Reduced Load 86.8%
09/13/23	7 AM	23.93	Reduced Load 86.7%
09/13/23	8 AM	23.96	Reduced Load 86.8%
09/13/23	9 AM	23.96	Reduced Load 86.8%
09/13/23	10 AM	23.96	Reduced Load 86.8%
09/13/23	11 AM	23.94	Reduced Load 86.7%
09/13/23	12 PM	23.97	Reduced Load 86.8%
09/13/23	1 PM	23.95	Reduced Load 86.8%
09/13/23	2 PM	23.97	Shutdown
09/13/23	6 PM	20.51	Startup
09/13/23	7 PM	23.99	Reduced Load 86.9%
09/13/23	8 PM	23.99	Reduced Load 86.9%
09/13/23	9 PM	23.99	Reduced Load 86.9%
09/13/23	10 PM	24.00	Reduced Load 87.0%
09/13/23	11 PM	24.00	Reduced Load 86.9%
09/14/23	12 AM	24.00	Reduced Load 87.0%
09/14/23	1 AM	23.99	Reduced Load 86.9%
09/14/23	2 AM	23.97	Reduced Load 86.9%
09/14/23	3 AM	24.00	Reduced Load 86.9%
09/14/23	4 AM	24.00	Reduced Load 87.0%
09/14/23	5 AM	23.99	Reduced Load 86.9%
09/14/23	6 AM	23.99	Reduced Load 86.9%
09/14/23	7 AM	23.98	Reduced Load 86.9%
09/14/23	8 AM	23.99	Reduced Load 86.9%
09/14/23	9 AM	23.99	Reduced Load 86.9%
09/14/23	10 AM	23.99	Reduced Load 86.9%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
09/14/23	11 AM	23.99	Reduced Load 86.9%
09/14/23	12 PM	23.98	Reduced Load 86.9%
09/14/23	1 PM	23.96	Reduced Load 86.8%
09/14/23	2 PM	23.96	Reduced Load 86.8%
09/14/23	3 PM	23.96	Reduced Load 86.8%
09/14/23	4 PM	23.99	Reduced Load 86.9%
09/14/23	5 PM	23.99	Reduced Load 86.9%
09/14/23	6 PM	23.99	Reduced Load 86.9%
09/14/23	7 PM	24.00	Reduced Load 87.0%
09/14/23	8 PM	23.99	Reduced Load 86.9%
09/14/23	9 PM	23.98	Reduced Load 86.9%
09/14/23	10 PM	23.99	Reduced Load 86.9%
09/14/23	11 PM	23.99	Reduced Load 86.9%
09/15/23	12 AM	24.00	Reduced Load 86.9%
09/15/23	1 AM	23.98	Reduced Load 86.9%
09/15/23	2 AM	23.99	Reduced Load 86.9%
09/15/23	3 AM	23.98	Reduced Load 86.9%
09/15/23	4 AM	23.99	Reduced Load 86.9%
09/15/23	5 AM	23.99	Reduced Load 86.9%
09/15/23	6 AM	23.97	Reduced Load 86.9%
09/15/23	7 AM	23.95	Reduced Load 86.8%
09/15/23	8 AM	23.98	Reduced Load 86.9%
09/15/23	9 AM	23.98	Reduced Load 86.9%
09/15/23	10 AM	23.98	Reduced Load 86.9%
09/15/23	11 AM	23.99	Reduced Load 86.9%
09/15/23	12 PM	23.98	Reduced Load 86.9%
09/15/23	1 PM	23.99	Reduced Load 86.9%
09/15/23	2 PM	23.98	Reduced Load 86.9%
09/15/23	3 PM	23.98	Reduced Load 86.9%
09/15/23	4 PM	23.99	Reduced Load 86.9%
09/15/23	5 PM	23.99	Reduced Load 86.9%
09/15/23	6 PM	24.00	Reduced Load 86.9%
09/15/23	7 PM	23.99	Reduced Load 86.9%
09/15/23	8 PM	23.99	Reduced Load 86.9%
09/15/23	9 PM	23.99	Reduced Load 86.9%
09/15/23	10 PM	23.99	Reduced Load 86.9%
09/15/23	11 PM	23.99	Reduced Load 86.9%
09/16/23	12 AM	23.98	Reduced Load 86.9%
09/16/23	1 AM	23.99	Reduced Load 86.9%
09/16/23	2 AM	23.98	Reduced Load 86.9%
09/16/23	3 AM	23.99	Reduced Load 86.9%
09/16/23	4 AM	23.93	Reduced Load 86.7%
09/16/23	5 AM	23.95	Reduced Load 86.8%
09/16/23	6 AM	23.98	Reduced Load 86.9%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
09/16/23	7 AM	23.98	Reduced Load 86.9%
09/16/23	8 AM	23.99	Reduced Load 86.9%
09/16/23	9 AM	23.98	Reduced Load 86.9%
09/16/23	10 AM	23.97	Reduced Load 86.9%
09/16/23	11 AM	21.56	Shutdown
09/16/23	4 PM	15.39	Startup
09/16/23	5 PM	23.99	Reduced Load 86.9%
09/16/23	6 PM	23.99	Reduced Load 86.9%
09/16/23	7 PM	23.99	Reduced Load 86.9%
09/16/23	8 PM	23.99	Reduced Load 86.9%
09/16/23	9 PM	23.98	Reduced Load 86.9%
09/16/23	10 PM	24.00	Reduced Load 86.9%
09/16/23	11 PM	23.99	Reduced Load 86.9%
09/17/23	12 AM	23.99	Reduced Load 86.9%
09/17/23	1 AM	23.95	Reduced Load 86.8%
09/17/23	2 AM	23.98	Reduced Load 86.9%
09/17/23	3 AM	23.99	Reduced Load 86.9%
09/17/23	4 AM	23.99	Reduced Load 86.9%
09/17/23	5 AM	16.05	Shutdown
09/17/23	3 PM	23.14	Startup
09/17/23	4 PM	23.88	Reduced Load 86.5%
09/17/23	5 PM	23.93	Reduced Load 86.7%
09/17/23	6 PM	23.97	Reduced Load 86.8%
09/17/23	7 PM	23.98	Reduced Load 86.9%
09/17/23	8 PM	23.98	Reduced Load 86.9%
09/17/23	9 PM	23.98	Reduced Load 86.9%
09/17/23	10 PM	23.94	Reduced Load 86.8%
09/17/23	11 PM	23.96	Reduced Load 86.8%
09/18/23	12 AM	23.96	Reduced Load 86.8%
09/18/23	1 AM	23.98	Reduced Load 86.9%
09/18/23	2 AM	23.99	Reduced Load 86.9%
09/18/23	3 AM	23.95	Reduced Load 86.8%
09/18/23	4 AM	23.99	Reduced Load 86.9%
09/18/23	5 AM	23.99	Reduced Load 86.9%
09/18/23	6 AM	23.97	Reduced Load 86.9%
09/18/23	7 AM	23.98	Reduced Load 86.9%
09/18/23	8 AM	23.97	Reduced Load 86.8%
09/18/23	9 AM	23.98	Reduced Load 86.9%
09/18/23	10 AM	23.99	Reduced Load 86.9%
09/18/23	11 AM	23.98	Reduced Load 86.9%
09/18/23	12 PM	23.98	Reduced Load 86.9%
09/18/23	1 PM	23.99	Reduced Load 86.9%
09/18/23	2 PM	23.99	Reduced Load 86.9%
09/18/23	3 PM	23.96	Reduced Load 86.8%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
09/18/23	4 PM	23.99	Reduced Load 86.9%
09/18/23	5 PM	23.99	Reduced Load 86.9%
09/18/23	6 PM	23.98	Reduced Load 86.9%
09/18/23	7 PM	23.99	Reduced Load 86.9%
09/18/23	8 PM	23.98	Reduced Load 86.9%
09/18/23	9 PM	23.98	Reduced Load 86.9%
09/18/23	10 PM	24.00	Reduced Load 86.9%
09/18/23	11 PM	23.98	Reduced Load 86.9%
09/19/23	12 AM	23.98	Reduced Load 86.9%
09/19/23	1 AM	23.98	Reduced Load 86.9%
09/19/23	2 AM	23.99	Reduced Load 86.9%
09/19/23	3 AM	23.99	Reduced Load 86.9%
09/19/23	4 AM	23.99	Reduced Load 86.9%
09/19/23	5 AM	23.98	Reduced Load 86.9%
09/19/23	6 AM	23.93	Reduced Load 86.7%
09/19/23	7 AM	23.95	Reduced Load 86.8%
09/19/23	8 AM	23.98	Reduced Load 86.9%
09/19/23	9 AM	23.96	Reduced Load 86.8%
09/19/23	10 AM	23.99	Reduced Load 86.9%
09/19/23	11 AM	23.98	Reduced Load 86.9%
09/19/23	12 PM	23.98	Reduced Load 86.9%
09/19/23	1 PM	23.99	Reduced Load 86.9%
09/19/23	2 PM	23.99	Reduced Load 86.9%
09/19/23	3 PM	23.99	Reduced Load 86.9%
09/19/23	4 PM	23.99	Reduced Load 86.9%
09/19/23	5 PM	23.99	Reduced Load 86.9%
09/19/23	6 PM	23.98	Reduced Load 86.9%
09/19/23	7 PM	23.99	Reduced Load 86.9%
09/19/23	8 PM	23.99	Reduced Load 86.9%
09/19/23	9 PM	23.99	Reduced Load 86.9%
09/19/23	10 PM	23.96	Reduced Load 86.8%
09/19/23	11 PM	23.98	Reduced Load 86.9%
09/20/23	12 AM	23.95	Reduced Load 86.8%
09/20/23	1 AM	23.90	Reduced Load 86.6%
09/20/23	2 AM	23.98	Reduced Load 86.9%
09/20/23	3 AM	23.92	Reduced Load 86.7%
09/20/23	4 AM	23.99	Reduced Load 86.9%
09/20/23	5 AM	23.97	Reduced Load 86.8%
09/20/23	6 AM	23.92	Reduced Load 86.7%
09/20/23	7 AM	23.78	Shutdown
09/20/23	6 PM	19.82	Startup
09/24/25	9 AM	7.87	Shutdown
09/24/25	1 PM	7.46	Startup
09/26/25	2 AM	13.15	Shutdown

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
09/26/25	9 AM	20.71	Startup
09/26/25	10 AM	24.59	Shutdown
09/26/25	2 PM	9.48	Startup
09/27/25	1 AM	16.44	Shutdown
09/27/25	12 PM	15.21	Startup
09/28/25	2 AM	11.38	Shutdown
09/28/25	3 PM	19.53	Startup
09/29/25	2 AM	15.30	Shutdown
10/02/23	8 PM	15.95	Startup
10/02/23	11 PM	7.94	Shutdown
10/06/23	7 PM	18.89	Startup
10/06/23	10 PM	9.82	Shutdown
10/09/23	9 PM	12.19	Shutdown
11/12/23	8 PM	17.45	Startup
11/12/23	10 PM	20.83	Shutdown
11/13/23	6 PM	11.95	Startup
11/13/25	10 PM	21.72	Shutdown
11/17/25	8 PM	8.92	Shutdown
12/05/25	1 PM	13.21	Startup
12/05/25	10 PM	15.72	Shutdown

**National Emission Standard for Hazardous Air Pollutants Subpart YYYY
Semi-Annual Report (40 CFR 63.6150)**

Pollutant: Formaldehyde, parts per billion by volume correct to 15% oxygen dry basis (ppbvdc)

Emission Limitation: 91 ppbvdc natural gas and oil firing

Reporting period dates: From January 1, 2024 to June 30, 2024

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-1

Monitor Manufacturer and Model No.: Satec PM130EH Plus

Date of Latest CMS Certification or Audit: N/A

Total source operating time in reporting period¹: 307

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 86	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 0	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 0	c. Quality assurance calibration – 0 hours
d. Other known causes – 1	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 87	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 2.8%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%

¹ For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.


On a separate page, describe any changes since last quarter in CMS, process or controls.
NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature



Title

Vice President- EEHS & Regulatory

Date

9/5/2025

Excess Emissions

Per agreement with USEPA, an operating load less than 90% is a period of noncompliance. The unit is rated at 27.6 megawatts (MW) and 90% operating load is 24.8 MW. There are no conversion factors from operating load to ppbvdc. Therefore, hours with operating load below 24.8 MW are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
01/19/24	12 AM	8.84	Startup	
01/19/24	3 AM	9.49	Shutdown	
03/30/24	7 PM	23.65	Startup	
03/31/24	2 AM	19.10	Shutdown	
03/31/24	7 PM	16.88	Startup	
03/31/24	11 PM	8.60	Shutdown	
04/01/24	6 PM	24.00	Startup	
04/01/24	11 PM	19.07	Shutdown	
04/02/24	7 PM	15.79	Startup	
04/02/24	9 PM	20.22	Shutdown	
04/05/24	2 PM	7.49	Startup	
04/05/24	9 PM	17.71	Shutdown	
04/06/24	6 PM	23.22	Startup	
04/06/24	11 PM	14.77	Shutdown	
04/07/24	6 PM	17.66	Startup	
04/07/24	11 PM	15.06	Shutdown	
04/20/24	8 PM	21.63	Startup	
04/20/24	11 PM	16.81	Shutdown	
04/21/24	6 PM	7.32	Startup	
04/21/24	7 PM	24.68	Reduced Load	89.4%
04/21/24	11 PM	15.90	Shutdown	
04/22/24	6 PM	18.24	Startup	
04/22/24	10 PM	23.54	Shutdown	
04/25/24	7 PM	13.92	Startup	
04/25/24	9 PM	23.05	Shutdown	
04/29/24	10 PM	13.86	Shutdown	
04/30/24	5 PM	22.58	Startup	
04/30/24	10 PM	22.98	Shutdown	
05/01/24	4 PM	24.67	Startup	
05/02/24	2 PM	22.86	Startup	
05/02/24	11 PM	20.58	Shutdown	
05/03/24	11 AM	13.37	Startup	
05/03/24	9 PM	8.59	Shutdown	
05/04/24	6 PM	20.71	Startup	
05/04/24	9 PM	17.32	Shutdown	
05/11/24	4 PM	22.54	Startup	
05/11/24	8 PM	21.88	Shutdown	

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
05/13/24	6 PM	9.52	Startup
05/13/24	10 PM	22.54	Shutdown
05/14/24	7 PM	15.95	Startup
05/14/24	11 PM	11.82	Shutdown
05/15/24	5 PM	20.03	Startup
05/15/24	10 PM	17.78	Shutdown
05/20/24	7 PM	15.05	Startup
05/21/24	4 PM	6.93	Startup
05/23/24	5 PM	20.69	Startup
05/24/24	8 AM	14.81	Startup
05/24/24	9 PM	6.94	Shutdown
05/25/24	6 PM	18.44	Startup
05/25/24	10 PM	22.90	Shutdown
05/26/24	5 PM	19.87	Startup
05/27/24	1 AM	7.05	Shutdown
05/27/24	5 PM	23.10	Startup
05/28/24	10 PM	19.02	Shutdown
05/29/24	8 PM	19.10	Startup
05/29/24	11 PM	16.02	Shutdown
05/30/24	7 AM	13.56	Startup
05/30/24	11 PM	23.54	Shutdown
05/31/24	6 PM	18.42	Startup
05/31/24	11 PM	7.76	Shutdown
06/01/24	7 PM	11.60	Startup
06/01/24	10 PM	14.03	Shutdown
06/04/24	8 PM	24.61	Startup
06/04/24	10 PM	21.99	Shutdown
06/05/24	12 PM	17.80	Startup
06/05/24	11 PM	9.53	Shutdown
06/06/24	5 PM	18.62	Startup
06/06/24	10 PM	13.71	Shutdown
06/08/24	2 PM	16.99	Startup
06/09/24	12 AM	14.24	Shutdown
06/09/24	2 PM	18.01	Startup
06/10/24	12 AM	24.61	Shutdown
06/10/24	12 PM	16.84	Startup
06/11/24	12 AM	17.75	Shutdown
06/11/24	4 PM	7.04	Startup
06/11/24	9 PM	22.93	Shutdown
06/12/24	4 PM	10.81	Startup
06/13/24	12 AM	19.20	Shutdown
06/13/24	10 PM	19.52	Shutdown
06/14/24	4 PM	12.02	Startup
06/14/24	8 PM	21.86	Shutdown

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
06/18/24	6 PM	23.26	Startup	
06/18/24	10 PM	20.25	Shutdown	
06/19/24	6 PM	8.12	Startup	
06/19/24	10 PM	20.32	Shutdown	
06/25/24	11 PM	15.00	Startup	
06/26/24	1 AM	13.22	Shutdown	

**National Emission Standard for Hazardous Air Pollutants Subpart YYYY
Semi-Annual Report (40 CFR 63.6150)**

Pollutant: Formaldehyde, parts per billion by volume correct to 15% oxygen dry basis (ppbvdc)

Emission Limitation: 91 ppbvdc natural gas and oil firing

Reporting period dates: From July 1, 2024 to December 31, 2024

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-1

Monitor Manufacturer and Model No.: Satec PM130EH Plus

Date of Latest CMS Certification or Audit: N/A

Total source operating time in reporting period¹: 829

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 236	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 0	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 4	c. Quality assurance calibration – 0 hours
d. Other known causes – 19	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 259	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 31.2%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%

¹ For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.


On a separate page, describe any changes since last quarter in CMS, process or controls.
NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature



Title

Vice President- EEHS & Regulatory

Date

9/5/2025

Excess Emissions

Per agreement with USEPA, an operating load less than 90% is a period of noncompliance. The unit is rated at 27.6 megawatts (MW) and 90% operating load is 24.8 MW. There are no conversion factors from operating load to ppbvdc. Therefore, hours with operating load below 24.8 MW are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
07/06/24	7 PM	13.05	Malfunction	
07/11/24	5 PM	11.93	Startup	
07/11/24	6 PM	9.40	Reduced Load	34.1%
07/11/24	7 PM	10.67	Reduced Load	38.7%
07/11/24	8 PM	7.60	Shutdown	
07/12/24	2 PM	19.66	Startup	
07/12/24	3 PM	8.01	Shutdown	
07/12/24	5 PM	17.95	Startup	
07/12/24	10 PM	22.04	Shutdown	
07/18/24	1 PM	10.02	Malfunction	
07/18/24	4 PM	8.56	Malfunction	
07/18/24	7 PM	14.79	Startup	
07/18/24	11 PM	21.43	Shutdown	
07/22/24	9 AM	13.73	Malfunction	
08/01/24	6 AM	9.17	Startup	
08/01/24	10 AM	14.22	Shutdown	
08/01/24	2 PM	7.10	Startup	
08/01/24	5 PM	18.31	Shutdown	
08/05/24	6 PM	16.47	Startup	
08/05/24	11 PM	15.04	Shutdown	
08/06/24	6 PM	14.76	Startup	
08/07/24	6 PM	15.74	Startup	
08/07/24	9 PM	24.73	Shutdown	
08/08/24	8 PM	23.70	Reduced Load	85.9%
08/08/24	10 PM	7.92	Shutdown	
08/09/24	2 AM	12.18	Startup	
08/10/24	1 AM	17.48	Shutdown	
08/13/24	11 PM	23.67	Shutdown	
08/15/24	4 PM	14.91	Startup	
08/16/24	2 AM	19.35	Shutdown	
08/16/24	4 PM	15.35	Startup	
08/17/24	1 AM	23.51	Shutdown	
08/17/24	1 PM	11.84	Startup	
08/18/24	6 PM	15.70	Startup	
08/18/24	11 PM	16.05	Shutdown	
08/19/24	3 PM	12.73	Startup	
08/21/24	3 PM	20.37	Startup	
08/21/24	10 PM	17.42	Shutdown	
08/22/24	3 PM	21.86	Startup	

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
08/24/24	2 AM	24.08	Shutdown
08/25/24	4 AM	21.07	Shutdown
08/25/24	4 PM	13.62	Startup
08/25/24	11 PM	24.72	Shutdown
08/26/24	3 PM	19.31	Startup
08/27/24	12 AM	7.57	Shutdown
08/27/24	11 PM	14.21	Shutdown
08/28/24	5 PM	22.32	Startup
08/29/24	1 AM	14.69	Shutdown
08/29/24	5 PM	7.01	Startup
08/30/24	12 AM	18.58	Shutdown
08/30/24	7 PM	23.67	Startup
08/31/24	7 PM	19.37	Startup
08/31/24	10 PM	20.76	Shutdown
09/01/24	7 PM	19.26	Startup
09/01/24	11 PM	12.14	Shutdown
09/02/24	5 PM	24.76	Startup
09/02/24	11 PM	24.05	Shutdown
09/03/24	3 PM	11.26	Startup
09/04/24	7 AM	24.19	Shutdown
09/04/24	4 PM	20.43	Startup
09/05/24	1 AM	20.84	Shutdown
09/05/24	3 PM	23.50	Startup
09/06/24	12 AM	18.34	Shutdown
09/06/24	1 PM	9.27	Startup
09/07/24	4 AM	21.36	Shutdown
09/07/24	2 PM	21.40	Startup
09/07/24	11 PM	10.24	Shutdown
09/10/24	2 PM	23.66	Startup
09/11/24	12 AM	13.19	Shutdown
09/11/24	9 AM	13.35	Startup
09/12/24	6 AM	23.85	Shutdown
09/12/24	2 PM	8.94	Startup
09/12/24	11 PM	14.06	Shutdown
09/13/24	2 PM	12.87	Startup
09/14/24	4 PM	14.76	Startup
09/15/24	4 PM	16.47	Startup
09/15/24	11 PM	16.67	Shutdown
09/16/24	4 PM	7.03	Startup
09/16/24	11 PM	10.61	Shutdown
09/17/24	5 PM	16.31	Startup
09/17/24	10 PM	20.52	Shutdown
09/18/24	4 PM	22.08	Startup
09/18/24	9 PM	18.80	Shutdown
09/19/24	9 PM	12.15	Shutdown

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
09/20/24	8 PM	22.31	Shutdown	
09/21/24	4 PM	13.00	Startup	
09/23/24	5 PM	8.73	Startup	
09/24/24	3 PM	22.58	Startup	
09/24/24	10 PM	20.04	Shutdown	
09/25/24	6 PM	13.86	Startup	
09/25/24	11 PM	9.48	Shutdown	
09/26/24	6 PM	12.83	Startup	
09/26/24	10 PM	20.76	Shutdown	
09/30/24	8 PM	18.06	Startup	
09/30/24	11 PM	7.98	Shutdown	
10/01/24	2 PM	23.30	Reduced Load	84.4%
10/01/24	7 PM	24.66	Reduced Load	89.4%
10/01/24	11 PM	15.75	Shutdown	
10/02/24	4 PM	20.00	Startup	
10/03/24	12 AM	19.39	Shutdown	
10/03/24	4 PM	22.09	Reduced Load	80.0%
10/03/24	6 PM	24.45	Reduced Load	88.6%
10/04/24	1 AM	15.39	Shutdown	
10/04/24	4 PM	23.29	Startup	
10/04/24	7 PM	24.77	Reduced Load	89.7%
10/04/24	11 PM	22.38	Shutdown	
10/05/24	3 PM	10.70	Startup	
10/05/24	6 PM	24.76	Reduced Load	89.7%
10/05/24	10 PM	15.86	Shutdown	
10/07/24	6 PM	16.14	Startup	
10/07/24	11 PM	15.41	Shutdown	
10/08/24	3 PM	11.15	Startup	
10/08/24	10 PM	24.75	Reduced Load	89.7%
10/08/24	11 PM	13.89	Shutdown	
10/09/24	2 PM	24.07	Startup	
10/10/24	2 AM	19.32	Shutdown	
10/10/24	6 AM	23.88	Startup	
10/10/24	4 PM	24.65	Reduced Load	89.3%
10/11/24	1 AM	20.54	Shutdown	
10/11/24	2 PM	11.46	Startup	
10/12/24	2 AM	18.83	Shutdown	
10/12/24	4 PM	13.37	Startup	
10/13/24	12 AM	13.22	Shutdown	
10/13/24	3 PM	20.68	Startup	
10/13/24	11 PM	24.54	Shutdown	
10/14/24	4 PM	20.05	Startup	
10/14/24	10 PM	23.38	Shutdown	
10/15/24	2 PM	19.52	Startup	
10/15/24	10 PM	16.19	Shutdown	

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
10/18/24	7 PM	24.40	Reduced Load	88.4%
10/18/24	9 PM	24.47	Reduced Load	88.7%
10/21/24	1 AM	16.24	Shutdown	
10/21/24	3 PM	7.67	Startup	
10/21/24	10 PM	19.54	Shutdown	
10/22/24	2 PM	14.78	Startup	
10/22/24	9 PM	19.91	Shutdown	
10/23/24	9 PM	22.97	Shutdown	
10/24/24	4 PM	24.66	Startup	
10/24/24	9 PM	17.71	Shutdown	
10/28/24	8 PM	23.10	Reduced Load	83.7%
10/28/24	9 PM	18.77	Shutdown	
10/29/24	4 PM	21.19	Startup	
10/29/24	9 PM	21.17	Shutdown	
10/30/24	2 PM	9.92	Startup	
10/30/24	10 PM	11.61	Shutdown	
11/04/24	4 PM	10.07	Startup	
11/04/24	10 PM	14.70	Shutdown	
11/13/24	2 PM	11.35	Startup	
11/14/24	9 PM	17.14	Shutdown	
11/18/24	5 PM	19.44	Startup	
11/18/24	8 PM	7.32	Shutdown	
11/19/24	5 PM	18.44	Startup	
11/19/24	10 PM	15.86	Shutdown	
11/20/24	4 PM	17.72	Startup	
11/20/24	10 PM	21.95	Shutdown	
11/21/24	4 PM	16.44	Startup	
11/21/24	10 PM	18.82	Shutdown	
11/22/24	5 PM	19.43	Startup	
11/23/24	12 AM	23.39	Shutdown	
11/23/24	5 PM	19.60	Startup	
11/23/24	11 PM	18.85	Shutdown	
11/29/24	5 PM	10.57	Startup	
11/29/24	9 PM	13.71	Shutdown	
11/30/24	7 PM	24.53	Startup	
11/30/24	9 PM	23.11	Shutdown	
12/02/24	3 PM	13.43	Startup	
12/02/24	9 PM	20.97	Shutdown	
12/05/24	4 PM	13.94	Startup	
12/06/24	2 AM	21.09	Shutdown	
12/06/24	4 PM	17.68	Startup	
12/07/24	12 AM	23.66	Shutdown	
12/07/24	5 PM	14.55	Startup	
12/08/24	6 PM	11.86	Startup	
12/08/24	8 PM	24.72	Reduced Load	89.6%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
12/09/24	5 PM	7.00	Startup	
12/09/24	10 PM	15.83	Shutdown	
12/10/24	9 AM	20.55	Shutdown	
12/12/24	11 PM	17.26	Shutdown	
12/13/24	4 PM	15.00	Startup	
12/13/24	11 PM	8.23	Shutdown	
12/14/24	6 PM	20.08	Startup	
12/14/24	8 PM	8.09	Shutdown	
12/15/24	6 PM	19.80	Startup	
12/15/24	10 PM	15.71	Shutdown	
12/16/24	2 PM	10.32	Startup	
12/16/24	9 PM	24.69	Shutdown	
12/17/24	1 PM	19.74	Startup	
12/17/24	11 PM	15.60	Shutdown	
12/18/24	3 PM	16.80	Startup	
12/18/24	8 PM	9.59	Shutdown	
12/19/24	1 PM	16.17	Startup	
12/19/24	2 PM	20.00	Reduced Load	72.4%
12/19/24	3 PM	20.65	Reduced Load	74.8%
12/19/24	8 PM	23.77	Shutdown	
12/23/24	6 PM	9.80	Startup	
12/23/24	8 PM	13.52	Shutdown	
12/31/24	5 PM	22.23	Startup	
12/31/24	9 PM	24.76	Shutdown	

**National Emission Standard for Hazardous Air Pollutants Subpart YYYY
Semi-Annual Report (40 CFR 63.6150)**

Pollutant: Formaldehyde, parts per billion by volume correct to 15% oxygen dry basis (ppbvdc)

Emission Limitation: 91 ppbvdc natural gas and oil firing

Reporting period dates: From January 1, 2023 to June 30, 2023

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-2

Monitor Manufacturer and Model No.: Satec PM130EH Plus

Date of Latest CMS Certification or Audit: N/A

Total source operating time in reporting period¹: 1041.5

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 225	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 0	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 2	c. Quality assurance calibration – 0 hours
d. Other known causes – 0	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 227	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 21.8%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%

¹ For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.


On a separate page, describe any changes since last quarter in CMS, process or controls.
NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature



Title

Vice President- EEHS & Regulatory

Date

9/5/2025

Excess Emissions

Per agreement with USEPA, an operating load less than 90% is a period of noncompliance. The unit is rated at 27.6 megawatts (MW) and 90% operating load is 24.8 MW. There are no conversion factors from operating load to ppbvdc. Therefore, hours with operating load below 24.8 MW are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
1/12/2023	11 AM	18.21	Startup
1/12/2023	9 PM	22.87	Shutdown
1/13/2023	5 PM	16.81	Startup
1/13/2023	9 PM	15.71	Shutdown
1/14/2023	4 PM	20.02	Startup
1/14/2023	11 PM	22.42	Shutdown
1/15/2023	4 PM	18.50	Startup
1/15/2023	8 PM	15.48	Shutdown
1/17/2023	8 PM	16.46	Shutdown
1/18/2023	9 PM	12.79	Shutdown
1/19/2023	5 PM	13.10	Startup
1/19/2023	9 PM	20.40	Shutdown
1/20/2023	5 PM	22.95	Startup
1/20/2023	9 PM	11.66	Shutdown
1/22/2023	5 PM	7.33	Startup
1/22/2023	6 PM	23.71	Malfunction
1/22/2023	9 PM	24.79	Shutdown
1/23/2023	5 PM	17.52	Startup
1/23/2023	10 PM	24.59	Shutdown
1/24/2023	4 PM	15.92	Startup
1/24/2023	8 PM	17.46	Shutdown
1/26/2023	5 PM	24.05	Startup
1/26/2023	9 PM	21.40	Shutdown
2/3/2023	4 PM	15.18	Startup
2/3/2023	11 PM	22.93	Shutdown
2/4/2023	5 PM	7.86	Startup
2/4/2023	10 PM	11.57	Shutdown
2/6/2023	5 PM	16.62	Startup
2/7/2023	10 PM	17.91	Shutdown
2/8/2023	3 PM	23.52	Startup
2/8/2023	9 PM	22.18	Shutdown
2/9/2023	2 PM	12.74	Startup
2/9/2023	10 PM	23.10	Shutdown
2/10/2023	10 PM	21.80	Shutdown
2/11/2023	7 PM	24.01	Startup
2/14/2023	12 AM	22.60	Startup
2/14/2023	9 PM	22.34	Shutdown

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
2/15/2023	6 PM	17.63	Startup
2/16/2023	11 PM	22.03	Shutdown
2/17/2023	3 PM	19.14	Startup
2/17/2023	10 PM	14.86	Shutdown
2/20/2023	6 PM	21.79	Startup
2/20/2023	11 PM	14.77	Shutdown
2/21/2023	5 PM	13.64	Startup
2/21/2023	9 PM	12.52	Shutdown
2/22/2023	6 PM	22.71	Startup
2/22/2023	11 PM	13.44	Shutdown
2/23/2023	3 PM	7.39	Startup
2/23/2023	10 PM	20.42	Shutdown
2/24/2023	3 PM	16.98	Startup
2/24/2023	9 PM	16.39	Shutdown
2/25/2023	6 PM	18.55	Startup
2/25/2023	9 PM	21.00	Shutdown
2/27/2023	4 PM	18.60	Startup
2/27/2023	10 PM	19.49	Shutdown
2/28/2023	3 PM	12.97	Startup
2/28/2023	9 PM	23.86	Shutdown
3/1/2023	4 PM	13.09	Startup
3/1/2023	11 PM	24.19	Shutdown
3/2/2023	10 AM	24.45	Startup
3/2/2023	11 PM	24.47	Shutdown
3/3/2023	7 AM	14.21	Startup
3/4/2023	3 PM	17.29	Startup
3/4/2023	10 PM	22.14	Shutdown
3/5/2023	5 PM	14.11	Startup
3/5/2023	10 PM	12.06	Shutdown
3/6/2023	4 PM	16.38	Startup
3/6/2023	10 PM	18.49	Shutdown
3/7/2023	4 PM	11.28	Startup
3/7/2023	10 PM	7.14	Shutdown
3/8/2023	6 PM	13.66	Startup
3/8/2023	10 PM	24.70	Shutdown
3/11/2023	4 PM	14.65	Startup
3/11/2023	8 PM	21.29	Shutdown
3/13/2023	10 PM	24.38	Shutdown
3/14/2023	1 PM	12.18	Startup
3/15/2023	6 PM	10.63	Startup
3/15/2023	8 PM	8.62	Shutdown
3/19/2025	6 PM	12.82	Startup
3/19/2025	10 PM	22.91	Shutdown
3/20/2025	5 PM	19.82	Startup

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
3/20/2025	10 PM	24.03	Shutdown
3/21/2025	6 PM	20.25	Startup
3/21/2023	10 PM	23.17	Shutdown
3/22/2023	4 PM	16.61	Startup
3/22/2023	10 PM	23.09	Shutdown
3/23/2023	9 PM	21.87	Shutdown
3/25/2023	6 PM	17.88	Startup
3/26/2023	5 PM	18.78	Startup
3/28/2023	4 PM	17.47	Startup
3/28/2023	10 PM	15.76	Shutdown
3/29/2023	6 PM	11.60	Startup
3/29/2023	9 PM	19.59	Shutdown
3/30/2023	6 PM	21.37	Startup
4/1/2023	12 AM	15.16	Shutdown
4/2/2023	6 PM	9.70	Startup
4/2/2023	11 PM	20.93	Shutdown
4/3/2023	5 PM	17.86	Startup
4/3/2023	10 PM	20.13	Shutdown
4/4/2023	4 PM	18.98	Startup
4/4/2023	10 PM	16.64	Shutdown
4/10/2023	3 PM	21.80	Startup
4/11/2023	12 AM	18.71	Shutdown
4/11/2023	2 PM	18.28	Startup
4/11/2023	10 PM	23.45	Shutdown
4/12/2023	6 PM	24.21	Startup
4/12/2023	10 PM	21.72	Shutdown
4/13/2023	3 PM	9.84	Startup
4/13/2023	10 PM	20.65	Shutdown
4/14/2023	5 PM	24.64	Startup
4/14/2023	9 PM	11.03	Shutdown
4/15/2023	5 PM	21.37	Startup
4/15/2023	9 PM	18.65	Shutdown
4/18/2023	3 PM	11.72	Shutdown
4/19/2023	5 PM	12.83	Startup
4/19/2023	10 PM	9.25	Shutdown
4/20/2023	6 PM	12.41	Startup
4/20/2023	9 PM	8.01	Shutdown
4/24/2023	4 PM	11.29	Startup
4/24/2023	10 PM	8.83	Shutdown
4/25/2023	5 PM	16.87	Startup
4/25/2023	10 PM	21.73	Shutdown
4/26/2023	3 PM	18.44	Startup
4/27/2023	10 PM	20.33	Shutdown
4/28/2023	3 PM	17.86	Startup

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
4/28/2023	8 PM	13.16	Shutdown
4/29/2023	4 PM	11.60	Startup
4/29/2023	10 PM	16.31	Shutdown
4/30/2023	5 PM	20.08	Startup
4/30/2023	11 PM	14.91	Shutdown
5/1/2023	4 PM	20.95	Startup
5/1/2023	11 PM	18.03	Shutdown
5/2/2023	12 PM	23.51	Startup
5/2/2023	11 PM	18.00	Shutdown
5/3/2023	2 PM	13.14	Startup
5/3/2023	10 PM	20.83	Shutdown
5/4/2023	8 AM	19.98	Startup
5/5/2023	12 AM	14.70	Shutdown
5/5/2023	9 AM	21.11	Startup
5/5/2023	11 PM	7.34	Shutdown
5/7/2023	12 AM	11.97	Shutdown
5/7/2023	4 PM	20.46	Startup
5/7/2023	11 PM	11.66	Shutdown
5/8/2023	10 AM	21.09	Startup
5/8/2023	10 PM	20.41	Shutdown
5/9/2023	2 PM	23.30	Startup
5/10/2023	12 AM	8.34	Shutdown
5/10/2023	3 PM	19.89	Startup
5/10/2023	11 PM	20.90	Shutdown
5/11/2023	3 PM	19.29	Startup
5/12/2023	3 PM	17.55	Startup
5/13/2023	4 PM	20.68	Startup
5/14/2023	5 PM	13.01	Startup
5/15/2023	12 AM	19.49	Startup
5/15/2023	2 PM	10.54	Shutdown
5/16/2023	12 AM	20.00	Startup
5/16/2023	2 PM	16.94	Shutdown
5/17/2023	1 AM	15.96	Startup
5/17/2023	2 PM	21.86	Shutdown
5/18/2023	11 AM	7.60	Startup
5/18/2023	11 PM	17.88	Shutdown
5/19/2023	8 AM	21.54	Startup
5/19/2023	10 AM	9.43	Shutdown
5/19/2023	5 PM	13.88	Startup
5/19/2023	10 PM	24.03	Shutdown
5/22/2025	10 PM	7.11	Shutdown
5/23/2025	8 AM	19.42	Startup
5/23/2025	10 AM	8.30	Shutdown
5/23/2025	1 PM	20.27	Startup

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
5/23/2025	9 PM	15.02	Shutdown
5/24/2025	9 AM	20.67	Startup
5/24/2025	9 PM	15.96	Shutdown
5/25/2025	8 AM	18.54	Startup
5/25/2025	9 PM	24.04	Shutdown
5/26/2025	7 AM	17.25	Startup
5/27/2025	5 PM	21.03	Startup
5/27/2025	10 PM	19.46	Shutdown
5/28/2025	7 PM	23.09	Startup
5/28/2025	11 PM	22.88	Shutdown
5/29/2025	4 PM	18.92	Startup
5/29/2025	10 PM	17.66	Shutdown
5/30/2025	8 AM	13.73	Startup
5/30/2025	10 PM	18.81	Shutdown
5/31/2025	8 AM	18.80	Startup
5/31/2025	10 PM	10.30	Shutdown
6/1/2025	8 AM	18.44	Startup
6/1/2025	11 PM	24.42	Shutdown
6/2/2025	8 AM	15.74	Startup
6/2/2025	11 PM	22.81	Shutdown
6/3/2025	3 PM	12.52	Startup
6/4/2025	1 AM	19.15	Shutdown
6/4/2025	2 PM	9.19	Startup
6/5/2025	11 PM	18.37	Shutdown
6/6/2025	2 PM	17.09	Startup
6/7/2025	1 AM	22.23	Shutdown
6/7/2025	8 AM	15.41	Startup
6/7/2025	10 PM	9.92	Malfunction
6/7/2025	11 PM	22.98	Malfunction
6/8/2025	12 PM	23.25	Malfunction
6/8/2025	4 PM	24.00	Malfunction
6/9/2023	12 AM	20.28	Shutdown
6/9/2023	4 PM	15.28	Startup
6/10/2023	10 PM	19.23	Shutdown
6/11/2023	4 PM	9.66	Startup
6/12/2023	12 AM	24.26	Shutdown
6/12/2023	4 PM	20.22	Startup
6/13/2023	4 PM	14.22	Startup
6/14/2025	12 AM	7.33	Shutdown
6/14/2025	3 PM	6.92	Startup
6/14/2025	11 PM	21.49	Shutdown
6/15/2025	3 PM	14.97	Startup
6/15/2025	5 PM	23.63	Malfunction
6/15/2025	6 PM	24.47	Malfunction

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
6/17/2025	1 AM	10.36	Shutdown
6/20/2025	4 PM	8.80	Shutdown
6/21/2025	3 PM	14.18	Startup
6/22/2025	8 AM	16.68	Startup
6/23/2025	12 AM	9.82	Shutdown
6/23/2025	12 PM	16.79	Startup
6/25/2023	11 PM	15.67	Shutdown
6/26/2023	3 PM	23.21	Startup
6/27/2023	12 AM	14.73	Shutdown
6/27/2023	1 PM	17.10	Startup
6/27/2023	11 PM	18.52	Shutdown
6/29/2023	7 PM	22.98	Startup
6/30/2023	12 AM	9.87	Shutdown
6/30/2023	7 AM	10.81	Startup
6/30/2023	11 PM	13.69	Shutdown

**National Emission Standard for Hazardous Air Pollutants Subpart YYYY
Semi-Annual Report (40 CFR 63.6150)**

Pollutant: Formaldehyde, parts per billion by volume correct to 15% oxygen dry basis (ppbvdC)

Emission Limitation: 91 ppbvdC natural gas and oil firing

Reporting period dates: From July 1, 2023 to December 31, 2023

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-2

Monitor Manufacturer and Model No.: Satec PM130EH Plus

Date of Latest CMS Certification or Audit: N/A

Total source operating time in reporting period¹: 1368

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 86	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 0	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 2	c. Quality assurance calibration – 0 hours
d. Other known causes – 265	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 353	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 25.8%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%

¹ For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.


On a separate page, describe any changes since last quarter in CMS, process or controls.
NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature



Title

Vice President- EEHS & Regulatory

Date

9/5/2025

Excess Emissions

Per agreement with USEPA, an operating load less than 90% is a period of noncompliance. The unit is rated at 27.6 megawatts (MW) and 90% operating load is 24.8 MW. There are no conversion factors from operating load to ppbvdc. Therefore, hours with operating load below 24.8 MW are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
07/02/23	5 PM	19.22	Startup	
07/03/23	4 PM	13.77	Startup	
07/03/23	11 PM	19.86	Shutdown	
07/05/23	3 PM	11.08	Startup	
07/05/23	11 PM	15.35	Shutdown	
07/06/23	3 PM	19.59	Startup	
07/07/23	11 PM	22.23	Shutdown	
07/09/23	5 PM	15.88	Startup	
07/09/23	6 PM	24.74	Reduced Load	89.6%
07/10/23	5 PM	23.56	Startup	
07/12/23	11 PM	19.37	Shutdown	
07/13/23	12 PM	15.09	Startup	
07/14/23	8 AM	8.15	Startup	
07/16/23	2 AM	20.83	Shutdown	
07/16/23	3 PM	15.96	Startup	
07/21/25	4 AM	17.32	Shutdown	
07/21/25	2 PM	11.84	Malfunction	
07/21/25	4 PM	8.54	Malfunction	
07/21/25	9 PM	14.25	Startup	
07/22/25	12 AM	15.10	Shutdown	
07/22/25	4 PM	15.74	Startup	
07/23/25	2 AM	19.38	Shutdown	
07/24/25	2 AM	15.46	Shutdown	
07/24/25	3 PM	22.32	Startup	
07/25/25	1 AM	19.61	Shutdown	
07/25/25	9 AM	9.50	Startup	
07/25/25	11 PM	19.88	Shutdown	
07/26/25	8 AM	13.58	Startup	
07/26/25	11 PM	18.63	Shutdown	
07/27/25	4 PM	8.44	Startup	
07/27/25	9 PM	12.80	Shutdown	
07/28/25	1 PM	13.86	Startup	
07/28/25	11 PM	22.32	Shutdown	
07/29/25	6 PM	11.49	Startup	
07/30/25	12 AM	21.57	Shutdown	
07/31/25	2 PM	8.84	Startup	
07/31/25	9 PM	22.38	Shutdown	

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
08/01/25	3 PM	18.81	Startup	
08/01/25	10 PM	21.12	Shutdown	
08/03/23	10 PM	15.13	Shutdown	
08/04/23	4 PM	17.70	Startup	
08/04/23	10 PM	17.54	Shutdown	
08/05/23	9 AM	24.19	Startup	
08/06/23	10 AM	15.26	Reduced Load	55.3%
08/06/23	11 AM	9.20	Reduced Load	33.3%
08/12/23	1 AM	20.14	Shutdown	
08/12/23	7 PM	18.69	Startup	
08/13/23	1 AM	19.41	Shutdown	
08/15/23	12 PM	7.74	Startup	
08/18/24	4 AM	9.15	Shutdown	
08/18/24	6 AM	17.27	Startup	
08/18/24	11 PM	23.34	Shutdown	
08/19/24	6 PM	8.66	Startup	
08/20/24	3 AM	19.54	Shutdown	
08/21/24	11 AM	18.36	Startup	
08/21/24	9 PM	22.04	Shutdown	
08/22/24	5 PM	7.01	Startup	
08/22/24	8 PM	17.80	Shutdown	
08/23/24	1 PM	12.85	Startup	
08/24/24	1 AM	21.61	Shutdown	
08/24/24	9 AM	21.05	Startup	
08/27/23	6 AM	22.13	Shutdown	
09/02/23	6 AM	18.60	Shutdown	
09/02/23	2 PM	17.62	Startup	
09/03/23	5 AM	17.38	Shutdown	
09/03/23	3 PM	8.76	Startup	
09/05/23	11 AM	12.57	Shutdown	
09/05/23	2 PM	7.66	Startup	
09/06/23	5 AM	18.54	Shutdown	
09/08/23	7 AM	17.08	Reduced Load	61.9%
09/08/23	8 AM	19.98	Reduced Load	72.4%
09/08/23	11 PM	17.44	Shutdown	
09/13/23	6 PM	18.59	Startup	
09/13/23	8 PM	21.15	Shutdown	
09/14/23	1 PM	17.37	Startup	
09/14/23	6 PM	12.78	Reduced Load	46.3%
09/15/23	2 PM	20.04	Startup	
09/15/23	3 PM	21.81	Reduced Load	79.0%
09/15/23	4 PM	23.44	Reduced Load	84.9%
09/15/23	5 PM	23.99	Reduced Load	86.9%
09/15/23	6 PM	23.99	Reduced Load	86.9%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
09/15/23	7 PM	23.99	Reduced Load	86.9%
09/15/23	8 PM	23.99	Reduced Load	86.9%
09/15/23	9 PM	23.98	Reduced Load	86.9%
09/15/23	10 PM	23.99	Reduced Load	86.9%
09/15/23	11 PM	23.99	Reduced Load	86.9%
09/16/23	12 AM	23.98	Reduced Load	86.9%
09/16/23	1 AM	23.99	Reduced Load	86.9%
09/16/23	2 AM	23.97	Reduced Load	86.9%
09/16/23	3 AM	23.99	Reduced Load	86.9%
09/16/23	4 AM	23.93	Reduced Load	86.7%
09/16/23	5 AM	23.94	Reduced Load	86.7%
09/16/23	6 AM	23.98	Reduced Load	86.9%
09/16/23	7 AM	23.98	Reduced Load	86.9%
09/16/23	8 AM	23.99	Reduced Load	86.9%
09/16/23	9 AM	23.98	Reduced Load	86.9%
09/16/23	10 AM	23.98	Reduced Load	86.9%
09/16/23	11 AM	23.98	Reduced Load	86.9%
09/16/23	12 PM	12.35	Shutdown	
09/16/23	4 PM	16.35	Startup	
09/16/23	5 PM	23.99	Reduced Load	86.9%
09/16/23	6 PM	23.99	Reduced Load	86.9%
09/16/23	7 PM	23.99	Reduced Load	86.9%
09/16/23	8 PM	23.99	Reduced Load	86.9%
09/16/23	9 PM	23.99	Reduced Load	86.9%
09/16/23	10 PM	23.99	Reduced Load	86.9%
09/16/23	11 PM	23.99	Reduced Load	86.9%
09/17/23	12 AM	23.99	Reduced Load	86.9%
09/17/23	1 AM	23.94	Reduced Load	86.8%
09/17/23	2 AM	23.98	Reduced Load	86.9%
09/17/23	3 AM	23.99	Reduced Load	86.9%
09/17/23	4 AM	23.94	Reduced Load	86.7%
09/17/23	5 AM	7.11	Shutdown	
09/17/23	3 PM	14.54	Startup	
09/17/23	4 PM	23.97	Reduced Load	86.9%
09/17/23	5 PM	23.95	Reduced Load	86.8%
09/17/23	6 PM	23.98	Reduced Load	86.9%
09/17/23	7 PM	23.98	Reduced Load	86.9%
09/17/23	8 PM	23.99	Reduced Load	86.9%
09/17/23	9 PM	24.00	Reduced Load	87.0%
09/17/23	10 PM	23.97	Reduced Load	86.8%
09/17/23	11 PM	23.98	Reduced Load	86.9%
09/18/23	12 AM	23.96	Reduced Load	86.8%
09/18/23	1 AM	23.98	Reduced Load	86.9%
09/18/23	2 AM	23.99	Reduced Load	86.9%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
09/18/23	3 AM	23.95	Reduced Load	86.8%
09/18/23	4 AM	23.99	Reduced Load	86.9%
09/18/23	5 AM	23.99	Reduced Load	86.9%
09/18/23	6 AM	23.97	Reduced Load	86.9%
09/18/23	7 AM	23.98	Reduced Load	86.9%
09/18/23	8 AM	23.98	Reduced Load	86.9%
09/18/23	9 AM	23.98	Reduced Load	86.9%
09/18/23	10 AM	23.98	Reduced Load	86.9%
09/18/23	11 AM	23.98	Reduced Load	86.9%
09/18/23	12 PM	23.98	Reduced Load	86.9%
09/18/23	1 PM	23.99	Reduced Load	86.9%
09/18/23	2 PM	23.99	Reduced Load	86.9%
09/18/23	3 PM	23.96	Reduced Load	86.8%
09/18/23	4 PM	23.99	Reduced Load	86.9%
09/18/23	5 PM	24.00	Reduced Load	86.9%
09/18/23	6 PM	23.98	Reduced Load	86.9%
09/18/23	7 PM	23.99	Reduced Load	86.9%
09/18/23	8 PM	23.98	Reduced Load	86.9%
09/18/23	9 PM	23.98	Reduced Load	86.9%
09/18/23	10 PM	24.00	Reduced Load	86.9%
09/18/23	11 PM	23.99	Reduced Load	86.9%
09/19/23	12 AM	23.98	Reduced Load	86.9%
09/19/23	1 AM	23.98	Reduced Load	86.9%
09/19/23	2 AM	23.99	Reduced Load	86.9%
09/19/23	3 AM	23.99	Reduced Load	86.9%
09/19/23	4 AM	24.00	Reduced Load	86.9%
09/19/23	5 AM	23.98	Reduced Load	86.9%
09/19/23	6 AM	23.93	Reduced Load	86.7%
09/19/23	7 AM	23.96	Reduced Load	86.8%
09/19/23	8 AM	23.98	Reduced Load	86.9%
09/19/23	9 AM	23.97	Reduced Load	86.8%
09/19/23	10 AM	23.98	Reduced Load	86.9%
09/19/23	11 AM	23.97	Reduced Load	86.9%
09/19/23	12 PM	23.98	Reduced Load	86.9%
09/19/23	1 PM	23.99	Reduced Load	86.9%
09/19/23	2 PM	23.99	Reduced Load	86.9%
09/19/23	3 PM	23.99	Reduced Load	86.9%
09/19/23	4 PM	23.99	Reduced Load	86.9%
09/19/23	5 PM	23.99	Reduced Load	86.9%
09/19/23	6 PM	23.98	Reduced Load	86.9%
09/19/23	7 PM	23.99	Reduced Load	86.9%
09/19/23	8 PM	23.99	Reduced Load	86.9%
09/19/23	9 PM	24.00	Reduced Load	86.9%
09/19/23	10 PM	23.96	Reduced Load	86.8%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
09/19/23	11 PM	23.98	Reduced Load	86.9%
09/20/23	12 AM	23.95	Reduced Load	86.8%
09/20/23	1 AM	23.90	Reduced Load	86.6%
09/20/23	2 AM	23.97	Reduced Load	86.8%
09/20/23	3 AM	23.94	Reduced Load	86.7%
09/20/23	4 AM	23.99	Reduced Load	86.9%
09/20/23	5 AM	23.97	Reduced Load	86.8%
09/20/23	6 AM	23.92	Reduced Load	86.7%
09/20/23	7 AM	23.97	Reduced Load	86.8%
09/20/23	8 AM	23.96	Reduced Load	86.8%
09/20/23	9 AM	23.87	Reduced Load	86.5%
09/20/23	10 AM	23.86	Reduced Load	86.5%
09/20/23	11 AM	22.01	Reduced Load	79.8%
09/20/23	12 PM	23.98	Reduced Load	86.9%
09/20/23	1 PM	23.97	Reduced Load	86.9%
09/20/23	2 PM	23.97	Reduced Load	86.8%
09/20/23	3 PM	23.97	Reduced Load	86.8%
09/20/23	4 PM	23.98	Reduced Load	86.9%
09/20/23	5 PM	23.98	Reduced Load	86.9%
09/20/23	6 PM	23.98	Reduced Load	86.9%
09/20/23	7 PM	23.99	Reduced Load	86.9%
09/20/23	8 PM	23.56	Reduced Load	85.4%
09/20/23	9 PM	23.97	Reduced Load	86.8%
09/20/23	10 PM	24.00	Reduced Load	86.9%
09/21/23	11 PM	23.99	Reduced Load	86.9%
09/21/23	12 AM	24.00	Reduced Load	86.9%
09/21/23	1 AM	24.00	Reduced Load	86.9%
09/21/23	2 AM	23.99	Reduced Load	86.9%
09/21/23	3 AM	23.99	Reduced Load	86.9%
09/21/23	4 AM	23.99	Reduced Load	86.9%
09/21/23	5 AM	23.98	Reduced Load	86.9%
09/21/23	6 AM	23.93	Reduced Load	86.7%
09/21/23	7 AM	23.98	Reduced Load	86.9%
09/21/23	8 AM	23.98	Reduced Load	86.9%
09/21/23	9 AM	23.98	Reduced Load	86.9%
09/21/23	10 AM	23.97	Reduced Load	86.9%
09/21/23	11 AM	23.99	Reduced Load	86.9%
09/21/23	12 PM	23.97	Reduced Load	86.9%
09/21/23	1 PM	23.99	Reduced Load	86.9%
09/21/23	2 PM	23.98	Reduced Load	86.9%
09/21/23	3 PM	23.75	Reduced Load	86.1%
09/21/23	4 PM	23.71	Reduced Load	85.9%
09/21/23	5 PM	23.98	Reduced Load	86.9%
09/21/23	6 PM	23.86	Reduced Load	86.4%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
09/21/23	7 PM	23.94	Reduced Load	86.7%
09/21/23	8 PM	23.97	Reduced Load	86.8%
09/21/23	9 PM	23.98	Reduced Load	86.9%
09/21/23	10 PM	23.98	Reduced Load	86.9%
09/21/23	11 PM	23.99	Reduced Load	86.9%
09/22/23	12 AM	23.98	Reduced Load	86.9%
09/22/23	1 AM	23.96	Reduced Load	86.8%
09/22/23	2 AM	23.94	Reduced Load	86.7%
09/22/23	3 AM	23.98	Reduced Load	86.9%
09/22/23	4 AM	23.98	Reduced Load	86.9%
09/22/23	5 AM	23.94	Reduced Load	86.8%
09/22/23	6 AM	23.99	Reduced Load	86.9%
09/22/23	7 AM	23.99	Reduced Load	86.9%
09/22/23	8 AM	23.99	Reduced Load	86.9%
09/22/23	9 AM	23.99	Reduced Load	86.9%
09/22/23	10 AM	23.99	Reduced Load	86.9%
09/22/23	11 AM	23.99	Reduced Load	86.9%
09/22/23	12 PM	23.96	Reduced Load	86.8%
09/22/23	1 PM	23.94	Reduced Load	86.7%
09/22/23	2 PM	23.95	Reduced Load	86.8%
09/22/23	3 PM	23.95	Reduced Load	86.8%
09/22/23	4 PM	23.98	Reduced Load	86.9%
09/22/23	5 PM	23.94	Reduced Load	86.7%
09/22/23	6 PM	23.98	Reduced Load	86.9%
09/22/23	7 PM	23.99	Reduced Load	86.9%
09/22/23	8 PM	23.97	Reduced Load	86.9%
09/22/23	9 PM	23.99	Reduced Load	86.9%
09/22/23	10 PM	23.99	Reduced Load	86.9%
09/22/23	11 PM	23.99	Reduced Load	86.9%
09/23/23	12 AM	23.97	Reduced Load	86.9%
09/23/23	1 AM	23.99	Reduced Load	86.9%
09/23/23	2 AM	24.00	Reduced Load	86.9%
09/23/23	3 AM	23.99	Reduced Load	86.9%
09/23/23	4 AM	23.99	Reduced Load	86.9%
09/23/23	5 AM	23.99	Reduced Load	86.9%
09/23/23	6 AM	23.99	Reduced Load	86.9%
09/23/23	7 AM	23.97	Reduced Load	86.8%
09/23/23	8 AM	23.99	Reduced Load	86.9%
09/23/23	9 AM	23.94	Reduced Load	86.8%
09/23/23	10 AM	23.96	Reduced Load	86.8%
09/23/23	11 AM	23.95	Reduced Load	86.8%
09/23/23	12 PM	19.79	Reduced Load	71.7%
09/23/23	1 PM	15.22	Reduced Load	55.1%
09/23/23	2 PM	13.61	Reduced Load	49.3%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
09/23/23	3 PM	13.02	Reduced Load	47.2%
09/23/23	4 PM	15.04	Reduced Load	54.5%
09/23/23	5 PM	22.27	Reduced Load	80.7%
09/23/23	6 PM	21.96	Reduced Load	79.6%
09/23/23	7 PM	21.98	Reduced Load	79.6%
09/23/23	8 PM	22.00	Reduced Load	79.7%
09/23/23	9 PM	21.98	Reduced Load	79.6%
09/23/23	10 PM	21.98	Reduced Load	79.6%
09/23/23	11 PM	21.98	Reduced Load	79.7%
09/24/23	12 AM	21.99	Reduced Load	79.7%
09/24/23	1 AM	22.00	Reduced Load	79.7%
09/24/23	2 AM	21.94	Reduced Load	79.5%
09/24/23	3 AM	21.97	Reduced Load	79.6%
09/24/23	4 AM	21.98	Reduced Load	79.6%
09/24/23	5 AM	21.99	Reduced Load	79.7%
09/24/23	6 AM	21.95	Reduced Load	79.5%
09/24/23	7 AM	21.87	Reduced Load	79.2%
09/24/23	8 AM	20.32	Shutdown	
09/24/23	4 PM	13.58	Startup	
09/24/23	5 PM	21.99	Reduced Load	79.7%
09/24/23	6 PM	21.99	Reduced Load	79.7%
09/24/23	7 PM	22.00	Reduced Load	79.7%
09/24/23	8 PM	22.00	Reduced Load	79.7%
09/24/23	9 PM	22.00	Reduced Load	79.7%
09/24/23	10 PM	21.99	Reduced Load	79.7%
09/24/23	11 PM	21.99	Reduced Load	79.7%
09/25/23	12 AM	21.99	Reduced Load	79.7%
09/25/23	1 AM	21.97	Reduced Load	79.6%
09/25/23	2 AM	21.98	Reduced Load	79.6%
09/25/23	3 AM	21.98	Reduced Load	79.6%
09/25/23	4 AM	22.00	Reduced Load	79.7%
09/25/23	5 AM	22.00	Reduced Load	79.7%
09/25/23	6 AM	21.99	Reduced Load	79.7%
09/25/23	7 AM	22.00	Reduced Load	79.7%
09/25/23	8 AM	21.99	Reduced Load	79.7%
09/25/23	9 AM	21.99	Reduced Load	79.7%
09/25/23	10 AM	21.98	Reduced Load	79.6%
09/25/23	11 AM	21.98	Reduced Load	79.6%
09/25/23	12 PM	21.98	Reduced Load	79.6%
09/25/23	1 PM	21.84	Reduced Load	79.1%
09/25/23	2 PM	21.97	Reduced Load	79.6%
09/25/23	3 PM	21.96	Reduced Load	79.6%
09/25/23	4 PM	21.96	Reduced Load	79.6%
09/25/23	5 PM	21.99	Reduced Load	79.7%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
09/25/23	6 PM	21.98	Reduced Load	79.7%
09/25/23	7 PM	21.96	Reduced Load	79.6%
09/25/23	8 PM	21.99	Reduced Load	79.7%
09/25/23	9 PM	21.98	Reduced Load	79.6%
09/25/23	10 PM	21.96	Reduced Load	79.6%
09/25/23	11 PM	21.97	Reduced Load	79.6%
09/26/23	12 AM	21.98	Reduced Load	79.6%
09/26/23	1 AM	21.38	Shutdown	
09/26/23	3 PM	8.44	Startup	
09/26/23	4 PM	21.96	Reduced Load	79.6%
09/26/23	5 PM	21.97	Reduced Load	79.6%
09/26/23	6 PM	21.98	Reduced Load	79.6%
09/26/23	7 PM	21.99	Reduced Load	79.7%
09/26/23	8 PM	21.98	Reduced Load	79.7%
09/26/23	9 PM	21.98	Reduced Load	79.6%
09/26/23	10 PM	21.97	Reduced Load	79.6%
09/26/23	11 PM	21.98	Reduced Load	79.7%
09/27/23	12 AM	21.99	Reduced Load	79.7%
09/27/23	1 AM	15.15	Shutdown	
09/27/23	2 PM	17.51	Startup	
09/27/23	3 PM	21.97	Reduced Load	79.6%
09/27/23	4 PM	22.00	Reduced Load	79.7%
09/27/23	5 PM	21.94	Reduced Load	79.5%
09/27/23	6 PM	21.98	Reduced Load	79.6%
09/27/23	7 PM	22.00	Reduced Load	79.7%
09/27/23	8 PM	22.00	Reduced Load	79.7%
09/27/23	9 PM	21.98	Reduced Load	79.7%
09/27/23	10 PM	21.99	Reduced Load	79.7%
09/27/23	11 PM	21.98	Reduced Load	79.7%
09/28/23	12 AM	21.95	Reduced Load	79.5%
09/28/23	1 AM	21.95	Reduced Load	79.5%
09/28/23	2 AM	13.04	Shutdown	
09/28/23	3 PM	15.42	Startup	
09/28/23	4 PM	21.99	Reduced Load	79.7%
09/28/23	5 PM	22.00	Reduced Load	79.7%
09/28/23	6 PM	21.99	Reduced Load	79.7%
09/28/23	7 PM	22.00	Reduced Load	79.7%
09/28/23	8 PM	22.00	Reduced Load	79.7%
09/28/23	9 PM	21.99	Reduced Load	79.7%
09/28/23	10 PM	22.00	Reduced Load	79.7%
09/28/23	11 PM	21.99	Reduced Load	79.7%
09/29/23	12 AM	21.99	Reduced Load	79.7%
09/29/23	1 AM	21.99	Reduced Load	79.7%
09/29/23	2 AM	14.86	Shutdown	

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
10/02/23	8 PM	14.40	Startup	
10/02/23	9 PM	21.94	Reduced Load	79.5%
10/02/23	10 PM	21.99	Reduced Load	79.7%
10/02/23	11 PM	12.00	Shutdown	
12/07/23	1 PM	19.60	Startup	
12/07/23	2 PM	16.66	Reduced Load	60.4%
12/07/23	3 PM	19.80	Reduced Load	71.7%
12/07/23	9 PM	10.28	Shutdown	

**National Emission Standard for Hazardous Air Pollutants Subpart YYYY
Semi-Annual Report (40 CFR 63.6150)**

Pollutant: Formaldehyde, parts per billion by volume correct to 15% oxygen dry basis (ppbvdc)

Emission Limitation: 91 ppbvdc natural gas and oil firing

Reporting period dates: From January 1, 2024 to June 30, 2024

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-2

Monitor Manufacturer and Model No.: Satec PM130EH Plus

Date of Latest CMS Certification or Audit: N/A

Total source operating time in reporting period¹: 285

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 84	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 0	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 0	c. Quality assurance calibration – 0 hours
d. Other known causes – 32	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 116	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 40.7%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%

¹ For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.


On a separate page, describe any changes since last quarter in CMS, process or controls.
NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature



Title

Vice President- EEHS & Regulatory

Date

9/5/2025

Excess Emissions

Per agreement with USEPA, an operating load less than 90% is a period of noncompliance. The unit is rated at 27.6 megawatts (MW) and 90% operating load is 24.8 MW. There are no conversion factors from operating load to ppbvdc. Therefore, hours with operating load below 24.8 MW are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
01/11/24	6 PM	13.33	Startup	
01/11/24	9 PM	16.22	Shutdown	
01/18/24	10 PM	14.45	Shutdown	
03/30/24	9 PM	17.63	Startup	
03/30/24	10 PM	20.09	Reduced Load	72.8%
03/30/24	11 PM	20.20	Reduced Load	73.2%
03/31/24	12 AM	19.99	Reduced Load	72.4%
03/31/24	1 AM	18.13	Shutdown	
04/02/24	7 PM	19.60	Startup	
04/02/24	8 PM	19.98	Reduced Load	72.4%
04/02/24	9 PM	19.97	Reduced Load	72.3%
04/02/24	10 PM	19.95	Reduced Load	72.3%
04/02/24	11 PM	12.60	Shutdown	
04/05/24	2 PM	15.01	Startup	
04/05/24	3 PM	19.96	Reduced Load	72.3%
04/05/24	4 PM	19.98	Reduced Load	72.4%
04/05/24	5 PM	19.98	Reduced Load	72.4%
04/05/24	6 PM	19.94	Reduced Load	72.2%
04/05/24	7 PM	19.91	Reduced Load	72.1%
04/05/24	8 PM	18.56	Shutdown	
04/06/24	5 PM	11.11	Startup	
04/06/24	6 PM	19.98	Reduced Load	72.4%
04/06/24	7 PM	20.74	Reduced Load	75.2%
04/06/24	8 PM	22.99	Reduced Load	83.3%
04/06/24	9 PM	22.99	Reduced Load	83.3%
04/06/24	10 PM	19.38	Shutdown	
04/07/24	6 PM	14.75	Startup	
04/07/24	7 PM	22.98	Reduced Load	83.3%
04/07/24	8 PM	22.99	Reduced Load	83.3%
04/07/24	9 PM	23.00	Reduced Load	83.3%
04/07/24	10 PM	23.00	Reduced Load	83.3%
04/07/24	11 PM	10.91	Shutdown	
04/20/24	7 PM	22.07	Startup	
04/20/24	11 PM	22.35	Shutdown	
04/21/24	7 PM	18.66	Startup	
04/21/24	11 PM	13.32	Shutdown	
04/22/24	5 PM	9.03	Startup	
04/22/24	10 PM	22.12	Shutdown	
04/25/24	7 PM	17.54	Startup	

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
04/25/24	9 PM	17.73	Shutdown	
04/29/24	11 PM	23.79	Startup	
04/30/24	12 AM	14.13	Shutdown	
04/30/24	5 PM	17.10	Startup	
04/30/24	11 PM	14.10	Shutdown	
05/01/24	3 PM	16.11	Startup	
05/01/24	7 PM	24.52	Reduced Load	88.8%
05/01/24	11 PM	7.31	Shutdown	
05/02/24	2 PM	16.89	Startup	
05/02/24	4 PM	24.56	Reduced Load	89.0%
05/02/24	11 PM	23.20	Shutdown	
05/03/24	11 AM	13.71	Startup	
05/03/24	8 PM	21.33	Shutdown	
05/04/24	6 PM	20.59	Startup	
05/04/24	9 PM	11.83	Shutdown	
05/11/24	4 PM	24.58	Startup	
05/11/24	8 PM	19.22	Shutdown	
05/13/24	6 PM	12.60	Startup	
05/13/24	10 PM	17.80	Shutdown	
05/14/24	8 PM	23.76	Startup	
05/14/24	11 PM	7.54	Shutdown	
05/15/24	5 PM	22.23	Startup	
05/15/24	10 PM	15.16	Shutdown	
05/20/24	7 PM	17.43	Startup	
05/20/24	9 PM	23.92	Shutdown	
05/21/24	3 PM	17.37	Startup	
05/21/24	9 PM	15.25	Shutdown	
05/23/24	5 PM	21.26	Startup	
05/23/24	11 PM	9.62	Shutdown	
05/24/24	8 AM	17.65	Startup	
05/24/24	8 PM	24.74	Shutdown	
05/25/24	6 PM	16.46	Startup	
05/26/24	5 PM	21.38	Startup	
05/28/24	6 PM	15.07	Startup	
05/28/24	10 PM	23.32	Shutdown	
05/29/24	8 PM	19.25	Startup	
05/29/24	11 PM	19.26	Shutdown	
05/30/24	7 AM	13.70	Startup	
05/30/24	11 PM	15.47	Shutdown	
05/31/24	6 PM	19.71	Startup	
06/01/24	7 PM	16.54	Startup	
06/01/24	10 PM	14.69	Shutdown	
06/04/24	6 PM	9.59	Startup	
06/04/24	10 PM	18.75	Shutdown	
06/05/24	12 PM	20.38	Startup	

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
06/05/24	11 PM	13.63	Shutdown	
06/06/24	5 PM	16.71	Startup	
06/06/24	10 PM	10.99	Shutdown	
06/08/24	2 PM	17.24	Startup	
06/08/24	11 PM	24.07	Reduced Load	87.2%
06/09/24	12 AM	8.74	Shutdown	
06/09/24	2 PM	20.30	Startup	
06/10/24	12 AM	24.48	Shutdown	
06/10/24	12 PM	19.57	Startup	
06/10/24	3 PM	20.35	Reduced Load	73.7%
06/10/24	4 PM	19.64	Reduced Load	71.2%
06/10/24	5 PM	20.00	Reduced Load	72.5%
06/10/24	6 PM	19.99	Reduced Load	72.4%
06/10/24	7 PM	21.31	Reduced Load	77.2%
06/10/24	8 PM	22.07	Reduced Load	80.0%
06/10/24	9 PM	22.00	Reduced Load	79.7%
06/10/24	10 PM	22.00	Reduced Load	79.7%
06/10/24	11 PM	21.99	Reduced Load	79.7%
06/11/24	12 AM	13.41	Shutdown	
06/11/24	4 PM	8.99	Startup	
06/11/24	5 PM	22.24	Reduced Load	80.6%
06/11/24	9 PM	23.39	Shutdown	
06/12/24	4 PM	23.68	Startup	
06/12/24	8 PM	23.42	Shutdown	
06/14/23	4 PM	10.98	Startup	
06/14/23	8 PM	17.33	Shutdown	
06/18/24	6 PM	23.29	Startup	
06/18/24	10 PM	18.61	Shutdown	
06/19/25	7 PM	24.43	Startup	
06/19/25	10 PM	14.82	Shutdown	
06/25/25	11 PM	16.09	Startup	
06/25/25	1 AM	10.72	Shutdown	

**National Emission Standard for Hazardous Air Pollutants Subpart YYYY
Semi-Annual Report (40 CFR 63.6150)**

Pollutant: Formaldehyde, parts per billion by volume correct to 15% oxygen dry basis (ppbvdc)

Emission Limitation: 91 ppbvdc natural gas and oil firing

Reporting period dates: From July 1, 2024 to December 31, 2024

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-2

Monitor Manufacturer and Model No.: Satec PM130EH Plus

Date of Latest CMS Certification or Audit: N/A

Total source operating time in reporting period¹: 826

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 245	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 0	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 3	c. Quality assurance calibration – 0 hours
d. Other known causes – 27	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 275	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 33.2%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%

¹ For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.


On a separate page, describe any changes since last quarter in CMS, process or controls.
NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature



Title

Vice President- EEHS & Regulatory

Date

9/5/2025

Excess Emissions

Per agreement with USEPA, an operating load less than 90% is a period of noncompliance. The unit is rated at 27.6 megawatts (MW) and 90% operating load is 24.8 MW. There are no conversion factors from operating load to ppbvdc. Therefore, hours with operating load below 24.8 MW are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
07/06/24	7 PM	23.34	Startup	
07/06/24	10 PM	20.93	Shutdown	
07/07/24	6 PM	18.65	Startup	
07/07/24	11 PM	15.56	Shutdown	
07/11/24	5 PM	15.19	Startup	
07/11/24	10 PM	19.36	Shutdown	
07/12/24	5 PM	19.87	Startup	
07/12/24	10 PM	23.57	Shutdown	
07/17/24	6 PM	16.61	Startup	
07/17/24	11 PM	16.48	Shutdown	
07/18/24	7 PM	16.30	Startup	
07/18/24	11 PM	19.96	Shutdown	
07/24/24	9 AM	11.30	Startup	
08/01/24	7 AM	7.12	Startup	
08/01/24	10 AM	13.12	Shutdown	
08/01/24	9 PM	22.35	Shutdown	
08/05/24	6 PM	16.28	Startup	
08/05/24	11 PM	16.54	Shutdown	
08/06/24	9 PM	13.09	Shutdown	
08/07/24	6 PM	7.58	Startup	
08/09/24	2 AM	16.17	Shutdown	
08/10/24	1 AM	23.11	Shutdown	
08/13/24	9 AM	11.69	Startup	
08/14/24	12 AM	8.71	Shutdown	
08/15/24	5 PM	16.76	Startup	
08/16/24	2 AM	14.22	Shutdown	
08/16/24	4 PM	10.28	Startup	
08/16/24	6 PM	23.85	Reduced Load	86.4%
08/17/24	1 AM	23.84	Shutdown	
08/17/24	2 PM	23.81	Startup	
08/18/24	6 PM	17.79	Startup	
08/18/24	11 PM	16.30	Shutdown	
08/19/24	3 PM	18.46	Startup	
08/19/24	6 PM	24.69	Shutdown	
08/20/24	12 PM	24.79	Startup	
08/20/24	7 PM	24.78	Reduced Load	89.8%
08/21/24	12 AM	23.03	Shutdown	
08/21/24	3 PM	20.57	Startup	
08/21/24	10 PM	21.53	Shutdown	
08/22/24	3 PM	14.51	Startup	

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
08/22/24	4 PM	24.78	Reduced Load	89.8%
08/23/24	8 PM	24.78	Reduced Load	89.8%
08/23/24	9 PM	24.71	Reduced Load	89.5%
08/24/24	3 AM	16.17	Shutdown	
08/24/24	4 PM	11.24	Startup	
08/24/24	6 PM	24.73	Reduced Load	89.6%
08/24/24	7 PM	24.79	Reduced Load	89.8%
08/25/24	2 AM	23.12	Reduced Load	83.8%
08/25/24	4 AM	19.42	Shutdown	
08/25/24	4 PM	13.44	Startup	
08/26/24	12 AM	19.26	Shutdown	
08/26/24	3 PM	16.06	Startup	
08/27/24	5 PM	21.42	Startup	
08/27/24	11 PM	14.85	Shutdown	
08/28/24	5 PM	17.62	Startup	
08/29/24	1 AM	12.11	Shutdown	
08/29/24	5 PM	9.44	Startup	
08/30/24	12 AM	15.20	Shutdown	
08/30/24	7 PM	10.40	Startup	
08/30/24	10 PM	12.37	Shutdown	
08/31/24	7 PM	16.33	Startup	
08/31/24	10 PM	15.87	Shutdown	
09/01/24	7 PM	22.87	Startup	
09/01/24	10 PM	23.16	Shutdown	
09/02/24	5 PM	21.66	Startup	
09/02/24	11 PM	22.69	Shutdown	
09/03/24	3 PM	9.38	Startup	
09/04/24	7 AM	22.15	Shutdown	
09/04/24	4 PM	24.28	Startup	
09/05/24	1 AM	16.18	Shutdown	
09/05/24	2 PM	9.78	Startup	
09/06/24	12 AM	21.09	Shutdown	
09/06/24	1 PM	14.48	Startup	
09/07/24	4 AM	17.18	Shutdown	
09/07/24	2 PM	23.36	Startup	
09/10/24	2 PM	20.11	Startup	
09/11/24	12 AM	19.49	Shutdown	
09/11/24	10 AM	20.43	Startup	
09/12/24	6 AM	22.12	Shutdown	
09/12/24	7 PM	17.65	Startup	
09/12/24	8 PM	20.01	Reduced Load	72.5%
09/12/24	9 PM	20.02	Reduced Load	72.5%
09/12/24	10 PM	20.00	Reduced Load	72.5%
09/12/24	11 PM	14.43	Shutdown	
09/13/24	2 PM	10.32	Startup	
09/13/24	3 PM	19.91	Reduced Load	72.1%
09/13/24	4 PM	19.96	Reduced Load	72.3%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
09/13/24	5 PM	20.02	Reduced Load	72.5%
09/14/24	4 PM	17.60	Startup	
09/14/24	11 PM	11.79	Shutdown	
09/15/24	4 PM	15.34	Startup	
09/15/24	11 PM	19.88	Shutdown	
09/16/24	4 PM	15.36	Startup	
09/16/24	11 PM	9.92	Shutdown	
09/17/24	5 PM	14.58	Startup	
09/17/24	10 PM	20.34	Shutdown	
09/18/24	3 PM	8.63	Startup	
09/18/24	9 PM	16.05	Shutdown	
09/19/24	6 PM	8.21	Startup	
09/20/24	4 PM	19.14	Startup	
09/20/24	8 PM	23.45	Shutdown	
09/21/24	5 PM	16.83	Startup	
09/21/24	11 PM	23.59	Shutdown	
09/23/24	11 PM	8.17	Shutdown	
09/24/24	3 PM	17.80	Startup	
09/25/24	6 PM	18.05	Startup	
09/25/24	11 PM	9.25	Shutdown	
09/26/24	6 PM	15.77	Startup	
09/26/24	10 PM	20.14	Shutdown	
09/30/24	6 PM	12.71	Startup	
09/30/24	11 PM	9.45	Shutdown	
10/01/24	11 PM	22.55	Shutdown	
10/02/24	4 PM	22.45	Startup	
10/03/24	12 AM	13.31	Shutdown	
10/03/24	4 PM	20.70	Startup	
10/04/24	1 AM	20.22	Shutdown	
10/05/24	3 PM	13.80	Startup	
10/05/24	10 PM	16.30	Shutdown	
10/07/24	6 PM	13.60	Startup	
10/08/24	3 PM	12.87	Startup	
10/08/24	11 PM	14.08	Shutdown	
10/09/24	1 PM	7.04	Startup	
10/10/24	2 AM	22.10	Shutdown	
10/11/24	1 AM	24.23	Shutdown	
10/11/24	2 PM	9.09	Startup	
10/12/24	2 AM	15.93	Shutdown	
10/12/24	4 PM	10.73	Startup	
10/13/24	12 AM	13.26	Shutdown	
10/13/24	3 PM	16.11	Startup	
10/14/24	4 PM	24.21	Startup	
10/14/24	11 PM	8.03	Shutdown	
10/15/24	2 PM	24.52	Startup	
10/15/24	10 PM	18.83	Shutdown	
10/18/24	7 PM	17.96	Startup	

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
10/20/24	3 PM	11.05	Startup	
10/21/24	1 AM	20.87	Shutdown	
10/21/24	3 PM	11.27	Startup	
10/21/24	6 PM	23.47	Reduced Load	85.0%
10/21/24	10 PM	20.99	Shutdown	
10/22/24	2 PM	15.06	Startup	
10/22/24	9 PM	18.98	Shutdown	
10/23/24	3 PM	12.96	Startup	
10/23/24	9 PM	23.95	Shutdown	
10/30/24	2 PM	8.18	Startup	
10/30/24	10 PM	18.42	Shutdown	
11/04/24	4 PM	10.87	Startup	
11/04/24	5 PM	19.99	Reduced Load	72.4%
11/04/24	6 PM	19.97	Reduced Load	72.3%
11/04/24	7 PM	19.98	Reduced Load	72.4%
11/04/24	8 PM	19.95	Reduced Load	72.3%
11/04/24	9 PM	19.94	Reduced Load	72.3%
11/04/24	10 PM	13.87	Shutdown	
11/14/24	12 AM	21.77	Shutdown	
11/14/24	3 PM	9.22	Startup	
11/14/24	4 PM	20.00	Reduced Load	72.5%
11/14/24	5 PM	20.00	Reduced Load	72.4%
11/14/24	6 PM	20.00	Reduced Load	72.5%
11/14/24	7 PM	20.00	Reduced Load	72.5%
11/14/24	8 PM	20.00	Reduced Load	72.5%
11/14/24	9 PM	15.66	Shutdown	
11/18/24	5 PM	20.15	Startup	
11/18/24	8 PM	10.89	Shutdown	
11/19/24	5 PM	15.81	Startup	
11/19/24	10 PM	17.42	Shutdown	
11/20/24	4 PM	23.63	Startup	
11/20/24	6 PM	8.51	Malfunction	
11/20/24	7 PM	13.54	Malfunction	
11/20/24	10 PM	24.48	Shutdown	
11/21/24	4 PM	16.91	Startup	
11/21/24	10 PM	18.60	Shutdown	
11/22/24	5 PM	14.18	Startup	
11/23/24	12 AM	24.71	Shutdown	
11/23/24	5 PM	23.33	Startup	
11/23/24	11 PM	20.84	Shutdown	
11/29/24	5 PM	15.95	Startup	
11/29/24	9 PM	18.67	Shutdown	
11/30/24	7 PM	14.03	Startup	
11/30/24	9 PM	19.12	Shutdown	
12/02/24	3 PM	6.98	Startup	
12/02/24	9 PM	15.95	Shutdown	
12/04/24	6 PM	19.82	Startup	

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
12/05/24	4 PM	13.43	Startup	
12/06/24	2 AM	16.21	Shutdown	
12/06/24	4 PM	10.76	Startup	
12/08/24	6 PM	15.23	Startup	
12/09/24	6 PM	21.59	Startup	
12/09/24	10 PM	11.91	Shutdown	
12/10/24	8 AM	21.44	Startup	
12/10/24	9 AM	18.41	Shutdown	
12/12/24	4 PM	11.41	Startup	
12/12/24	11 PM	21.96	Shutdown	
12/13/24	4 PM	12.75	Startup	
12/15/24	6 PM	24.14	Startup	
12/15/24	10 PM	19.14	Shutdown	
12/16/24	2 PM	10.14	Startup	
12/16/24	9 PM	21.85	Shutdown	
12/17/24	6 PM	18.21	Startup	
12/17/24	11 PM	13.97	Shutdown	
12/18/24	1 PM	20.73	Startup	
12/19/24	9 AM	7.97	Malfunction	
12/19/24	1 PM	14.16	Startup	
12/19/24	2 PM	19.95	Reduced Load	72.3%
12/19/24	3 PM	20.62	Reduced Load	74.7%
12/19/24	8 PM	18.90	Shutdown	
12/23/24	6 PM	11.63	Startup	
12/23/24	8 PM	17.10	Shutdown	
12/31/24	5 PM	15.64	Startup	
12/31/24	9 PM	24.76	Shutdown	

**National Emission Standard for Hazardous Air Pollutants Subpart YYYY
Semi-Annual Report (40 CFR 63.6150)**

Pollutant: Formaldehyde, parts per billion by volume correct to 15% oxygen dry basis (ppbvdc)

Emission Limitation: 91 ppbvdc natural gas and oil firing

Reporting period dates: From January 1, 2023 to June 30, 2023

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-3

Monitor Manufacturer and Model No.: Satec PM130EH Plus

Date of Latest CMS Certification or Audit: N/A

Total source operating time in reporting period¹: 995

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 208	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 0	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 4	c. Quality assurance calibration – 0 hours
d. Other known causes – 0	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 212	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 21.3%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%

¹ For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.


On a separate page, describe any changes since last quarter in CMS, process or controls.
NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature



Title

Vice President- EEHS & Regulatory

Date

9/5/2025

Excess Emissions

Per agreement with USEPA, an operating load less than 90% is a period of noncompliance. The unit is rated at 27.6 megawatts (MW) and 90% operating load is 24.8 MW. There are no conversion factors from operating load to ppbvdc. Therefore, hours with operating load below 24.8 MW are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
1/12/2023	11 AM	14.37	Startup
1/12/2023	9 PM	17.27	Shutdown
1/13/2023	4 PM	9.01	Startup
1/13/2023	9 PM	17.53	Shutdown
1/14/2023	4 PM	20.23	Startup
1/14/2023	10 PM	22.89	Shutdown
1/15/2023	4 PM	20.27	Startup
1/15/2023	8 PM	20.64	Shutdown
1/17/2023	8 PM	18.07	Malfunction
1/18/2023	4 PM	7.88	Startup
1/18/2023	9 PM	9.66	Shutdown
1/19/2023	9 PM	14.52	Shutdown
1/20/2023	5 PM	22.27	Startup
1/20/2023	9 PM	18.16	Shutdown
1/22/2023	6 PM	22.29	Startup
1/22/2023	10 PM	14.98	Shutdown
1/23/2023	5 PM	18.59	Startup
1/23/2023	11 PM	14.04	Shutdown
1/26/2023	5 PM	18.46	Startup
1/26/2023	9 PM	16.37	Shutdown
1/27/2023	6 PM	21.19	Startup
1/27/2023	8 PM	10.61	Shutdown
2/2/2023	9 PM	18.89	Shutdown
2/3/2023	6 PM	23.64	Startup
2/4/2023	10 PM	13.93	Shutdown
2/7/2023	10 PM	18.29	Shutdown
2/8/2023	3 PM	23.56	Startup
2/8/2023	9 PM	18.04	Shutdown
2/9/2023	3 PM	16.66	Startup
2/9/2023	4 PM	9.69	Malfunction
2/9/2023	10 PM	20.22	Shutdown
2/10/2023	10 PM	23.58	Shutdown
2/11/2023	7 PM	24.21	Startup
2/11/2023	8 PM	20.20	Shutdown
2/13/2023	4 PM	24.18	Startup
2/14/2023	12 AM	22.22	Shutdown

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
2/14/2023	6 PM	21.36	Startup
2/15/2023	10 PM	11.58	Shutdown
2/16/2023	3 PM	23.73	Startup
2/16/2023	11 PM	14.89	Shutdown
2/17/2023	3 PM	11.75	Startup
2/17/2023	10 PM	16.08	Shutdown
2/20/2023	4 PM	13.87	Startup
2/20/2023	11 PM	16.42	Shutdown
2/21/2023	5 PM	9.02	Startup
2/21/2023	9 PM	14.80	Shutdown
2/22/2023	11 PM	15.72	Shutdown
2/23/2023	10 PM	24.67	Shutdown
2/24/2023	3 PM	18.74	Startup
2/24/2023	9 PM	20.78	Shutdown
2/25/2023	6 PM	17.59	Startup
2/25/2023	9 PM	23.59	Shutdown
2/27/2023	4 PM	13.10	Startup
2/28/2023	9 PM	20.95	Shutdown
3/1/2023	4 PM	19.68	Startup
3/1/2023	11 PM	20.86	Shutdown
3/2/2023	11 PM	21.05	Shutdown
3/3/2023	7 AM	17.52	Startup
3/3/2023	11 PM	22.31	Shutdown
3/4/2023	3 PM	17.27	Startup
3/4/2023	10 PM	19.83	Shutdown
3/5/2023	8 PM	13.97	Startup
3/5/2023	10 PM	9.25	Shutdown
3/6/2023	4 PM	22.21	Startup
3/6/2023	10 PM	23.15	Shutdown
3/7/2023	10 PM	24.04	Shutdown
3/8/2023	6 PM	22.46	Startup
3/8/2023	10 PM	22.12	Shutdown
3/11/2023	5 PM	15.71	Startup
3/11/2023	9 PM	20.72	Shutdown
3/13/2023	4 PM	21.26	Startup
3/14/2023	11 PM	15.55	Startup
3/14/2025	8 PM	8.46	Shutdown
3/19/2025	10 PM	21.31	Shutdown
3/20/2025	5 PM	24.26	Startup
3/20/2025	11 PM	10.33	Shutdown
3/21/2025	6 PM	15.83	Startup
3/21/2025	10 PM	23.24	Shutdown
3/22/2025	4 PM	18.10	Startup

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
3/22/2025	10 PM	20.09	Shutdown
3/23/2025	6 PM	16.27	Startup
3/23/2025	9 PM	21.14	Shutdown
3/25/2025	6 PM	9.77	Malfunction
3/31/2023	5 PM	24.56	Startup
4/1/2023	12 AM	16.83	Shutdown
4/2/2023	11 PM	20.77	Shutdown
4/3/2023	5 PM	17.51	Startup
4/3/2023	10 PM	20.42	Shutdown
4/4/2023	4 PM	18.16	Startup
4/4/2023	10 PM	21.79	Shutdown
4/10/2023	3 PM	24.49	Startup
4/11/2023	12 AM	21.18	Shutdown
4/11/2023	10 AM	17.32	Startup
4/11/2023	10 PM	19.78	Shutdown
4/12/2023	5 PM	7.42	Startup
4/12/2023	10 PM	16.84	Shutdown
4/13/2023	3 PM	7.07	Startup
4/13/2023	10 PM	18.31	Shutdown
4/14/2023	5 PM	21.28	Startup
4/14/2023	9 PM	13.55	Shutdown
4/15/2023	5 PM	21.67	Startup
4/15/2023	9 PM	18.28	Shutdown
4/16/2023	6 PM	21.47	Startup
4/16/2023	10 PM	19.68	Shutdown
4/17/2023	6 PM	9.37	Startup
4/17/2023	9 PM	21.38	Shutdown
4/19/2023	6 PM	15.81	Startup
4/19/2023	10 PM	19.10	Shutdown
4/20/2023	6 PM	10.85	Startup
4/20/2023	9 PM	16.15	Shutdown
4/24/2023	9 PM	24.20	Shutdown
4/25/2023	5 PM	15.78	Startup
4/25/2023	10 PM	21.68	Shutdown
4/26/2023	3 PM	13.09	Startup
4/27/2023	3 PM	24.12	Startup
4/27/2023	10 PM	20.13	Shutdown
4/28/2023	3 PM	17.26	Startup
4/28/2023	8 PM	17.16	Shutdown
4/29/2023	4 PM	9.32	Startup
4/29/2023	10 PM	22.33	Shutdown
4/30/2023	5 PM	21.90	Startup
4/30/2023	11 PM	7.64	Shutdown

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
5/1/2023	4 PM	16.97	Startup
5/1/2023	11 PM	15.27	Shutdown
5/2/2023	12 PM	16.99	Startup
5/2/2023	11 PM	18.21	Shutdown
5/3/2023	3 PM	24.36	Startup
5/3/2023	10 PM	23.35	Shutdown
5/4/2023	8 AM	14.42	Startup
5/5/2023	12 AM	16.30	Shutdown
5/5/2023	9 AM	21.16	Startup
5/5/2023	11 PM	14.26	Shutdown
5/6/2023	5 PM	21.39	Startup
5/6/2023	12 AM	11.48	Shutdown
5/7/2023	4 PM	21.39	Startup
5/7/2023	11 PM	12.29	Shutdown
5/8/2023	11 AM	17.80	Startup
5/8/2023	10 PM	18.91	Shutdown
5/9/2023	2 PM	21.51	Startup
5/10/2023	12 AM	15.48	Shutdown
5/10/2023	3 PM	19.33	Startup
5/10/2023	11 PM	24.10	Shutdown
5/11/2023	3 PM	17.25	Startup
5/11/2023	11 PM	12.26	Shutdown
5/12/2023	3 PM	10.70	Startup
5/13/2023	12 AM	12.15	Shutdown
5/13/2023	11 PM	10.58	Shutdown
5/14/2023	5 PM	23.26	Startup
5/15/2023	12 AM	23.29	Shutdown
5/15/2023	2 PM	14.28	Startup
5/16/2023	12 AM	23.58	Shutdown
5/16/2023	2 PM	7.09	Startup
5/17/2023	1 AM	20.84	Shutdown
5/17/2023	2 PM	23.00	Startup
5/17/2023	11 PM	8.75	Shutdown
5/18/2023	11 PM	24.20	Shutdown
5/19/2023	8 AM	21.97	Startup
5/19/2023	9 AM	17.06	Malfunction
5/19/2023	6 PM	18.82	Startup
5/19/2023	10 PM	22.70	Startup
5/23/2023	8 AM	13.72	Startup
5/23/2023	10 AM	11.62	Shutdown
5/23/2023	1 PM	17.67	Startup
5/23/2023	9 PM	16.95	Shutdown
5/24/2023	12 PM	21.34	Startup

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
5/24/2023	9 PM	15.08	Shutdown
5/25/2023	1 PM	24.02	Startup
5/25/2023	10 PM	9.67	Shutdown
5/26/2023	7 AM	15.24	Startup
5/26/2023	10 PM	12.85	Shutdown
5/27/2023	5 PM	14.78	Startup
5/27/2023	10 PM	22.19	Shutdown
5/28/2023	7 PM	17.90	Startup
5/28/2023	11 PM	22.29	Shutdown
5/29/2023	4 PM	14.69	Startup
5/30/2023	8 AM	12.60	Startup
5/30/2023	10 PM	16.94	Shutdown
5/31/2023	8 AM	11.59	Startup
5/31/2023	10 PM	11.23	Shutdown
6/1/2023	8 AM	10.24	Startup
6/2/2023	12 AM	7.32	Shutdown
6/2/2023	8 AM	15.84	Startup
6/2/2023	11 PM	24.64	Shutdown
6/4/2023	1 AM	17.94	Shutdown
6/4/2023	3 PM	24.22	Startup
6/5/2023	11 PM	21.75	Shutdown
6/6/2023	2 PM	11.85	Startup
6/7/2023	8 AM	14.15	Startup
6/7/2023	10 PM	12.92	Shutdown
6/10/2023	10 PM	21.34	Startup
6/12/2023	1 AM	8.42	Shutdown
6/12/2023	4 PM	14.91	Startup
6/14/2023	12 AM	13.73	Shutdown
6/14/2023	4 PM	23.24	Startup
6/14/2023	11 PM	23.93	Shutdown
6/15/2023	3 PM	16.42	Startup
6/17/2023	1 AM	16.24	Shutdown
6/21/2023	3 PM	15.53	Startup
6/21/2023	10 PM	12.88	Shutdown
6/22/2023	8 AM	14.45	Startup
6/23/2023	12 AM	17.61	Shutdown
6/23/2023	12 PM	9.33	Startup
6/25/2023	6 PM	24.76	Startup
6/25/2023	11 PM	11.58	Shutdown
6/26/2023	3 PM	19.04	Startup
6/27/2023	12 AM	16.23	Shutdown
6/27/2023	1 PM	18.93	Startup
6/27/2023	11 PM	18.91	Shutdown

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
6/29/2023	7 PM	15.85	Startup
6/30/2023	12 AM	9.31	Shutdown
6/30/2023	8 AM	16.73	Startup
6/30/2023	11 PM	13.23	Shutdown

**National Emission Standard for Hazardous Air Pollutants Subpart YYYY
Semi-Annual Report (40 CFR 63.6150)**

Pollutant: Formaldehyde, parts per billion by volume correct to 15% oxygen dry basis (ppbvdc)

Emission Limitation: 91 ppbvdc natural gas and oil firing

Reporting period dates: From July 1, 2023 to December 31, 2023

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-3

Monitor Manufacturer and Model No.: Satec PM130EH Plus

Date of Latest CMS Certification or Audit: N/A

Total source operating time in reporting period¹: 1500

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 95	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 0	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 0	c. Quality assurance calibration – 0 hours
d. Other known causes – 24	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 119	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 7.9%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%

¹ For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.

On a separate page, describe any changes since last quarter in CMS, process or controls.
NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature



Title

Vice President- EEHS & Regulatory

Date

9/5/2025

Excess Emissions

Per agreement with USEPA, an operating load less than 90% is a period of noncompliance. The unit is rated at 27.6 megawatts (MW) and 90% operating load is 24.8 MW. There are no conversion factors from operating load to ppbvdc. Therefore, hours with operating load below 24.8 MW are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
07/02/23	5 PM	8.51	Startup	
07/03/23	12 AM	21.41	Shutdown	
07/03/23	5 PM	23.27	Startup	
07/04/23	12 AM	10.21	Shutdown	
07/04/23	5 PM	17.01	Startup	
07/05/23	1 AM	21.33	Shutdown	
07/05/23	4 PM	22.93	Startup	
07/05/23	11 PM	20.77	Shutdown	
07/06/23	3 PM	12.69	Startup	
07/07/23	12 AM	21.51	Shutdown	
07/07/23	9 AM	21.49	Startup	
07/09/23	5 PM	12.94	Startup	
07/09/23	11 PM	16.53	Shutdown	
07/10/23	8 AM	10.95	Startup	
07/12/23	11 PM	15.63	Shutdown	
07/13/23	12 PM	16.80	Startup	
07/14/23	2 AM	14.90	Shutdown	
07/14/23	8 AM	8.60	Startup	
07/16/23	2 AM	20.47	Shutdown	
07/16/23	3 PM	7.36	Startup	
07/16/23	5 PM	17.54	Reduced Load	63.6%
07/16/23	6 PM	14.14	Reduced Load	51.2%
07/16/23	7 PM	17.89	Reduced Load	64.8%
07/16/23	8 PM	14.52	Reduced Load	52.6%
07/16/23	9 PM	15.00	Reduced Load	54.4%
07/16/23	10 PM	14.72	Reduced Load	53.3%
07/16/23	11 PM	12.69	Reduced Load	46.0%
07/17/23	12 AM	14.01	Reduced Load	50.8%
07/17/23	1 AM	13.98	Reduced Load	50.7%
07/17/23	2 AM	13.99	Reduced Load	50.7%
07/17/23	3 AM	14.00	Reduced Load	50.7%
07/17/23	4 AM	14.00	Reduced Load	50.7%
07/17/23	5 AM	14.18	Reduced Load	51.4%
07/17/23	6 AM	14.01	Reduced Load	50.8%
07/17/23	7 AM	13.63	Reduced Load	49.4%
07/18/23	6 PM	24.32	Shutdown	
07/19/23	9 AM	10.33	Startup	

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
07/21/23	4 AM	20.93	Shutdown	
07/21/23	12 PM	13.00	Shutdown	
07/21/23	2 PM	13.21	Shutdown	
07/22/23	12 AM	22.04	Shutdown	
07/22/23	4 PM	9.17	Startup	
07/24/23	2 AM	14.17	Shutdown	
07/24/23	3 PM	13.22	Startup	
07/25/23	2 AM	12.03	Shutdown	
07/25/23	11 AM	23.22	Startup	
07/25/23	11 PM	24.47	Shutdown	
07/26/23	11 PM	15.48	Shutdown	
07/27/23	5 PM	22.32	Startup	
07/28/23	12 AM	16.77	Shutdown	
07/29/23	12 AM	12.31	Shutdown	
07/29/23	7 PM	24.52	Startup	
07/31/23	3 PM	19.63	Startup	
07/31/23	10 PM	14.02	Shutdown	
08/01/23	3 PM	22.07	Startup	
08/01/23	10 PM	21.07	Shutdown	
08/03/23	10 PM	19.72	Shutdown	
08/04/23	4 PM	20.01	Startup	
08/06/23	10 AM	22.17	Startup	
08/06/23	3 PM	17.28	Shutdown	
08/10/23	7 PM	19.82	Startup	
08/10/23	11 PM	23.23	Reduced Load	84.2%
08/12/23	1 AM	24.09	Shutdown	
08/12/23	6 PM	21.87	Startup	
08/13/23	5 PM	12.46	Startup	
08/18/23	9 AM	21.86	Shutdown	
08/18/23	3 PM	16.11	Startup	
08/19/23	1 AM	20.45	Shutdown	
08/19/23	5 PM	12.14	Startup	
08/20/25	4 AM	13.57	Shutdown	
08/21/25	11 AM	12.19	Startup	
08/21/25	12 PM	19.13	Shutdown	
08/21/25	4 PM	20.03	Startup	
08/21/25	8 PM	12.20	Shutdown	
08/23/23	2 PM	24.60	Startup	
08/24/23	1 AM	17.22	Shutdown	
08/24/23	3 PM	19.03	Startup	
08/27/23	7 AM	10.19	Shutdown	
08/27/23	4 PM	20.74	Startup	
09/01/23	12 PM	15.86	Reduced Load	57.4%
09/01/23	1 PM	21.89	Reduced Load	79.3%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
09/02/23	6 AM	20.64	Shutdown	
09/02/23	2 PM	14.30	Startup	
09/03/23	5 AM	20.90	Shutdown	
09/03/23	2 PM	13.94	Startup	
09/05/23	2 AM	18.49	Shutdown	
09/05/23	6 AM	19.32	Startup	
09/05/23	8 AM	24.46	Reduced Load	88.6%
09/05/23	10 AM	24.20	Shutdown	
09/05/23	2 PM	23.11	Startup	
09/05/23	11 PM	24.21	Reduced Load	87.7%
09/06/23	12 AM	24.09	Reduced Load	87.3%
09/08/23	2 AM	22.48	Reduced Load	81.4%
09/12/23	5 PM	22.61	Reduced Load	81.9%
09/12/23	6 PM	13.16	Shutdown	
09/12/23	8 PM	19.73	Startup	
09/13/25	5 PM	9.00	Startup	
09/13/25	6 PM	18.39	Reduced Load	66.6%
09/13/25	8 PM	18.10	Startup	
09/14/25	5 PM	15.58	Startup	
09/16/23	12 PM	11.01	Shutdown	
09/16/23	4 PM	15.41	Startup	
09/17/23	5 AM	16.83	Shutdown	
09/17/23	3 PM	22.31	Startup	
09/24/23	9 AM	12.50	Shutdown	
09/24/23	2 PM	21.12	Startup	
09/26/23	2 AM	15.14	Shutdown	
09/26/23	9 AM	18.49	Startup	
09/26/23	3 PM	23.68	Startup	
09/27/23	1 AM	17.64	Shutdown	
09/28/23	2 AM	7.46	Shutdown	
09/28/23	3 PM	17.05	Startup	
09/29/23	1 AM	16.11	Shutdown	
10/02/23	8 PM	15.40	Startup	
10/02/25	11 PM	14.08	Shutdown	
11/12/25	9 PM	16.89	Startup	
11/13/25	6 PM	9.50	Startup	
11/13/25	10 PM	21.03	Shutdown	
12/06/23	1 PM	17.04	Startup	

**National Emission Standard for Hazardous Air Pollutants Subpart YYYY
Semi-Annual Report (40 CFR 63.6150)**

Pollutant: Formaldehyde, parts per billion by volume correct to 15% oxygen dry basis (ppbvdc)

Emission Limitation: 91 ppbvdc natural gas and oil firing

Reporting period dates: From January 1, 2024 to June 30, 2024

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-3

Monitor Manufacturer and Model No.: Satec PM130EH Plus

Date of Latest CMS Certification or Audit: N/A

Total source operating time in reporting period¹: 278

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 76	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 0	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 4	c. Quality assurance calibration – 0 hours
d. Other known causes – 9	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 89	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 32.0%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%

¹ For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.


On a separate page, describe any changes since last quarter in CMS, process or controls.
NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature



Title

Vice President- EEHS & Regulatory

Date

9/5/2025

Excess Emissions

Per agreement with USEPA, an operating load less than 90% is a period of noncompliance. The unit is rated at 27.6 megawatts (MW) and 90% operating load is 24.8 MW. There are no conversion factors from operating load to ppbvdc. Therefore, hours with operating load below 24.8 MW are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
01/11/24	5 PM	17.92	Startup	
01/11/24	9 PM	21.20	Shutdown	
01/18/24	7 PM	14.01	Startup	
01/18/24	10 PM	7.20	Shutdown	
03/30/24	8 PM	22.22	Startup	
03/31/24	3 AM	15.63	Shutdown	
03/31/24	7 PM	20.42	Startup	
03/31/24	10 PM	19.60	Shutdown	
04/01/24	6 PM	18.85	Startup	
04/01/24	7 PM	11.47	Shutdown	
04/02/24	8 PM	9.98	Malfunction	
04/03/24	3 PM	15.63	Malfunction	
04/05/24	2 PM	12.57	Startup	
04/05/24	9 PM	22.64	Shutdown	
04/06/24	6 PM	19.10	Startup	
04/06/24	11 PM	14.68	Shutdown	
04/07/24	6 PM	14.83	Startup	
04/07/24	11 PM	15.43	Shutdown	
04/20/24	7 PM	9.90	Startup	
04/20/24	8 PM	24.50	Reduced Load	88.8%
04/20/24	11 PM	21.73	Shutdown	
04/22/24	6 PM	17.04	Startup	
04/22/24	11 PM	7.59	Shutdown	
04/25/24	7 PM	11.95	Startup	
04/25/24	10 PM	7.58	Shutdown	
04/29/24	11 PM	16.80	Startup	
04/30/24	12 AM	15.27	Shutdown	
04/30/24	5 PM	19.14	Startup	
04/30/24	9 PM	23.96	Reduced Load	86.8%
04/30/24	10 PM	8.32	Shutdown	
05/02/24	2 PM	7.39	Startup	
05/02/24	4 PM	24.55	Reduced Load	88.9%
05/02/24	11 PM	17.02	Shutdown	
05/03/24	12 PM	24.24	Startup	
05/03/24	9 PM	14.26	Shutdown	
05/11/24	4 PM	17.60	Startup	
05/13/24	7 PM	22.18	Startup	
05/13/24	10 PM	20.93	Shutdown	
05/14/24	7 PM	9.36	Startup	

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
05/14/24	11 PM	13.12	Shutdown	
05/15/24	5 PM	16.20	Startup	
05/15/24	10 PM	15.05	Shutdown	
05/21/24	5 PM	22.87	Startup	
05/21/24	10 PM	16.36	Shutdown	
05/23/24	5 PM	19.95	Startup	
05/23/24	11 PM	7.61	Shutdown	
05/24/24	9 PM	12.42	Shutdown	
05/25/24	6 PM	18.36	Startup	
05/26/24	5 PM	20.26	Startup	
05/27/24	1 AM	20.48	Shutdown	
05/27/24	3 PM	20.50	Startup	
05/27/24	10 PM	24.44	Shutdown	
05/28/24	7 PM	22.13	Startup	
05/28/24	10 PM	17.87	Shutdown	
05/29/24	8 PM	22.94	Startup	
05/30/24	7 AM	18.68	Startup	
05/31/24	6 PM	18.12	Startup	
05/31/24	11 PM	11.29	Shutdown	
06/01/24	7 PM	7.09	Startup	
06/01/24	8 PM	23.92	Reduced Load	86.7%
06/01/24	10 PM	11.75	Shutdown	
06/04/24	7 PM	22.92	Reduced Load	83.0%
06/04/24	10 PM	23.42	Reduced Load	84.9%
06/05/24	12 PM	16.09	Startup	
06/05/24	11 PM	13.86	Shutdown	
06/06/24	5 PM	19.34	Startup	
06/06/24	10 PM	13.01	Shutdown	
06/08/24	2 PM	12.17	Startup	
06/09/24	12 AM	11.96	Shutdown	
06/09/24	2 PM	18.45	Startup	
06/10/24	1 AM	15.45	Shutdown	
06/10/24	1 PM	14.46	Startup	
06/11/24	12 AM	17.59	Shutdown	
06/11/24	4 PM	9.38	Startup	
06/11/24	5 PM	24.39	Reduced Load	88.4%
06/11/24	10 PM	14.08	Shutdown	
06/12/24	5 PM	23.19	Reduced Load	84.0%
06/12/24	9 PM	11.99	Shutdown	
06/13/24	12 AM	20.09	Startup	
06/13/24	2 PM	23.56	Reduced Load	85.4%
06/13/24	3 PM	7.55	Shutdown	
06/13/24	7 PM	7.42	Malfunction	
06/14/24	8 PM	21.00	Malfunction	
06/18/24	6 PM	20.54	Startup	

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
06/18/24	10 PM	17.57	Shutdown	
06/19/24	7 PM	24.22	Startup	
06/19/24	10 PM	20.04	Shutdown	
06/25/24	11 PM	16.06	Startup	
06/26/24	1 AM	16.42	Shutdown	

**National Emission Standard for Hazardous Air Pollutants Subpart YYYY
Semi-Annual Report (40 CFR 63.6150)**

Pollutant: Formaldehyde, parts per billion by volume correct to 15% oxygen dry basis (ppbvdc)

Emission Limitation: 91 ppbvdc natural gas and oil firing

Reporting period dates: From July 1, 2024 to December 31, 2024

Company: GeneraPR

Plant: Palo Seco Steam Generating Plant

Address: PR-165 KM 30.8
TOA BAJA, P.R. 00949

Process Unit(s) Description: PS-MP-3

Monitor Manufacturer and Model No.: Satec PM130EH Plus

Date of Latest CMS Certification or Audit: N/A

Total source operating time in reporting period¹: 774

Emission data summary	CMS performance summary
1. Duration of excess emissions in reporting period due to ¹ :	1. CMS downtime in reporting period due to ¹ :
a. Startup/shutdown – 194	a. Monitor equipment malfunctions – 0 hours
b. Control equipment problems – 0	b. Non-Monitor equipment malfunctions – 0 hours
c. Process problems – 1	c. Quality assurance calibration – 0 hours
d. Other known causes – 218	d. Other known causes – 0 hours
e. Unknown causes – 0	e. Unknown causes – 0 hours
2. Total duration of excess emission – 413	2. Total CMS Downtime – 0 hours
3. Total duration of excess emissions × (100) % ² [Total source operating time] – 53.3%	3. [Total CMS Downtime] × (100) % ² [Total source operating time] – 0%

¹ For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in § 60.7(c) shall be submitted.

On a separate page, describe any changes since last quarter in CMS, process or controls.
NOT APPLICABLE

I certify that the information contained in this report is true, accurate, and complete.

Name

Ricardo Pallens Cruz, Esq.

Signature



Title

Vice President- EEHS & Regulatory

Date

9/5/2025

Excess Emissions

Per agreement with USEPA, an operating load less than 90% is a period of noncompliance. The unit is rated at 27.6 megawatts (MW) and 90% operating load is 24.8 MW. There are no conversion factors from operating load to ppbvdc. Therefore, hours with operating load below 24.8 MW are reported.

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
07/06/24	7 PM	13.40	Startup	
07/06/24	11 PM	10.39	Shutdown	
07/07/24	6 PM	7.54	Startup	
07/07/24	11 PM	13.27	Shutdown	
07/11/24	6 PM	18.80	Startup	
07/11/24	7 PM	19.99	Reduced Load	72.4%
07/11/24	8 PM	19.98	Reduced Load	72.4%
07/11/24	9 PM	19.98	Reduced Load	72.4%
07/11/24	10 PM	19.15	Shutdown	
07/12/24	5 PM	13.19	Startup	
07/12/24	6 PM	20.00	Reduced Load	72.5%
07/12/24	7 PM	20.00	Reduced Load	72.5%
07/12/24	8 PM	23.74	Reduced Load	86.0%
07/12/24	11 PM	14.40	Shutdown	
07/17/24	8 PM	15.63	Startup	
07/17/24	9 PM	8.12	Shutdown	
07/18/24	7 PM	18.89	Startup	
07/18/24	9 PM	17.41	Shutdown	
07/20/24	1 PM	12.00	Startup	
07/20/24	2 PM	14.70	Shutdown	
07/23/24	3 PM	14.42	Startup	
08/01/24	7 AM	19.23	Startup	
08/05/24	6 PM	9.92	Startup	
08/05/24	11 PM	17.73	Shutdown	
08/06/24	6 PM	8.60	Startup	
08/06/24	7 PM	24.64	Reduced Load	89.3%
08/06/24	9 PM	10.52	Shutdown	
08/07/24	6 PM	9.43	Startup	
08/07/24	7 PM	24.70	Reduced Load	89.5%
08/07/24	9 PM	23.22	Shutdown	
08/08/24	7 PM	7.26	Startup	
08/08/24	8 PM	24.10	Reduced Load	87.3%
08/08/24	9 PM	21.46	Reduced Load	77.8%
08/09/24	2 AM	10.80	Startup	
08/09/24	1 PM	15.60	Reduced Load	56.5%
08/09/24	5 PM	16.90	Reduced Load	61.2%
08/09/24	6 PM	17.13	Reduced Load	62.1%
08/09/24	7 PM	19.98	Reduced Load	72.4%
08/09/24	8 PM	19.98	Reduced Load	72.4%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
08/09/24	9 PM	19.99	Reduced Load	72.4%
08/09/24	10 PM	19.99	Reduced Load	72.4%
08/09/24	11 PM	20.00	Reduced Load	72.5%
08/10/24	12 AM	20.00	Reduced Load	72.5%
08/10/24	1 AM	19.08	Shutdown	
08/13/24	12 PM	21.95	Startup	
08/13/24	1 PM	24.00	Reduced Load	87.0%
08/13/24	2 PM	24.00	Reduced Load	86.9%
08/13/24	3 PM	18.49	Reduced Load	67.0%
08/13/24	4 PM	19.91	Reduced Load	72.1%
08/13/24	5 PM	19.99	Reduced Load	72.4%
08/13/24	6 PM	19.99	Reduced Load	72.4%
08/13/24	7 PM	20.00	Reduced Load	72.5%
08/13/24	8 PM	20.00	Reduced Load	72.5%
08/13/24	9 PM	19.98	Reduced Load	72.4%
08/13/24	10 PM	19.99	Reduced Load	72.4%
08/13/24	11 PM	19.96	Shutdown	
08/15/24	4 PM	8.18	Startup	
08/15/24	5 PM	19.91	Reduced Load	72.1%
08/15/24	6 PM	19.98	Reduced Load	72.4%
08/15/24	7 PM	19.97	Reduced Load	72.4%
08/15/24	8 PM	19.89	Reduced Load	72.1%
08/15/24	9 PM	19.89	Reduced Load	72.1%
08/15/24	10 PM	19.99	Reduced Load	72.4%
08/15/24	11 PM	19.99	Reduced Load	72.4%
08/16/24	12 AM	20.00	Reduced Load	72.5%
08/16/24	1 AM	20.00	Reduced Load	72.5%
08/16/24	2 AM	10.70	Shutdown	
08/16/24	4 PM	8.00	Startup	
08/16/24	5 PM	19.81	Reduced Load	71.8%
08/16/24	6 PM	19.89	Reduced Load	72.1%
08/16/24	7 PM	19.99	Reduced Load	72.4%
08/16/24	8 PM	19.86	Reduced Load	71.9%
08/16/24	9 PM	19.97	Reduced Load	72.4%
08/16/24	10 PM	19.95	Reduced Load	72.3%
08/16/24	11 PM	19.96	Reduced Load	72.3%
08/17/24	12 AM	19.98	Reduced Load	72.4%
08/17/24	1 AM	18.15	Shutdown	
08/17/24	1 PM	10.17	Startup	
08/17/24	2 PM	20.00	Reduced Load	72.5%
08/17/24	3 PM	20.00	Reduced Load	72.5%
08/17/24	4 PM	19.98	Reduced Load	72.4%
08/17/24	5 PM	20.00	Reduced Load	72.4%
08/17/24	6 PM	19.96	Reduced Load	72.3%
08/17/24	7 PM	19.98	Reduced Load	72.4%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
08/17/24	8 PM	20.00	Reduced Load	72.4%
08/17/24	9 PM	20.00	Reduced Load	72.5%
08/17/24	10 PM	20.00	Reduced Load	72.5%
08/17/24	11 PM	19.08	Shutdown	
08/18/24	6 PM	11.74	Startup	
08/18/24	7 PM	20.00	Reduced Load	72.5%
08/18/24	8 PM	20.00	Reduced Load	72.4%
08/18/24	9 PM	20.00	Reduced Load	72.5%
08/18/24	10 PM	20.00	Reduced Load	72.5%
08/18/24	11 PM	14.10	Shutdown	
08/19/24	3 PM	11.39	Startup	
08/19/24	4 PM	19.99	Reduced Load	72.4%
08/19/24	5 PM	19.91	Reduced Load	72.1%
08/19/24	6 PM	19.68	Reduced Load	71.3%
08/19/24	7 PM	19.85	Reduced Load	71.9%
08/19/24	8 PM	19.96	Reduced Load	72.3%
08/19/24	9 PM	19.94	Reduced Load	72.3%
08/19/24	10 PM	19.98	Reduced Load	72.4%
08/19/24	11 PM	19.99	Reduced Load	72.4%
08/20/24	12 AM	20.03	Reduced Load	72.6%
08/20/24	1 AM	19.88	Reduced Load	72.0%
08/20/24	2 AM	20.00	Reduced Load	72.5%
08/20/24	3 AM	20.00	Reduced Load	72.5%
08/20/24	4 AM	20.00	Reduced Load	72.5%
08/20/24	5 AM	19.99	Reduced Load	72.4%
08/20/24	6 AM	20.05	Reduced Load	72.7%
08/20/24	7 AM	20.01	Reduced Load	72.5%
08/20/24	8 AM	19.99	Reduced Load	72.4%
08/20/24	9 AM	19.99	Reduced Load	72.4%
08/20/24	10 AM	19.99	Reduced Load	72.4%
08/20/24	11 AM	19.98	Reduced Load	72.4%
08/20/24	12 PM	19.85	Reduced Load	71.9%
08/20/24	1 PM	19.94	Reduced Load	72.2%
08/20/24	2 PM	19.98	Reduced Load	72.4%
08/20/24	3 PM	19.97	Reduced Load	72.4%
08/20/24	4 PM	19.95	Reduced Load	72.3%
08/20/24	5 PM	19.95	Reduced Load	72.3%
08/20/24	6 PM	19.90	Reduced Load	72.1%
08/20/24	7 PM	19.78	Reduced Load	71.7%
08/20/24	8 PM	19.99	Reduced Load	72.4%
08/20/24	9 PM	20.00	Reduced Load	72.4%
08/20/24	10 PM	19.96	Reduced Load	72.3%
08/20/24	11 PM	19.99	Reduced Load	72.4%
08/21/24	12 AM	19.94	Reduced Load	72.2%
08/21/24	1 AM	8.68	Shutdown	

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
08/21/24	3 PM	12.82	Startup	
08/21/24	4 PM	19.97	Reduced Load	72.4%
08/21/24	5 PM	19.99	Reduced Load	72.4%
08/21/24	6 PM	19.99	Reduced Load	72.4%
08/21/24	7 PM	20.00	Reduced Load	72.5%
08/21/24	8 PM	20.00	Reduced Load	72.5%
08/21/24	9 PM	20.00	Reduced Load	72.5%
08/21/24	10 PM	19.51	Shutdown	
08/22/24	3 PM	17.54	Startup	
08/22/24	4 PM	19.78	Reduced Load	71.7%
08/22/24	5 PM	19.87	Reduced Load	72.0%
08/22/24	6 PM	19.86	Reduced Load	72.0%
08/22/24	7 PM	19.95	Reduced Load	72.3%
08/22/24	8 PM	19.98	Reduced Load	72.4%
08/22/24	9 PM	19.99	Reduced Load	72.4%
08/22/24	10 PM	20.00	Reduced Load	72.4%
08/22/24	11 PM	19.99	Reduced Load	72.4%
08/23/24	12 AM	20.00	Reduced Load	72.5%
08/23/24	1 AM	20.00	Reduced Load	72.5%
08/23/24	2 AM	20.00	Reduced Load	72.4%
08/23/24	3 AM	20.00	Reduced Load	72.5%
08/23/24	4 AM	20.00	Reduced Load	72.5%
08/23/24	5 AM	19.99	Reduced Load	72.4%
08/23/24	6 AM	19.99	Reduced Load	72.4%
08/23/24	7 AM	19.98	Reduced Load	72.4%
08/23/24	8 AM	19.98	Reduced Load	72.4%
08/23/24	9 AM	19.99	Reduced Load	72.4%
08/23/24	10 AM	19.99	Reduced Load	72.4%
08/23/24	11 AM	19.99	Reduced Load	72.4%
08/23/24	12 PM	19.98	Reduced Load	72.4%
08/23/24	1 PM	19.98	Reduced Load	72.4%
08/23/24	2 PM	19.97	Reduced Load	72.4%
08/23/24	3 PM	19.93	Reduced Load	72.2%
08/23/24	4 PM	19.85	Reduced Load	71.9%
08/23/24	5 PM	19.88	Reduced Load	72.0%
08/23/24	6 PM	19.94	Reduced Load	72.2%
08/23/24	7 PM	19.93	Reduced Load	72.2%
08/23/24	8 PM	19.84	Reduced Load	71.9%
08/23/24	9 PM	19.74	Reduced Load	71.5%
08/23/24	10 PM	19.98	Reduced Load	72.4%
08/23/24	11 PM	19.99	Reduced Load	72.4%
08/24/24	12 AM	20.00	Reduced Load	72.5%
08/24/24	1 AM	20.00	Reduced Load	72.5%
08/24/24	2 AM	20.00	Reduced Load	72.5%
08/24/24	3 AM	10.91	Shutdown	

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
08/24/24	5 PM	18.80	Startup	
08/24/24	6 PM	19.73	Reduced Load	71.5%
08/24/24	7 PM	19.79	Reduced Load	71.7%
08/24/24	8 PM	19.97	Reduced Load	72.4%
08/24/24	9 PM	20.00	Reduced Load	72.5%
08/24/24	10 PM	19.99	Reduced Load	72.4%
08/24/24	11 PM	20.00	Reduced Load	72.4%
08/25/24	12 AM	19.99	Reduced Load	72.4%
08/25/24	1 AM	20.01	Reduced Load	72.5%
08/25/24	2 AM	20.00	Reduced Load	72.5%
08/25/24	3 AM	20.00	Reduced Load	72.5%
08/25/24	4 AM	17.18	Shutdown	
08/25/24	4 PM	9.02	Startup	
08/25/24	5 PM	19.97	Reduced Load	72.4%
08/25/24	6 PM	19.98	Reduced Load	72.4%
08/25/24	7 PM	19.97	Reduced Load	72.3%
08/25/24	8 PM	20.00	Reduced Load	72.4%
08/25/24	9 PM	20.00	Reduced Load	72.5%
08/25/24	10 PM	20.00	Reduced Load	72.5%
08/25/24	11 PM	20.00	Reduced Load	72.5%
08/26/24	12 AM	17.56	Shutdown	
08/26/24	3 PM	15.09	Startup	
08/26/24	4 PM	19.96	Reduced Load	72.3%
08/26/24	5 PM	19.90	Reduced Load	72.1%
08/26/24	6 PM	19.89	Reduced Load	72.0%
08/26/24	7 PM	19.92	Reduced Load	72.2%
08/26/24	8 PM	19.99	Reduced Load	72.4%
08/26/24	9 PM	19.99	Reduced Load	72.4%
08/26/24	10 PM	20.00	Reduced Load	72.5%
08/26/24	11 PM	19.12	Shutdown	
08/27/24	4 PM	8.12	Startup	
08/27/24	5 PM	19.44	Reduced Load	70.4%
08/27/24	6 PM	20.00	Reduced Load	72.5%
08/27/24	7 PM	19.99	Reduced Load	72.4%
08/27/24	8 PM	20.00	Reduced Load	72.4%
08/27/24	9 PM	20.00	Reduced Load	72.5%
08/27/24	10 PM	20.00	Reduced Load	72.5%
08/27/24	11 PM	13.47	Shutdown	
08/28/24	5 PM	19.79	Startup	
08/28/24	6 PM	20.00	Reduced Load	72.4%
08/28/24	7 PM	19.99	Reduced Load	72.4%
08/28/24	8 PM	19.99	Reduced Load	72.4%
08/28/24	9 PM	20.00	Reduced Load	72.5%
08/28/24	10 PM	20.00	Reduced Load	72.5%
08/28/24	11 PM	20.00	Reduced Load	72.5%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
08/29/24	12 AM	20.00	Reduced Load	72.5%
08/29/24	1 AM	7.90	Shutdown	
08/29/24	5 PM	8.46	Startup	
08/29/24	6 PM	19.52	Reduced Load	70.7%
08/29/24	7 PM	20.00	Reduced Load	72.5%
08/29/24	8 PM	20.00	Reduced Load	72.5%
08/29/24	9 PM	20.00	Reduced Load	72.5%
08/29/24	10 PM	20.00	Reduced Load	72.5%
08/29/24	11 PM	20.00	Reduced Load	72.5%
08/30/24	12 AM	14.32	Shutdown	
08/30/24	7 PM	17.41	Startup	
08/30/24	8 PM	20.00	Reduced Load	72.4%
08/30/24	9 PM	18.84	Shutdown	
09/01/24	7 PM	17.30	Startup	
09/01/24	8 PM	20.00	Reduced Load	72.5%
09/01/24	9 PM	20.00	Reduced Load	72.5%
09/01/24	10 PM	18.99	Shutdown	
09/02/24	5 PM	16.89	Startup	
09/02/24	6 PM	19.99	Reduced Load	72.4%
09/02/24	7 PM	19.99	Reduced Load	72.4%
09/02/24	8 PM	19.96	Reduced Load	72.3%
09/02/24	9 PM	19.99	Reduced Load	72.4%
09/02/24	10 PM	20.00	Reduced Load	72.5%
09/02/24	11 PM	14.35	Shutdown	
09/03/24	3 PM	7.98	Startup	
09/03/24	4 PM	24.66	Reduced Load	89.3%
09/03/24	6 PM	14.26	Shutdown	
09/10/24	2 PM	13.07	Startup	
09/10/24	3 PM	24.50	Reduced Load	88.8%
09/11/24	12 AM	14.73	Shutdown	
09/11/24	10 AM	19.59	Startup	
09/11/24	1 PM	24.78	Reduced Load	89.8%
09/11/24	2 PM	24.76	Reduced Load	89.7%
09/12/24	6 AM	23.85	Shutdown	
09/12/24	3 PM	21.62	Startup	
09/12/24	11 PM	18.44	Shutdown	
09/13/24	2 PM	10.54	Startup	
09/13/24	11 PM	12.20	Shutdown	
09/14/24	4 PM	15.02	Startup	
09/14/24	11 PM	17.06	Shutdown	
09/15/24	4 PM	10.42	Startup	
09/15/24	11 PM	17.00	Shutdown	
09/16/24	5 PM	23.99	Startup	
09/16/24	11 PM	14.06	Shutdown	
09/17/24	5 PM	12.99	Startup	

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
09/17/24	10 PM	20.89	Shutdown	
09/18/24	4 PM	17.75	Startup	
09/18/24	9 PM	15.11	Shutdown	
09/19/24	7 PM	22.64	Startup	
09/19/24	9 PM	12.27	Shutdown	
09/20/24	4 PM	22.26	Startup	
09/20/24	8 PM	19.54	Shutdown	
09/21/24	4 PM	7.65	Startup	
09/21/24	5 PM	23.65	Shutdown	
09/23/24	5 PM	8.87	Startup	
09/23/24	11 PM	8.45	Shutdown	
09/24/24	3 PM	19.16	Startup	
09/24/24	4 PM	24.50	Reduced Load	88.8%
09/24/24	5 PM	24.67	Reduced Load	89.4%
09/24/24	6 PM	24.75	Reduced Load	89.7%
09/24/24	10 PM	21.65	Shutdown	
09/25/24	6 PM	13.43	Startup	
09/25/24	7 PM	24.77	Reduced Load	89.7%
09/25/24	11 PM	10.88	Shutdown	
09/26/24	6 PM	12.31	Startup	
09/26/24	10 PM	22.25	Shutdown	
09/30/24	8 PM	14.10	Startup	
09/30/24	11 PM	11.63	Shutdown	
10/01/24	1 PM	8.99	Startup	
10/01/24	2 PM	24.61	Reduced Load	89.1%
10/01/24	3 PM	24.79	Reduced Load	89.8%
10/01/24	11 PM	18.21	Shutdown	
10/02/24	4 PM	19.02	Startup	
10/03/24	12 AM	12.98	Shutdown	
10/03/24	4 PM	19.76	Startup	
10/04/24	1 AM	17.39	Shutdown	
10/04/24	4 PM	21.54	Startup	
10/05/24	12 AM	12.05	Shutdown	
10/05/24	3 PM	7.91	Startup	
10/05/24	10 PM	20.39	Shutdown	
10/07/24	6 PM	20.83	Startup	
10/07/24	11 PM	8.79	Shutdown	
10/08/24	4 PM	24.55	Startup	
10/08/24	11 PM	19.01	Shutdown	
10/09/24	2 PM	21.30	Startup	
10/09/24	3 PM	24.36	Reduced Load	88.3%
10/09/24	4 PM	24.58	Reduced Load	89.1%
10/10/24	2 AM	17.88	Shutdown	
10/10/24	6 AM	22.33	Startup	
10/10/24	11 AM	24.70	Reduced Load	89.5%

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
10/10/24	12 PM	24.60	Reduced Load	89.1%
10/10/24	1 PM	24.47	Reduced Load	88.6%
10/10/24	2 PM	24.46	Reduced Load	88.6%
10/10/24	3 PM	24.49	Reduced Load	88.7%
10/10/24	4 PM	24.69	Reduced Load	89.4%
10/11/24	1 AM	18.53	Shutdown	
10/11/24	2 PM	11.78	Startup	
10/11/24	3 PM	24.58	Reduced Load	89.1%
10/11/24	4 PM	24.72	Reduced Load	89.6%
10/11/24	5 PM	24.77	Reduced Load	89.8%
10/12/24	2 AM	22.47	Shutdown	
10/12/24	4 PM	13.46	Startup	
10/13/24	12 AM	16.78	Shutdown	
10/13/24	3 PM	18.98	Startup	
10/14/24	4 PM	19.20	Startup	
10/15/24	2 PM	14.91	Startup	
10/15/24	10 PM	20.34	Shutdown	
10/18/24	7 PM	23.49	Startup	
10/18/24	9 PM	23.82	Shutdown	
10/20/24	3 PM	7.41	Startup	
10/20/24	4 PM	24.39	Reduced Load	88.4%
10/20/24	5 PM	24.68	Reduced Load	89.4%
10/20/24	6 PM	24.72	Reduced Load	89.6%
10/21/24	1 AM	20.54	Shutdown	
10/21/24	4 PM	24.78	Startup	
10/21/24	10 PM	21.82	Shutdown	
10/22/24	2 PM	10.51	Startup	
10/22/24	3 PM	24.49	Reduced Load	88.7%
10/22/24	4 PM	24.63	Reduced Load	89.3%
10/22/24	9 PM	19.92	Shutdown	
10/23/24	10 PM	8.81	Shutdown	
10/24/24	2 PM	11.13	Startup	
10/24/24	3 PM	24.15	Reduced Load	87.5%
10/24/24	4 PM	24.33	Reduced Load	88.1%
10/24/24	5 PM	24.68	Reduced Load	89.4%
10/24/24	6 PM	24.72	Reduced Load	89.6%
10/24/24	9 PM	20.20	Shutdown	
10/28/24	8 PM	20.15	Startup	
10/28/24	9 PM	20.79	Shutdown	
10/29/24	4 PM	22.74	Startup	
10/29/24	9 PM	23.87	Shutdown	
10/30/24	10 PM	18.63	Shutdown	
11/04/24	4 PM	7.60	Startup	
11/04/24	5 PM	24.52	Reduced Load	88.8%
11/04/24	10 PM	15.86	Shutdown	

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE
11/13/24	2 PM	10.18	Startup
11/14/24	1 AM	7.44	Shutdown
11/14/24	4 PM	23.17	Startup
11/14/24	9 PM	19.70	Shutdown
11/18/24	5 PM	16.27	Startup
11/18/24	8 PM	14.68	Shutdown
11/19/24	5 PM	19.02	Startup
11/19/24	10 PM	19.05	Shutdown
11/20/24	4 PM	13.55	Startup
11/20/24	10 PM	22.35	Shutdown
11/21/24	4 PM	11.77	Startup
11/21/24	10 PM	19.37	Shutdown
11/22/24	5 PM	16.14	Startup
11/22/24	12 AM	20.97	Shutdown
11/23/24	5 PM	16.11	Startup
11/23/24	11 PM	15.12	Shutdown
11/29/24	6 PM	24.66	Startup
11/29/24	9 PM	15.26	Shutdown
11/30/24	6 PM	24.37	Startup
11/30/24	9 PM	24.06	Shutdown
12/02/24	3 PM	12.76	Startup
12/04/24	5 PM	7.67	Startup
12/04/24	11 PM	7.98	Shutdown
12/05/24	4 PM	17.43	Startup
12/06/24	2 AM	21.61	Shutdown
12/06/24	4 PM	16.58	Startup
12/07/24	12 AM	23.84	Shutdown
12/07/24	4 PM	9.33	Startup
12/07/24	11 PM	7.99	Shutdown
12/08/24	6 PM	18.79	Startup
12/09/24	6 PM	22.89	Startup
12/09/24	10 PM	17.65	Shutdown
12/10/24	8 AM	24.17	Startup
12/10/24	9 AM	21.33	Shutdown
12/12/24	5 PM	21.65	Startup
12/12/24	11 PM	21.09	Shutdown
12/13/24	4 PM	14.90	Startup
12/13/24	10 PM	21.71	Shutdown
12/14/24	6 PM	15.27	Startup
12/14/24	7 PM	24.11	Shutdown
12/15/24	6 PM	16.22	Startup
12/15/24	10 PM	16.67	Shutdown
12/16/24	1 PM	8.81	Startup
12/16/24	9 PM	22.68	Shutdown
12/17/24	6 PM	20.54	Startup

DATE	CLOCK HOUR	GENERATOR OUTPUT POWER	CAUSE	
12/17/24	11 PM	12.43	Shutdown	
12/18/24	3 PM	11.71	Startup	
12/18/24	8 PM	11.85	Shutdown	
12/19/24	1 PM	15.32	Reduced Load	55.5%
12/19/24	2 PM	20.00	Reduced Load	72.4%
12/19/24	3 PM	20.51	Reduced Load	74.3%
12/19/24	8 PM	19.61	Shutdown	
12/23/24	6 PM	13.88	Startup	
12/23/24	8 PM	9.18	Shutdown	
12/31/24	11 AM	16.50	Startup	
12/31/24	3 PM	7.08	Shutdown	
12/31/24	4 PM	22.83	Startup	
12/31/24	7 PM	16.65	Malfunction	
12/31/24	9 PM	23.39	Shutdown	